



Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM, Lawe-lawe, dan DHP

Periode Ke :

844-044 2021

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
1	Senin, 11.10.21	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
2	Senin, 11.10.21	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
3	Senin, 11.10.21	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
4	Senin, 11.10.21	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
5	Senin, 11.10.21	A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
6	Senin, 11.10.21	A-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
7		A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
8		A-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
9		A-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
10		A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
11	Senin, 11.10.21	A-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
12	Senin, 11.10.21	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
13	Senin, 11.10.21	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
14	Senin, 11.10.21	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
15		A-25														
16	Senin, 11.10.21	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
17	Senin, 11.10.21	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
18	Senin, 11.10.21	A-28	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
19	Senin, 11.10.21	A-30	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
20		A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
21		A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
22	Senin, 11.10.21	A-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
23	Senin, 11.10.21	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
24	Senin, 11.10.21	E-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
25	Senin, 11.10.21	E-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
26	Senin, 11.10.21	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
27	Senin, 11.10.21	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
28	Senin, 11.10.21	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
29		T-901														
30	Senin, 11.10.21	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
31	Senin, 11.10.21	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
32	Senin, 11.10.21	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
33	Senin, 11.10.21	T-201	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
34	Senin, 11.10.21	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	

TANK CLEANING

TANK CLEANING

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
35	Pabu. 13. 10. 21	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermiten
36	Pawut. 13.10. 21	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
37	Pawut. 14. 10. 21	D20-05B	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✓	✓	
38		D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
39		D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	Intermiten
40		D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
41		D20-07A	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
42		D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
43		D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	Intermiten
44		D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
45		D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
46		D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
47		D20-01A	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✗	✓	✓	Communication still not connected, cause voltage leak
48		D20-01B														
49		D20-08	✓	✓	✗	✓	✗	✗	✓	✓	✓	✓	✓	✓	✓	
50		D20-13A	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✗	✓	✓	
51	6. 10. 2021	D20-13B	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✗	✓	✓	
52	6. 10. 2021	D20-15A	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✗	✓	✓	
53	6. 10. 2021	D20-15B	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✗	✓	✓	
54	Selatan. 12. 10. 21	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
55	Selatan. 12. 10. 21	R-2	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
56	Selatan. 12. 10. 21	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
57		R-4	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
58		R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
59		R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
60	Selatan. 12. 10. 21	R-7	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
61		R-8	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
62	Selatan. 13. 10. 21	R-9	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
63		R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
64		V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
65		V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
66	Pawut. 14. 10. 21.	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
67	Pawut P. 14. 10. 21	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
68	Pawut. 14. 10. 21	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
69	Pawut. 14. 10. 21	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
70		O-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
71		O-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
72	Selatan. 12. 10. 21	O-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

OVERHAUL

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
73	Selasa 12.10.21	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
74		O-9	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
75	Selasa 12.10.21	O-10	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
76	Selasa 12.10.21	O-11	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
77	Selasa 12.10.21	O-12	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
78	Selasa 12.10.21	O-13	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓	
79	Selasa 12.10.21	O-14	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✗	✓	✓	
80		D20-17	✓	✗	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	MST Rusak, Mainhole MST kecil
81		D20-18	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
82		O-15	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
83	7.10.2021	O-16	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
84		O-17	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
85		O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
86	7.10.2021	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
87	7.10.2021	O-20	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
88	7.10.2021	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
89		O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
90		O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
91		O-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
92		D20-11	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
93		D20-12	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	Spot 2 and 4 Temp broken
94		P-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
95		P-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
96		P-1	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
97		P-2	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
98		P-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
99		P-5	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
100		P-8	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
101		D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
102		TK-101-11A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
103	6.10.2021	TK-101-11B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
104	6.10.2021	TK-101-11C	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
105	6.10.2021	TK-101-11D	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
106	6.10.2021	TK-101-11E	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
107	6.10.2021	TK-101-11F	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
108	6.10.2021	TK-101-11G	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

No	Hari/Tanggal	Nama Tangki	ATG Systems			Tank Master Status		Power Switch		Shroud Cable		Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	

DHP													
NO	Hari/Tanggal	Nama Tangki	ATG Systems			Komunikasi Wireless	Power Switch		Shroud Cable		Ground	Keterangan	
			Level	Interface	TankHub		Fungsional	Shroud Cable	GWR	TankHub			THUMB
1	Februari - 14.10.11	T-01A	✓		✓			✓		✓		✓	
2	Februari, 14.10.11	T-01B	✓		✓			✓		✓		✓	

NOTE :

PT Control Systems


M. Iyahi

Instrument MA2


M. Iyahi

Instrument MA4


ALEAN YUDHA P.