

## Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM, Lawe-lawe, dan DHP

Periode Ke : Feb - Mar 2022

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
1	Rabu, 16-02-2022	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
2	Rabu, 16-02-2022	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
3	Rabu, 16-02-2022	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
4	Rabu, 16-02-2022	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
5	Rabu, 16-02-2022	A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
6	Rabu, 16-02-2022	A-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
7	Rabu, 16-02-2022	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
8	Rabu, 16-02-2022	A-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
9	Rabu, 16-02-2022	A-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
10	Rabu, 16-02-2022	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
11	Selasa, 15-02-2022	A-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
12	Selasa, 15-02-2022	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
13	Selasa, 15-02-2022	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
14	Selasa, 15-02-2022	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
15		A-25	TANK CLEANING													
16	Kamis, 17-02-2022	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
17	Kamis, 17-02-2022	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
18	Kamis, 17-02-2022	A-28	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
19	Kamis, 17-02-2022	A-30	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
20	Kamis, 17-02-2022	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
21	Kamis, 17-02-2022	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
22	Kamis, 17-02-2022	A-33	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	MST is not include FWL Sensor
23	Jum'at, 18-02-2022	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
24	Jum'at, 18-02-2022	E-3	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Need replace cable and cable gland from ATG to MST
25	Jum'at, 18-02-2022	E-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
26	Jum'at, 18-02-2022	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
27	Jum'at, 18-02-2022	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
28	Jum'at, 18-02-2022	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
29		T-901	TANK CLEANING													
30	Selasa, 01-03-2022	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
31	Selasa, 01-03-2022	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	



No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
32	Selasa, 01-03-2022	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
33	Selasa, 01-03-2022	T-201	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
34	Selasa, 01-03-2022	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
35	Selasa, 01-03-2022	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
36	Rabu, 02-03-2022	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
37	Rabu, 02-03-2022	D20-05B	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✓	✓	
38	Rabu, 02-03-2022	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermitten
39	Rabu, 02-03-2022	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
40	Rabu, 02-03-2022	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
41	Rabu, 02-03-2022	D20-07A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
42	Rabu, 02-03-2022	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
43	Rabu, 02-03-2022	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
44	Rabu, 02-03-2022	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
45	Rabu, 02-03-2022	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
46	Rabu, 02-03-2022	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
47	Rabu, 02-03-2022	D20-01A	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✗	✓	✓	
48		D20-01B	OVERHALL													
49	Jum'at, 04-03-2022	D20-08	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	MST is not include FWL Sensor
50	Rabu, 02-03-2022	D20-13A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
51	Rabu, 02-03-2022	D20-13B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
52		D20-15A	MODIFIKASI TANKI RDMP													
53	Rabu, 02-03-2022	D20-15B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
54	Jum'at, 04-03-2022	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
55		D20-15A	MODIFIKASI TANKI RDMP													
56	Jum'at, 04-03-2022	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
57	Jum'at, 04-03-2022	R-4	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
58	Jum'at, 04-03-2022	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
59	Jum'at, 04-03-2022	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
60	Jum'at, 04-03-2022	R-7	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
61	Jum'at, 04-03-2022	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
62	Jum'at, 04-03-2022	R-9	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
63	Jum'at, 04-03-2022	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
64		V-4	TANK CLEANING													
65	Kamis, 10-03-2022	V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
66	Senin, 07-03-2022	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
67	Senin, 07-03-2022	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	



No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
68	Senin, 07-03-2022	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
69	Senin, 07-03-2022	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
70	Senin, 07-03-2022	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
71	Senin, 07-03-2022	O-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
72	Rabu, 09-03-2022	O-6	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	✓	
73	Rabu, 09-03-2022	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
74	Rabu, 09-03-2022	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
75	Rabu, 09-03-2022	O-10	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
76	Rabu, 09-03-2022	O-11	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
77	Rabu, 09-03-2022	O-12	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓	
78	Rabu, 09-03-2022	O-13	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓	
79	Rabu, 09-03-2022	O-14	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✗	✓	✓	
80	Kamis, 10-03-2022	D20-17	✓	✗	✗	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	MST Rusak, Mainhole MST kecil
81	Kamis, 10-03-2022	D20-18	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
82	Selasa, 08-03-2022	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
83	Selasa, 08-03-2022	O-16	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
84	Selasa, 08-03-2022	O-17	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
85	Selasa, 08-03-2022	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
86	Selasa, 08-03-2022	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
87	Selasa, 08-03-2022	O-20	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
88	Selasa, 08-03-2022	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
89	Selasa, 08-03-2022	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
90	Selasa, 08-03-2022	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
91		O-25	TANK CLEANING													
92		D20-11	MODIFIKASI TANKI RDMP													
93		D20-12	MODIFIKASI TANKI RDMP													Spot 2 and 4 Temp broken
94	Kamis, 10-03-2022	P-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
95	Kamis, 10-03-2022	P-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
96	Kamis, 10-03-2022	P-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
97	Kamis, 10-03-2022	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
98		P-3	MODIFIKASI TANKI RDMP													
99	Kamis, 10-03-2022	P-5	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
100	Kamis, 10-03-2022	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
101	Kamis, 10-03-2022	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
102		TK-101-T1A	TANK CLEANING													
103	Senin, 14-03-2022	TK-101-T1B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
104	Senin, 14-03-2022	TK-101-T1C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
105	Senin, 14-03-2022	TK-101-T1D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
106	Senin, 14-03-2022	TK-101-T1E	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
107	Senin, 14-03-2022	TK-101-T1F	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
108	Senin, 14-03-2022	TK-101-T1G	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

NOTE : Agenda Troubleshoot Bulan Depan


DHP													
NO	Hari/Tanggal	Nama Tangki	ATG Systems			Komunikasi wireless	Power Switch		Shroud Cable			Ground	Keterangan
			Level	Interface	TankHub		Fungsional	Shroud Cable	GWR	TankHub	THUMB		
1	Kamis, 10-03-2022	T-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
2	Kamis, 10-03-2022	T-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

NOTE :

PT.Control Systems

  
M. Hasbi

Instrument MA2

  
W. Farhan SP

Instrument MA4

  
M. Haceri T