



Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM, Lawe-lawe, dan DHP

Oil Movement

Periode Ke :

September - Oktober 2020

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
1	Sen 25.9.20	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
2	Sen 25.9.20	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
3	Sen 25.9.20	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
4	Sen 25.9.20	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
5	Sen 25.9.20	A-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
6	Sen 25.9.20	A-6	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
7	Sen 25.9.20	A-15	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
8	Sen 25.9.20	A-17	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
9	Sen 25.9.20	A-21	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
10	Sen 25.9.20	A-22	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
11	Sen 25.9.20	A-23	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
12	Sen 25.9.20	A-24	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
13	Sen 25.9.20	A-25	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
14	Sen 25.9.20	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
15	Sen 25.9.20	A-27	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
16	Sen 25.9.20	A-28	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
17	Sen 25.9.20	A-29	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
18	Sen 25.9.20	A-30	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
19	Sen 25.9.20	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
20	Sen 25.9.20	A-32	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
21	Sen 25.9.20	A-33	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
22	Sen 25.9.20	E-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
23	Sen 25.9.20	E-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
24	Sen 25.9.20	E-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
25	Sen 25.9.20	E-6	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
26	Sen 25.9.20	E-7	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
27	Sen 25.9.20	T-901	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
28	Sen 25.9.20	T-902	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
29	Sen 25.9.20	T-903	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
30	Sen 25.9.20	T-904	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
31	Sen 25.9.20	T-201	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
32	Sen 25.9.20	T-202	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
33	Sen 25.9.20	T-203	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
34	Sen 25.9.20	D20-05A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	



No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Functional	Shroud Cable	RTG	MST	RDU	
35	Sun. 8.10.20	D20-05B	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	
36	Sun. 12.10.20	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
37	Sun. 12.10.20	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
38	Lab. 9.10.20	D20-06B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
39	Sun. 5.10.20	D20-07A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
40	Sun. 12.10.20	D20-07B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
41	Sun. 12.10.20	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
42	Sun. 8.10.20	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
43	Lab. 7.10.20	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
44	Sun. 12.10.20	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
45	Lab. 12.10.20	D20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
46	Lab. 9.10.20	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
47	Lab. 12.10.20	D20-08	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
48	Lab. 9.10.20	D20-13A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
49	Sun. 5.10.20	D20-13B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
50	Sun. 5.10.20	D20-15A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
51	Sun. 5.10.20	D20-15B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
52	Sun. 5.10.20	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
53	Lab. 9.10.20	R-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
54	Lab. 12.10.20	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
55	Sun. 8.10.20	R-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
56	Sun. 8.10.20	R-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
57	Sun. 5.10.20	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
58	Lab. 9.10.20	R-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
59	Sun. 5.10.20	R-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
60	Sun. 8.10.20	R-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
61	Sun. 5.10.20	R-10	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
62	Sun. 5.10.20	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
63	Sun. 5.10.20	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
64	Sun. 5.10.20	V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
65	Sun. 8.10.20	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
66	Sun. 8.10.20	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
67	Sun. 8.10.20	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
68	Sun. 8.10.20	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
69	Sun. 12.10.20	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
70	Sun. 5.10.20	O-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
71	Sun. 5.10.20	O-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
72	Lab. 1.10.20	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	



No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
73	Sen. 20-10-20	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
74	Sen 98-10-20	O-10	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
75	Sen. 2-10-20	O-11	✓	TANK	KOSONG	✓	✓	✓	✓	✓	✓	✓	✓	
76	Sen. 2-10-20	O-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
77	Sen. 6-10-20	O-13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
78	Sen. 98-10-20	O-14	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
79	Sen. 98-10-20	D20-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
80	Sen. 12-10-20	D20-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
81	Sen. 1-10-20	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
82	Sen. 1-10-20	O-16	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
83	Sen. 1-10-20	O-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
84	Sen. 9-10-20	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
85	Sen. 1-10-20	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
86	Sen. 1-10-20	O-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
87	Sen. 1-10-20	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
88	Sen. 6-10-20	O-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
89	Sen. 6-10-20	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
90	Sen. 6-10-20	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
91	Sen. 6-10-20	O-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
92	Sen. 1-10-20	D20-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
93	Sen. 1-10-20	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
94	Sen. 6-10-20	P-31	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
95	Sen. 6-10-20	P-32	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
96	Sen. 6-10-20	P-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
97	Sen. 6-10-20	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
98	Sen. 6-10-20	P-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
99	Sen. 6-10-20	P-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
100	Sen. 1-10-20	P-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
101	Sen. 1-10-20	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
102	Sen. 9-10-20	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
103		TK-101-T1A		TANK	CLEANING									
104		TK-101-T1B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
105		TK-101-T1C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
106		TK-101-T1D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
107		TK-101-T1E	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
108		TK-101-T1F	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
109		TK-101-T1G	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

FWL kadang2 error.

Temp broken, ATG mining



No	Har/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	

DHP														
NO	Har/Tanggal	Nama Tangki	ATG Systems				Komunikasi wireless	Power Switch			Shroud Cable			Keterangan
			Level	Interface	TankHub			Fungsional	Shroud Cable		GWR	TankHub	THUMB	
1	Jun 9-10-2020	T-01A	✓	✓	✓		✓	✓	✓		✓	✓	✓	
2	Jun 9-10-2020	T-01B	✓	✓	✓		✓	✓	✓		✓	✓	✓	


NOTE :

T-01A level oil discentg selidik - 30 mm.

PT Control Systems

  
M. Hasybi

Instrumen MA2

  
H. Hasybi

Instrumen MA4

  
H. Hasybi