

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM, Lawe-lawe, dan DHP

Periode Ke :

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	PWL	RDU	Tank Master	Intranet	Functional	Shroud Cable	RTG	MST	RDU	RTG	MST	
1	Senin, 16 Agustus 2021	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
2	Senin, 16 Agustus 2021	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
3	Senin, 16 Agustus 2021	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
4	Senin, 16 Agustus 2021	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
5	Senin, 16 Agustus 2021	A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
6	Senin, 16 Agustus 2021	A-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
7	Senin, 16 Agustus 2021	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
8	Senin, 16 Agustus 2021	A-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
9	Senin, 16 Agustus 2021	A-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
10	Senin, 16 Agustus 2021	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
11	Kamis, 19 Agustus 2021	A-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
12	Kamis, 19 Agustus 2021	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
13	Kamis, 19 Agustus 2021	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
14	Kamis, 19 Agustus 2021	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
15		A-25	TANK CLEANING													
16	Kamis, 19 Agustus 2021	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
17	Kamis, 19 Agustus 2021	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
18	Kamis, 19 Agustus 2021	A-28	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
19	Kamis, 19 Agustus 2021	A-30	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
20	Senin, 23 Agustus 2021	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
21	Senin, 23 Agustus 2021	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
22	Kamis, 19 Agustus 2021	A-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
23	Jumat, 20 Agustus 2021	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
24	Jumat, 20 Agustus 2021	E-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
25	Jumat, 20 Agustus 2021	E-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
26	Jumat, 20 Agustus 2021	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
27	Jumat, 20 Agustus 2021	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
28	Jumat, 20 Agustus 2021	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
29		T-901	TANK CLEANING													
30	Senin, 23 Agustus 2021	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
31	Senin, 23 Agustus 2021	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
32	Senin, 23 Agustus 2021	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
33	Senin, 23 Agustus 2021	T-201	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
34	Senin, 23 Agustus 2021	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
35	Senin, 23 Agustus 2021	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
36	Salasa, 24 Agustus 2021	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermitten



No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan		
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST			
37	Selasa, 24 Agustus 2021	D20-05B	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✓	✓	Intermitten		
38	Selasa, 24 Agustus 2021	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		Intermitten	
39	Selasa, 24 Agustus 2021	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓			Intermitten
40	Selasa, 24 Agustus 2021	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		Intermitten	
41	Selasa, 24 Agustus 2021	D20-07A	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	Intermitten		
42	Selasa, 24 Agustus 2021	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓			Intermitten
43	Selasa, 24 Agustus 2021	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermitten		
44	Selasa, 24 Agustus 2021	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
45	Selasa, 24 Agustus 2021	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
46	Selasa, 24 Agustus 2021	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
47	Selasa, 24 Agustus 2021	D20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓			
48		D20-01B	OVERHAUL															
49	Rabu, 25 Agustus 2021	D20-08	✓	✓	✗	✓	✗	✗	✓	✓	✓	✓	✓	✓	✓	Communication still not connected, cause voltage leak		
50	Rabu, 25 Agustus 2021	D20-13A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓			
51	Rabu, 25 Agustus 2021	D20-13B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓			
52	Rabu, 25 Agustus 2021	D20-15A	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓			
53	Rabu, 25 Agustus 2021	D20-15B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓			
54	Kamis, 26 Agustus 2021	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓			
55	Kamis, 26 Agustus 2021	R-2	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓			
56	Kamis, 26 Agustus 2021	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓			
57	Kamis, 26 Agustus 2021	R-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓			
58	Kamis, 26 Agustus 2021	R-5	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓			
59	Kamis, 26 Agustus 2021	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓			
60	Kamis, 26 Agustus 2021	R-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓			
61	Kamis, 26 Agustus 2021	R-8	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓			
62	Kamis, 26 Agustus 2021	R-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓			
63	Kamis, 26 Agustus 2021	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓			
64	Senin, 26 Juli 2021	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
65	Senin, 26 Juli 2021	V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
66	Jumat, 27 Agustus 2021	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
67	Jumat, 27 Agustus 2021	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
68	Jumat, 27 Agustus 2021	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
69	Jumat, 27 Agustus 2021	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
70	Jumat, 27 Agustus 2021	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
71	Jumat, 27 Agustus 2021	O-4	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓			
72	Jumat, 27 Agustus 2021	O-6	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✓	✓			
73	Jumat, 27 Agustus 2021	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
74	Senin, 30 Agustus 2021	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
75	Senin, 30 Agustus 2021	O-10	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓			
76	Senin, 30 Agustus 2021	O-11	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓			

OVERHAUL

Communication still not connected, cause voltage leak



No	Hari/Tanggal	Nama Tangki	ATG systems				Tank Master Status		Power switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Functional	Shroud Cable	RTG	MST	RDU	RTG	MST	
77	Senin, 30 Agustus 2021	O-12	✓	✓	✓	✓	✓	✓	✓	X	✓	✓	✓	✓	✓	
78	Senin, 30 Agustus 2021	O-13	✓	✓	✓	✓	✓	✓	✓	X	✓	✓	✓	✓	✓	
79	Senin, 30 Agustus 2021	O-14	✓	✓	✓	✓	✓	✓	X	X	X	X	X	✓	✓	
80	Selasa, 31 Agustus 2021	D20-17	✓	X	✓	✓	✓	✓	✓	✓	✓	✓	X	✓	✓	
81	Selasa, 31 Agustus 2021	D20-18	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
82	Selasa, 31 Agustus 2021	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	
83	Selasa, 31 Agustus 2021	O-16	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
84	Selasa, 31 Agustus 2021	O-17	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
85	Selasa, 31 Agustus 2021	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
86	Selasa, 31 Agustus 2021	O-19	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	✓	
87	Selasa, 31 Agustus 2021	O-20	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
88	Selasa, 31 Agustus 2021	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
89	Selasa, 31 Agustus 2021	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
90	Rabu, 1 September 2021	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
91		O-25														
92	Rabu, 1 September 2021	D20-11	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
93		D20-12														
94	Rabu, 1 September 2021	P-31	✓	✓	✓	✓	✓	✓	✓	X	✓	X	X	✓	✓	Spot 2 and 4 Temp broken
95	Rabu, 1 September 2021	P-32	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	
96	Rabu, 1 September 2021	P-1	✓	✓	✓	✓	✓	✓	✓	X	✓	X	X	✓	✓	
97	Rabu, 1 September 2021	P-2	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	
98		P-3														
99	Rabu, 1 September 2021	P-5	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	
100	Rabu, 1 September 2021	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
101	Rabu, 1 September 2021	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	
102		TK-101-T1A														
103	Rabu, 3 September 2021	TK-101-T1B	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	
104	Rabu, 3 September 2021	TK-101-T1C	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	
105	Rabu, 3 September 2021	TK-101-T1D	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	
106	Rabu, 3 September 2021	TK-101-T1E	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	
107	Rabu, 3 September 2021	TK-101-T1F	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
108	Rabu, 3 September 2021	TK-101-T1G	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

TANK CLEANING

TANK CLEANING

TANK CLEANING


DHP											Keterangan
NO	Hari/Tanggal	Nama Tangki	ATG Systems			Power Switch		Shroud Cable		Ground	
			Level	Interface	TankHub	Komunikasi wireless	Functional	Shroud Cable	GWNR		
1	Rabu, 8 September 2021	T-01A	✓	✓	✓	✓	✓	✓	✓	✓	
2	Rabu, 8 September 2021	T-01B	✓	✓	✓	✓	✓	✓	✓	✓	

NOTE :




No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	PWL	RDU	Tank Master	Intranet	Functional	Shroud Cable	RTG	MST	RDU	RTG	MST	


PT. Control Systems

  
M. Platy.

Instrument MA2

  
H. S. W. A.

Instrument MA4

  
M. Platy