



Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM, Lawe-lawe, dan DHP

Oil Movement

Periode Ke :

Januari - Februari 2021

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
1	Sen. 10.1.21	A-1	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
2	Sen. 10.1.21	A-2	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
3	Feb 20.1.21	A-3	✓	✓	✓	✓	✓	✓	✓	X	X	✓	X	
4	Feb 20.1.21	A-4	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
5	Feb 20.1.21	A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
6	Feb 20.1.21	A-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
7	Feb 11.2.21	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
8	Feb 3.2.21	A-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
9	Sen. 10.1.21	A-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
10	Sen. 10.1.21	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
11	Sen. 10.1.21	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
12	Sen. 10.1.21	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
13	Sen. 10.1.21	A-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
14	Feb. 11.2.21	A-26	✓	✓	✓	✓	✓	✓	✓	X	X	✓	X	
15	Sen. 10.1.21	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
16	Sen. 10.1.21	A-28	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
17	Sen. 10.2.21	A-29	MODIFIKASI		PDMF		✓	✓	MODIFIKASI		PDMF		✓	
18	Feb. 3.2.21	A-30	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
19	Feb 23.2.21	A-31	✓	✓	✓	✓	✓	✓	✓	X	✓	✓	X	
20	Feb. 02.2.21	A-32	✓	✓	✓	✓	✓	✓	✓	✓	X	✓	X	
21	Sen. 10.1.21	A-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
22	Feb. 20.1.21	E-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
23	Feb. 20.1.21	E-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
24	Feb 20.1.21	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
25	Feb 20.1.21	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
26	Feb. 20.1.21	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
27	Sen. 1.2.21	T-901	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
28	Sen. 1.2.21	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
29	Sen. 1.2.21	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
30	Feb. 1.2.21	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
31	Sen. 1.2.21	T-201	✓	✓	Error		✓	✓	✓	✓	✓	✓	X	FWL Error.
32	Sen. 1.2.21	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	
33	Sen. 1.2.21	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
34	Sun. 8.8.21	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
35	Sun 8.8.21	D20-05B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
36	Sun 8.8.21	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
37	Sun 8.8.21	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
38	Sun 15.8.21	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
39	Sab 9.8.21	D20-07A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent
40	Sun 15.8.21	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent
41	Sun 8.8.21	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
42	Sun 15.8.21	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
43	Sun 8.8.21	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
44	Sun 15.8.21	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
45	Sun 15.8.21	D20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
46	Sun 15.8.21	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
47	Sun 8.8.21	D20-08	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
48	Kem. 4.8.21	D20-13A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
49	Kem 4.8.21	D20-13B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
50	Pab 27.1.21	D20-15A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
51	Pabu 27.1.21	D20-15B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
52	Sun. 28.1.21	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
53	Sun 28.1.21	R-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
54	Sun 8.8.21	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
55	Sun. 8.8.21	R-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
56	Sun. 28.1.21	R-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
57	Sun. 8.8.21	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
58	Sun. 27.1.21	R-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
59	Sun. 8.8.21	R-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
60	Sun 27.1.21	R-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
61	Sun 15.8.21	R-10	TANK	CLEANING					TANK	CLEANING				
62	Sun 15.8.21	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent
63	Sun 15.8.21	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent
64	Sun 15.8.21	V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent
65	Sun. 29.1.21	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent
66	Sun 29.1.21	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent
67	Sab. 8.8.21	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent
68	Sab 8.8.21	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent
69	Sun 15.8.21	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent
70	Kem. 4.8.21	O-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermittent

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	PWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
71	Senin 8. 21.		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermitten
72	Kam. 4.2.21		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermitten
73	Sabtu 26.1.21	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
74	Sabtu 26.1.21	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
75	Sabtu 26.1.21	O-10	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
76	Sabtu 26.1.21	O-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
77	Sabtu 26.1.21	O-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermitten.
78	Sabtu 26.1.21	O-13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
79	Sabtu 26.1.21	O-14	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
80	Dom. 4.2.21	D20-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermitten
81	Sabtu 26.1.21	D20-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermitten.
82	Sabtu 26.1.21	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
83	Sabtu 26.1.21	O-16	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
84	Sabtu 26.1.21	O-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
85	Sabtu 26.1.21	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
86	Sabtu 26.1.21	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
87	Sabtu 26.1.21	O-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
88	Sabtu 26.1.21	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
89	Dom. 4.2.21	O-22	MODIFIKASI	✓	✓	✓	✓	✓	MODIFIKASI	✓	✓	✓	✓	
90	Dom. 4.2.21	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
91	Dom. 4.2.21	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
92	Dom. 4.2.21	O-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
93	Dom. 4.2.21	D20-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
94	Dom. 4.2.21	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Spot 2, 4 temp rusak.
95	Dom. 29.1.21	P-31	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
96	Dom. 29.1.21	P-32	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
97	Dom. 29.1.21	P-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
98	Dom. 29.1.21	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
99	Dom. 29.1.21	P-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
100	Dom. 11.2.21	P-4	MODIFIKASI	✓	✓	✓	✓	✓	MODIFIKASI	✓	✓	✓	✓	intermitten.
101	Dom. 11.2.21	P-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
102	Dom. 11.2.21	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
103	Dom. 11.2.21	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	intermitten.
104	Dom. 11.2.21	TK-101-T1A	TANK	CLEANING	✓	✓	✓	✓	TANK	CLEANING	✓	✓	✓	
105	Dom. 11.2.21	TK-101-T1B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
106	Dom. 11.2.21	TK-101-T1C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
107	Dom. 11.2.21	TK-101-T1D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
108	Dom. 11.2.21	TK-101-T1E	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	


No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
108	Sen. 1. 2. 21	TK-101-T1F	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Full Error.
109	Sen. 1. 2. 21	TK-101-T1G	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	

DHP

NO	Hari/Tanggal	Nama Tangki	ATG Systems			Komunikasi Wireless	Power Switch		Shroud Cable			Keterangan
			Level	Interface	TankHub		Fungsional	Shroud Cable	GWR	TankHub	THUMB	
1	Des. 20. 1. 21	T-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	
2	Des. 20. 1. 21	T-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	

NOTE :

PT. Control Systems


M. Faria

Instrument MA2


Irfan SP

Instrument MA4


Aristo L.