

PRE-LICENSING INSPECTION SCORECARD

Adult Day Care • Group Home • Assisted Living Facility

This is a universal foundational checklist based on standard ADA and building safety codes. Always double-check your local state administrative code (e.g., Chapter 59A in Florida or Chapter 551 in Texas) for localized variances.

FACILITY INSPECTION DETAILS

Date: _____ Inspector: _____

Property Address: _____

Target Model: ☐ Adult Day Care ☐ Group Home ☐ Assisted Living Facility

SECTION 1: EXTERNAL ACCESS & ADA COMPLIANCE

- ☐ **The Approach:** Continuous, unobstructed pathway from parking to entrance.
- ☐ **The Ramps:** Adequate space for 1:12 slope ratio installation.
- ☐ **Door Widths:** At least 32 inches clear width for wheelchairs.
- ☐ **Thresholds:** Flush or under 0.5 inches with beveled edges.

SECTION 2: INTERNAL PATHWAYS & COMMON AREAS

- ☐ **Hallway Clearance:** At least 36 inches wide, obstruction-free.
- ☐ **Flooring Hazards:** Level flooring, no high-pile carpets or loose rugs.
- ☐ **Lighting Levels:** Bright and well-lit hallways, stairwells, and exits.
- ☐ **Handrails:** Structural framing present for secure handrail installation.

SECTION 3: RESIDENT BEDROOMS

- ☐ **Square Footage (Private):** 80–100 sq ft usable floor space per resident.
- ☐ **Square Footage (Shared):** 60–80 sq ft per resident in shared rooms.
- ☐ **Window Requirements:** Operable window present for emergency egress.
- ☐ **Closet Space:** Dedicated closet or wardrobe space per bed.

SECTION 4: BATHROOMS & HIGH-RISK WET AREAS

Focus on moisture control, physical safety clearances, and high-frequency state citation areas.

☐ **Door Swing Clearance:** Bathroom doors must swing outward or be equipped with double-acting hinges. This ensures emergency access if a resident falls against the inside of the door.

☐ **Grab Bar Structural Integrity:** Grab bars must be securely anchored into structural wall framing (blocking). Must support at least 250 lbs of shear force — not merely screwed into drywall.

☐ **Turning Radius:** A clear, unobstructed turning space of at least 60 inches in diameter (or a T-shaped turnaround) inside the main bathroom to accommodate wheelchairs.

☐ **Anti-Scald Valve Controls:** Mixing valves must be installed on water lines to ensure hot water at resident fixtures never exceeds safe state limits (typically 105°F–115°F nationwide).

☐ **Shower Entry:** Zero-threshold roll-in shower design for wheelchair accessibility.

☐ **Flooring Slip Resistance:** Flooring materials must be non-slip or textured when wet. Zero high-gloss tile or polished surfaces allowed in bathing and wet areas.

SECTION 5: LIFE SAFETY & INFRASTRUCTURE

☐ **Sprinkler Main:** 1.5+ inch line available for commercial sprinkler system.

☐ **Exit Signage:** Line of sight to two exits with illuminated emergency signs.

☐ **HVAC System:** Working in all rooms with lockable thermostat controls.

SCORING BREAKDOWN

Score Range	Zone	Status	Action
20–23 Boxes	GREEN ZONE	✓ Approved	Minimal modifications needed.
15–19 Boxes	YELLOW ZONE	■ Caution	Moderate investment required.
Under 15	RED ZONE	✗ Walk Away	Severe renovations needed.

NOTES & DISCREPANCIES ACTION LOG

Use this log as a negotiation tool. Present identified deficiencies to your landlord to negotiate rent reductions or build-out credits prior to signing a lease.

Item / Room #	Deficiency Found (e.g., 'Hallway measures 34" instead of 36"')	Est. Contractor Fix Cost