


Test Procedure Reference	Test Procedure Reference	Job No.	Job Number
Unique No.	Unique Number	Test Description	Calibration
R&D Reference	R&D Reference	Test Date	29/09/2025
Valve Description	Valve Description	Valve Drawing No.	Valve Drawing Number



Calibration Ambient Temperature



Applied (mV)	-5.89	9.28	24.46	39.64	54.81
Counts (avg)	19	19.0	19.0	19.0	19.0
Converted (mV)	2.577	2.577	2.58	2.58	2.581
Abs Error (mV) - ±0.12 mV	8.47	6.7	21.88	37.06	52.23

Data Recording Equipment Used

Data Logger FAT Rig 1

Serial No. a53beec16f67e4c2

Transducers

Gauges

Torque Transducer N/A

Cycle Count 1

Test Pressure 0 psi

Breakout Torque N/A

Running Torque N/A

Coefficient	Value
S3	7048489.65813077
S2	-402638375.521734
S1	7666780326.15897
S0	-48661963202.5433

3rd Party Stamp and Date

Operative: Toby Lelean