SF 30 CONTINUATION PAGE

AMENDMENT 0001

RFQ 140FF027Q0038

Warm Springs National Fish Hatchery, Quarters #4

Painting and Flooring Installation

Amendment Number	0001
Effective Date	November 9, 2026
Quotation Due Date/Time	November 24, 2026, at 5:00 p.m. PST
Acknowledgment	Offerors shall acknowledge this amendment with their quotation.

1. Purpose of Amendment

The purpose of this amendment is to provide consolidated Government responses to questions received, resolve identified inconsistencies, and clarify solicitation requirements. Except as changed by this amendment, all other terms and conditions remain unchanged.

2. Solicitation Changes

Section L.2.1.3(c) - Oregon CCB License

Delete the existing requirement and replace it with: "Proof of a current and valid Oregon Construction Contractors Board (CCB) license held by the prime quoter or the proposed subcontractor(s) that will perform the regulated work. If a proposed subcontractor license is submitted, the quoter shall identify that subcontractor in the Bid Schedule and include a copy of the current license with the technical submission."

Section L.2.1.4 - Experience

Replace "references and three examples" with "references for up to three projects similar in size, scope, and complexity completed within the last three years." Experience submitted for a proposed subcontractor must clearly identify the entity that performed the work and its role.

Section F / Period of Performance

The Government anticipates issuing the Notice to Proceed within 30 calendar days after award. The contractor shall commence work within 30 calendar days after receipt of the Notice to Proceed and complete all work within 60 calendar days after receipt of the Notice to Proceed. The anticipated on-site performance window is January 19, 2027 through February 19, 2027. If the actual Notice to Proceed date causes those dates to differ, the Notice to Proceed and FAR 52.211-10 govern.

Quotation Deadline

The quotation deadline is November 24, 2026, at 5:00 p.m. Pacific Standard Time (PST). Any inconsistent deadline shown elsewhere is superseded.

Site Visit

The organized site visit is Tuesday, November 10, 2026, at 12:00 p.m. PST, at 1 Fish Hatchery Road, Warm Springs, Oregon 97761. Any inconsistent date shown elsewhere is superseded.

3. Consolidated Questions and Answers

Q1. Must the prime quoter hold the Oregon CCB license, or may a performing subcontractor provide the required license?

A1. A current and valid Oregon Construction Contractors Board (CCB) license may be provided by the prime quoter or by the proposed subcontractor(s) that will perform the regulated construction work. If relying on a subcontractor license, the quoter shall identify the subcontractor in the Bid Schedule and include a copy of the subcontractor current Oregon CCB license with the technical submission.

Q2. May a prime identify separate painting and flooring subcontractors, and what information is required?

A2. Yes. A quoter may identify separate painting and flooring subcontractors. The completed Bid Schedule shall include the name and address of each proposed subcontractor, as applicable, together with any documentation required by this amendment.

Q3. May a quoter submit relevant experience of a proposed subcontractor?

A3. Yes. Relevant experience of a proposed subcontractor that will perform a material portion of the work may be submitted. Each project shall clearly identify the entity that performed the work, that entity's role, and the information required by Section L.2.1.4, as revised by this amendment.

Q4. Does FAR 52.219-14 apply?

A4. No. FAR 52.219-14, Limitations on Subcontracting, is not included in this solicitation and does not apply to this requirement. Quoters shall comply with all clauses and requirements incorporated into the solicitation.

Q5. Which wage classifications apply to the painting and flooring work?

A5. Wage Determination OR20260009 does not include classifications appropriate for the skilled painting and soft-floor-laying work required by this solicitation. The listed Carpenter classification covers formwork and does not include soft-floor laying. The Laborer classification applies to unskilled work and is not appropriate for skilled painter work. After contract award, the contractor shall initiate the conformance process for each required classification not listed in the wage determination, in accordance with FAR 52.222-6 and the applicable Davis-Bacon requirements. The contractor shall submit the proposed additional classification and wage and fringe-benefit rate to the Contracting Officer for review and transmittal to the U.S. Department of Labor. Quoters remain responsible for pricing all labor necessary to perform the requirement.

Q6. Are there labor-compliance or certified-payroll requirements beyond the solicitation?

A6. No additional project-specific requirements are imposed by this amendment. The contractor shall comply with the labor clauses in the solicitation. Certified payrolls and the Statement of Compliance required by FAR 52.222-8 shall be attached to the applicable Invoice Processing Platform invoice.

Q7. Which period of performance controls?

A7. The Government anticipates issuing the Notice to Proceed within 30 calendar days after award. The contractor must commence work within 30 calendar days after receiving the Notice to Proceed and complete all work within 60 calendar days after receiving it. The anticipated on-site performance window is January 19, 2027 through February 19, 2027. If the actual Notice to Proceed date causes those dates to differ, the Notice to Proceed and FAR 52.211-10 govern.

Q8. Is the site visit November 10 or November 12, 2026?

A8. The site visit is Tuesday, November 10, 2026, at 12:00 p.m. PST. Any inconsistent date in the SAM.gov notice is superseded.

Q9. Is an RSVP required, and may a subcontractor attend on behalf of the prime?

A9. No advance RSVP is required. A proposed subcontractor may attend on behalf of or with a prospective prime quoter. All substantive technical and contractual questions must be submitted in writing to nicole_johnson@ios.doi.gov in accordance with Section L.

Q10. Where should attendees park and check in, and who will lead the site visit?

A10. The site visit will be held at Warm Springs National Fish Hatchery, 1 Fish Hatchery Road, Warm Springs, Oregon 97761. The gate will be open. Attendees should park in the designated visitor parking lot next to the Main Building/Visitor Center and sign in upon arrival. Government personnel will be watching for arriving

contractors. Kenneth Lujan and Jorge Alcala, the Contracting Officer Representative, will meet attendees and escort the group to Quarters #4. Attendees may use available online maps or navigation applications for directions. Cellular reception may be limited. For day-of-visit assistance, Kenneth Lujan may be reached at (541) 490-3728.

Q11. What is the closing time for quotations?

A11. Quotations are due November 24, 2026, at 5:00 p.m. Pacific Standard Time (PST). Any inconsistent time shown elsewhere is superseded.

Q12. Are bid, performance, or payment bonds required?

A12. No bid bond is required with the quotation. Performance and payment bonds are not required if the proposed award amount is $35,000 or less. If the proposed award amount exceeds $35,000, the Government will require the applicable bonds before award or before the contractor begins work, as directed by the Contracting Officer.

Q13. What insurance documentation is required?

A13. The solicitation does not prescribe specific coverage types or limits. The contractor shall maintain insurance required by applicable law. The apparent successful quoter shall provide a current Certificate of Insurance upon request by the Contracting Officer and before commencement of on-site work.

Q14. Are badging, escort, or other site-access requirements applicable?

A14. No badges, security clearances, escorts for entry, or special site-access credentials are required. The Warm Springs National Fish Hatchery is open to the public. Contractor personnel shall carry photo identification, sign in with hatchery personnel upon arrival, and comply with the site coordination requirements identified in the solicitation. Contractor access will be limited to areas necessary for performance of the contract.

Q15. Which permits are required?

A15. The Government has not identified a specific permit required for this work. The contractor is responsible for determining whether any permits are required and for obtaining and paying for them. Applicable permit costs shall be included in the firm-fixed price.

Q16. Is a lead or asbestos survey available, and should quotations include abatement?

A16. No lead or asbestos survey is available. The residence was last painted in 2015, and the Government does not expect lead-based paint or asbestos-containing materials to be encountered. Quoters shall not include hazardous-material abatement that is not identified in the solicitation. If suspected hazardous material is encountered, the contractor shall stop work in the affected area and immediately notify the Contracting Officer in accordance with Section H.7.

Q17. Is Sherwin-Williams Emerald Interior Acrylic Latex in satin finish acceptable?

A17. An alternate brand may be considered as an approved equal if the submitted product information demonstrates compliance with the solicitation's low-VOC and other performance requirements. The specified finish remains eggshell for walls and ceilings and semi-gloss for doors and trim. Satin is not accepted as a substitute for the required eggshell finish. Product data and manufacturer warranty information shall be submitted as required by Section L.

4. Administrative

Offerors shall acknowledge receipt of this amendment. Failure to acknowledge the amendment may result in the quotation not being considered for award. Except as expressly revised by this amendment, all other solicitation terms and conditions remain unchanged.