AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		6

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0003	10/29/2026		

6. ISSUED BY CODE FSE

FWS, SAT Team 3
5275 Leesburg Pike
Falls Church VA 22041

7.ADMINISTERED BY *(If other than Item 6)* CODE

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

CODE FACILITY CODE

(X) 9A. AMENDMENT OF SOLICITATION NUMBER
140FF027Q0053

[X] 9B. DATED *(SEE ITEM 11)*
10/29/2026

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

[ ]

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [ ] is extended. [X] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE

[ ] A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.

[ ] B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

[ ] C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

[ ] D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor [ ] is not [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

See continuation page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		Fred Riley	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	

Previous edition unusable

STANDARD FORM 30 (REV. 11/2016)
Prescribed by GSA FAR (48 CFR) 53.243

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	Amendment 0003 is necessary to address concerns posed from industry. Closing remains Monday, November 16, 2026, at 2:00pm. All other terms and conditions remain unchanged. Mold remediation, Merritt Island NWR Tech POC Name/#: Keith Ramos (321) 861-2278 Contract POC: Fred Riley, Fred_riley@ios.doi.gov				

Questions and Answers

Question 1: PWS Section 4.3 says an asbestos inspection report would be provided before the solicitation. It is not among the posted attachments. Can you provide it, or confirm none exists?

Answer 1: The Government has located a February 2012 Comprehensive Asbestos Survey that includes the project facility, identified as the Fire Cache/Administrative Building. The survey will be provided as an attachment to the solicitation amendment.

Because the 2012 survey does not address every material anticipated to be disturbed under the current mold-remediation scope, the Government will also obtain a supplemental, affected-area asbestos inspection. The supplemental report will be provided to the Contractor before intrusive work begins.

Offerors shall not include asbestos inspection, testing, or abatement in their proposed prices. If the supplemental inspection identifies asbestos-containing material that affects the scope, schedule, or performance requirements, the Government will address it through an appropriate solicitation amendment or contract modification before the affected material is disturbed.

Question 2: Insurance: PWS Section 10 states that insurance requirements will be established in the solicitation. Please provide the required coverages and minimum limits.

Answer 2: The Contractor shall maintain the following insurance throughout contract performance:

1. Workers' Compensation: Statutory limits required by applicable Federal and Florida law.

2. Employer's Liability: Not less than $100,000.

3. Commercial General Liability: Not less than $500,000 per occurrence for bodily injury.

4. Automobile Liability for vehicles used in contract performance: Not less than $200,000 per person and $500,000 per occurrence for bodily injury, and $20,000 per occurrence for property damage.

5. Contractor's Pollution Liability, including mold-related operations: $1,000,000 per occurrence or claim and $2,000,000 aggregate.

The Contractor shall provide evidence of the required insurance before commencing work. Required coverage shall apply to subcontractors performing work on the Government installation, consistent with FAR 52.228-5.

Question 3: The Bio Pro assessment report recommends removal of affected attic roof decking and replacement of the conference-room flex duct. The PWS excludes both (cleaning of decking only; flex duct removal only). Please confirm that offerors should price strictly to the PWS.

Answer 3: Confirmed. Offerors shall price the work expressly defined by the PWS. The base scope includes cleaning and remediation of retained attic roof decking and removal and disposal of the identified contaminated conference-room flex-duct branch. Roof-deck removal or replacement and flex-duct replacement are excluded.

The assessment report documents existing conditions and informs the remediation protocol, but it does not add reconstruction or replacement work expressly excluded by the PWS. If roof decking cannot be successfully remediated, or additional replacement work is determined necessary, the condition shall be documented and referred to the Government for separate action. No excluded work may be performed without written authorization from the Contracting Officer.

Question 4: Have the identified water-intrusion sources at the north-side walls and window assemblies already been corrected?

Answer 4: No. The source of water intrusion at the north-side window assemblies has not yet been permanently corrected. The Government will have the affected window assemblies secured and sealed before mold-remediation work begins.

Question 5: If not, does the Government have a separate repair plan, and are those corrections anticipated before mold-remediation work begins?

Answer 5: Yes. Before mold-remediation work commences, the Government will have the affected north-side window assemblies secured and sealed. This work is separate from the mold-remediation contract and shall not be included in the Contractor's proposed price. The mold-remediation Contractor will not be held responsible for subsequent water intrusion through the Government-repaired or sealed window assemblies, or for water damage or mold growth resulting from such intrusion. This allocation does not relieve the Contractor of responsibility for intrusion or damage directly caused by its own actions, damage to the completed repair or weatherproofing, or failure to protect an opening created during its work.

Question 6: If permanent repairs will occur later, will temporary weatherproofing or other moisture-control measures be provided to prevent additional intrusion during remediation and clearance?

Answer 6: Yes. The Government will provide temporary exterior covering or weatherproofing at the affected north-side window assemblies before intrusive remediation activities. The temporary protection will be maintained as necessary to prevent additional water intrusion until the permanent window repairs are completed. The mold-remediation Contractor remains responsible for protecting any openings it creates, maintaining containment and temporary humidity control, and promptly reporting any evidence of additional moisture intrusion.

Question 7: If additional water intrusion occurs during the remediation or drying period, how will the resulting interruption, restoration of acceptable conditions, and any necessary schedule or scope adjustments be addressed?

Answer 7: If additional water intrusion occurs, the Contractor shall immediately notify the COR, document the condition with photographs and moisture readings, and suspend work in the affected area when necessary to protect personnel, containment, completed work, and materials to remain. The Contractor shall take reasonable temporary protective measures within its control but shall not perform permanent building-envelope repairs or expand the remediation scope without written authorization from the Contracting Officer. The Government will evaluate and address the source of the new intrusion and will authorize resumption of affected work after the area is adequately protected. Before post-remediation verification, the affected area must again meet the SOW requirements for drying, cleanliness, moisture content, and relative humidity. If the additional intrusion or resulting deficiency is attributable to the Contractor's failure to maintain required protection, containment, temporary closures, or humidity control, corrective work and repeat testing will be performed at no additional cost to the Government. If the intrusion is outside the Contractor's control, any demonstrated effect on contract time, cost, or scope will be evaluated under the applicable contract terms and must be authorized through a written contract modification. No adjustment is automatic.

Question 8: The contractor's pollution liability requirement calls for coverage that includes mold-related operations, but the minimum limit is blank. Could you confirm the required per-occurrence and aggregate limits, and whether the air-handler cleaning subcontractor must carry its own pollution liability policy or can be covered under the prime contractor's policy?

Answer 8: Contractor's Pollution Liability limits of $1,000,000 per occurrence or claim and $2,000,000 aggregate. Coverage should specifically include mold, fungi, microbial contamination, HVAC and air-handler cleaning, containment failure, cleanup, transportation, and disposal. The prime contractor should maintain this coverage, and any subcontractor performing air-handler, duct-cleaning, or other mold-related work should carry its own pollution-liability coverage at the same limits, even if the prime

contractor’s policy also provides coverage. Certificates of Insurance should be required before the applicable work begins.