ASBESTOS MATERIALS RE-ASSESSMENT 2025
BUILDING 3

FLOOR	FUNCTIONAL SPACE/ROOM		AHERA MATERIAL									REMOVAL COST 2025
			VCT/Mastic*		Transite/Panel Radiator **		TSI/Fittings***		Caulk		Condition	(Approximated)
	2019	2025	Qty.	Unit	Qty.	Unit	Qty.	Unit	Qty.	Unit		
1st	114	114			1	Ea.	20	LF				$ 206.00
1st	115	115	149	SF	1	Ea.	60	LF				$ 1,500.00
1st	116	116	147	SF	1	Ea.						$ 888.00
1st	117	117	140	SF	1	Ea.						$ 846.00
1st	117A	117A	102	SF	1	Ea.	20	LF				$ 818.00
1st	118	118	175	SF	1	Ea.	20	LF				$ 1,256.00
1st	118A	118A	4	SF								$ 24.00
1st	119	119	57	SF								$ 342.00
1st	121	121	278	SF	1	Ea.	120	LF				$ 2,874.00
1st	121A	121A	13	SF								$ 78.00
1st	123	123	140	SF	1	Ea.	40	LF				$ 1,246.00
1st	124	124	140	SF	1	Ea.	80	LF				$ 1,646.00
1st	125	125	146	SF	1	Ea.						$ 882.00
1st	126	SH-03			1	Ea.						$ 6.00
1st	135	148	166	SF	1	Ea.						$ 1,002.00
1st	136	149	158	SF	1	Ea.	20	LF				$ 1,154.00
1st	137	151	161	SF	1	Ea.	20	LF				$ 1,172.00
1st	138	152	191	SF	1	Ea.						$ 1,152.00
2nd	201A	201A			3	Ea.						$ 18.00
2nd	203	203	28	SF								$ 168.00
2nd	204	204	166	SF	1	Ea.						$ 1,002.00
2nd	205	205	175	SF	1	Ea.						$ 1,056.00
2nd	206	206	177	SF	1	Ea.						$ 1,068.00
2nd	207	207	8	SF								$ 48.00
2nd	207A	207A	6	SF								$ 36.00
2nd		207B	130	SF	1	Ea.						$ 786.00

ASBESTOS MATERIALS RE-ASSESSMENT 2025
BUILDING 3

FLOOR	FUNCTIONAL SPACE/ROOM		AHERA MATERIAL									REMOVAL COST 2025
			VCT/Mastic*		Transite/Panel Radiator **		TSI/Fittings***		Caulk		Condition	(Approximated)
	2019	2025	Qty.	Unit	Qty.	Unit	Qty.	Unit	Qty.	Unit		
2nd	208	207B1	260	SF		Ea.						$ 1,560.00
2nd		208	110	SF		Ea.						$ 660.00
2nd		208A	928	SF	6	Ea.						$ 5,604.00
2nd		208A1	175	SF	1	Ea.						$ 1,056.00
2nd		208A3	175	SF	1	Ea.						$ 1,056.00
2nd		208A4	150	SF	1	Ea.						$ 906.00
2nd		209A1	150	SF	1	Ea.						$ 906.00
2nd	209	209			2	Ea.	8	LF				$ 92.00
2nd	209A	209A			1	Ea.						$ 6.00
2nd	209C	209C			1	Ea.						$ 6.00
2nd	214	Server Area/Server Room (214)	1500	SF	9	Ea.						$ 9,054.00
2nd	214A	214A			1	Ea.						$ 6.00
2nd	215	North Stair Hall SH 02			1	Ea.						$ 6.00
2nd	216	216	154	SF	1	Ea.	12	LF				$ 1,050.00
2nd	217	217	157	SF	1	Ea.						$ 948.00
2nd	218	218	137	SF	1	Ea.						$ 828.00
2nd	218A	218A	6	SF	1	Ea.						$ 42.00
2nd	219	219	274	SF	2	Ea.						$ 1,656.00
2nd	220A	220A					14	LF				$ 140.00
2nd	220B	220B			1	Ea.						$ 6.00
2nd	221	221	55	SF								$ 330.00
2nd	223	223	136	SF	1	Ea.						$ 822.00
2nd	224	224	164	SF	1	Ea.	12	LF				$ 1,110.00
2nd	225	225	142	SF	1	Ea.						$ 858.00
2nd	226	South Stair Hall SH 03			1	Ea.						$ 6.00
2nd	230		42	SF								$ 252.00

ASBESTOS MATERIALS RE-ASSESSMENT 2025
BUILDING 3

FLOOR	FUNCTIONAL SPACE/ROOM		AHERA MATERIAL									REMOVAL COST 2025
			VCT/Mastic*		Transite/Panel Radiator **		TSI/Fittings***		Caulk		Condition	(Approximated)
	2019	2025	Qty.	Unit	Qty.	Unit	Qty.	Unit	Qty.	Unit		
2nd	242	252	100	SF								$ 600.00
2nd	242A	242	5	SF								$ 30.00
2nd	242B		8	SF								$ 48.00
2nd	243	243	210	SF	1	Ea.						$ 1,266.00
2nd	243A	243A	111	SF	1	Ea.						$ 672.00
2nd	244	244			1	Ea.						$ 6.00
2nd	245 & 201	245			3	Ea.						$ 18.00
2nd	COR239Z	COR247Z	325	SF								$ 1,950.00
2nd	COR240Z	COR246Z	422	SF								$ 2,532.00
2nd	COR220Z	220	200	SF	1	Ea.						$ 1,206.00
			16330		97		4086				TOTAL	$ 147,422.00

LEGEND

LF = linear feet
SF = square feet
NF = non-friable
F= friable

AHERA Category
1 = damaged or significantly damaged thermal system insulation ACM
2 = damaged friable surfacing ACM
3 = significantly damaged friable surfacing ACM
4 = damaged or significantly damaged friable miscellaneous ACM
5 = ACBM with potential for damage
6 = ACBM with potential for significant damage
7 = any remaining friable ACBM or friable suspected ACBM

Material		AHERA Classification	Response Action
VCT/Mastic:		Miscellaneous (NF)	