Users of printed versions are responsible for assuring most recent version is being referenced

EMERGENCY ACTION PLAN and FIRE PREVENTION PLAN

Bureau of Engraving and Printing
Washington, D. C. Facility
75D-04.0-01
Rev #8
02/22/24

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

This document serves as BEP's Emergency Action Plan (EAP) and Fire Prevention Plan (FPP) in accordance with OSHA standards. It applies to all Bureau staff, contractors, visitors, facilities, equipment, and materials. All employees, offices, and directorates are responsible for fully complying with the policies and procedures contained in this document.

<SIGNED>
Virginie Antoine-Pompey
Chief, Office of Environment, Health and Safety

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

EMERGENCY ACTION AND FIRE PREVENTION PLAN

1.0 Purpose:

This document serves as BEP's Emergency Action Plan (EAP) and Fire Prevention Plan (FPP) in accordance with OSHA standards. An EAP details the actions employees are to take in the event of an emergency. A FPP is intended to educate employees about the specific hazards of their jobs and is an extension of the EAP.

2.0 Scope:

This plan applies to all emergency evacuations and fire prevention activities within the DCF. It applies to employees, on-site contractors and visitors at the DCF.

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

EMERGENCY ACTIONS AND EVACUATIONS

1.0 *REPORTING AN EMERGENCY - CONTACT CPOC on 4-0911*

To report emergencies of any kind, contact the Police Communications (aka CPOC) on 874-***0911*** or by using the Emergency Fire Phones located in each stairwell on most floors. These phones connect directly to the Police Communications and can be used by all personnel to report emergencies or request evacuation assistance.

2.0 Fire Response:

2.1 FIRE EXTINGUISHER USE:

Employees that have received training are permitted to use fire extinguishers if they so choose. Employees receive annual training to familiarize themselves with the general principles of fire extinguisher use and the hazards involved with incipient stage firefighting. No employee is required to use a fire extinguisher to put out a fire.

2.2 FIRE EXTINGUISHER INSPECTIONS:

The OFS conducts annual maintenance checks of fire extinguishers and ensures that hydrostatic testing is performed as required per 29 CFR 1910.157. Supervisors or their designee are responsible for visually inspecting fire extinguishers and initialing/dating tags in their areas of responsibility on a monthly basis. OFS and OEHS are responsible for visually inspecting fire extinguishers and initialing/dating tags in common areas on a monthly basis.

3.0 Emergency Evacuation

Upon hearing activation of the building-wide fire alarm or being advised to evacuate by a supervisor, police officer, or safety and health official, all employees, except those classified as essential personnel, are to immediately evacuate the building according to the following procedures:

3.1 Close all doors and windows in your area;

3.2 Using the nearest stairway (**NOT** elevators), exit the building without delay; and

3.3 Once outside, assemble at the pre-assigned assembly areas for your office and report to your supervisor (see Appendix A for assembly areas).

3.4 Stairwells in both buildings have been designated as refuge areas, and are designed to temporarily hold any employee or visitor who cannot evacuate the building by means of the stairs during an emergency due to an injury or physical limitation.

3.5 Each designated stairwell is marked and contains emergency phones that allow direct contact (no dialing) to the Police Communications. Pick up the phone and it will automatically connect you to Police Communications. When you hear a voice, YOU MUST "KEY" THE PHONE BY DEPRESSING THE BUTTON ON THE RECEIVER TO SPEAK.

3.6 Personnel can use the phone for any emergency (smoke, fire, medical, spills, etc.).

3.7 Employee evacuation from a refuge area will be based on the site hazard assessment made by either the fire fighters or other emergency responders during their assessment of the current incident.

3.8 If you are involved in an actual fire or if you discover fire, smoke, or heat that is unaccounted for, remember "RACE." The following four steps are to be followed in order:

a. **R**emove people in a life-threatened situation. If a person is overcome by smoke or for other reason needs to be immediately removed from the fire-involved area, try to help without putting your own life in danger. Close door to fire-involved room, if possible.

b. **A**larm – Sound the alarm as follows:

Pull the nearest manual pull station (if the alarm is not already sounding). These are located near every stairwell door and at midpoints in long corridors.

Call Police Communications to report the fire. Either call x ***40911*** or use a phone in the refuge area of a stairwell. Tell the Officer the size and nature of the fire, exact location of the fire, if any people are in danger, and any other pertinent information. DO NOT hang up on the Officer as they may have specific questions.

c. **C**lose all doors in the fire-involved area. If you are not at the site of the emergency, but are ordered to evacuate, close all doors and windows before you leave; and

d. **E**vacuate the building according to the evacuation procedures listed below.

4.0 Evacuation Drills:

Evacuation drills will be held with sufficient frequency to familiarize occupants with evacuation procedures in each building. In the conduct of drills, emphasis shall be placed on orderly evacuation rather than on speed. Drills are coordinated by OEHS, in conjunction with OS and OFS.

5.0 Accounting for All Employees After an Evacuation:

Each supervisor, or their designee, shall account for his/her employees at the designated assembly area until the emergency/drill is over, and an announcement is made that the building can be reentered. Each supervisor or their designee shall inform the nearest BEP Police Officer if any personnel are unaccounted for when the evacuation is completed. To the extent possible, supervisors or their designees shall keep employees together in case additional relocation instructions are given by emergency management personnel.

6.0 Sheltering in Place (SIP)

Sheltering in Place (SIP) is a technique/precaution frequently used by emergency services and public safety personnel. It is designed for those situations in which it is safer for occupants to remain in the building than to evacuate. SIP does not mean going to an underground shelter. Generally, it means simply staying indoors. Whether at home, school, or at work you want to stay indoors and stage in a safe place to await further instructions. SIP is usually implemented for events that have a relatively short duration, of hours, not days or weeks.

SIP is recommended by the American Red Cross, OSHA, EPA, DHS, CDC, USDA, and other key agencies as an appropriate strategy to harbor employees during emergencies, as well as situations in which building evacuation could be more hazardous to occupants than remaining sheltered inside.

Should an event occur that necessitates SIP, the following will occur:

- An audible alarm and announcement over the facility's fire management system will alert you to assemble in pre-designated SIP location (see table below).
- BEP Police may stop all employees, contractors, and visitors from exiting the buildings and direct them to the nearest SIP location.

What you should do:

- Secure all products, sensitive documents, etc.
- Shut all windows and doors.
- Assemble in pre-designated SIP locations.
- Each Supervisor, or their designee shall account for his/her employees at the designated assembly area until an announcement is made to return to normal duty stations.
- Each Supervisor or their designee shall inform the nearest BEP Police Officer if any personnel are unaccounted for.
- Employees that cannot reach their designated SIP assembly area shall assemble in the nearest SIP location and notify an available BEP Police Officer or their supervisor, if possible.
- Remain in the SIP area until the "all clear" is announced.
- Follow all guidance of BEP police officers and/or Office of Security personnel.

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

Shelter in Place locations:

Assigned Duty Station	SIP Location
Annex Basement and Floors 2,3,4,5,6,7	Center corridor of building on assigned floor
Annex First Floor/Loading Dock	Second Floor Corridor
Main Building - Basement through Fourth Floor	Center corridor of building on assigned floor
Main Building – Fifth Floor	A and D-Wings
Tour Visitors OUTSIDE the BEP	Will be housed in the Tour Bridge Area
Tour Visitors in the Tour Bridge Waiting Area	Held in the Tour Bridge Area
Tour Visitors in the Gift Shop/Visitor Center	Held in the Gift Shop/Visitor Center
Tour Visitors INSIDE the BEP on the Tour	Held on the Tour Gallery

After the emergency:

After the “all clear” has been given, return to your offices and areas of operation.

6.1 Severe weather (i.e., hurricanes, tornadoes, floods, snowstorms, etc.)

a. Should weather conditions appear threatening, adhere to ALERT WARNINGS. Look for early dismissal, delayed opening, facility closures, and traffic notifications.

b. Immediately react to emergency instructions provided over the voice notification system.

6.2 Earthquake

a. Take cover immediately. Get under a desk or table or stand in a doorway or corner. Stay clear of windows and heavy items that could fall or tip over. Stay there until the initial shaking stops and be alert for aftershocks.

b. Do not attempt to evacuate the building unless prompted by the voice notification system or told to do so by a supervisor, police officer, emergency management or safety official.

c. If prompted to evacuate follow emergency evacuation procedures outlined in section 3.0 of this document. Proceed to your assembly area and await further instructions from the police or other emergency management personnel.

d. Report any significant damage, potential hazards, and location of any injured occupants observed during the evacuation to police or emergency management personnel.

e. If outside during an earthquake, attempt to get into the open. Do not put yourself in harm's way but try to get away from buildings, trees, walls, poles, and power lines.

f. Do not attempt to reenter the building unless a structural examination has occurred and an official all clear signal has been given.

7.0 Individual Critical Plant Operational Procedures are contained in Appendix B.

8.0 Employees Performing Medical or Rescue Duties:

Employees are not required to conduct rescue or medical duties. Employees are required, at a minimum, to render assistance to building occupants that require medical assistance or rescue by contacting the Police Communications on 4-***0911***.

9.0 VOICE NOTIFICATION SYSTEM

Main and Annex Buildings – During an actual emergency, the voice evacuation system will be sounded in all areas as an audible signal tone, followed by a voice message with information concerning the emergency.

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

FIRE PREVENTION PLAN

1.0 The Fire Prevention Plan (FPP) is intended to provide employees with basic information on the major fire hazards and control methods at the BEP in accordance with 29 CFR 1910.39. For more information, contact the Office of Environment, Health & Safety at 874-3591.

1.1 The following table details DCF's major fire fuel source hazards, their proper storage and handling, and available fire control equipment:

Fuel Source Hazard	Proper Storage & Handling	Fire Control Equipment
Accumulation of ordinary combustibles, such as paper, cardboard, office trash, other combustible wastes.	Daily housekeeping activities to remove these items from the workplace; Intrinsically safe dust collection and vacuum systems; Periodic inspections to ensure adequate housekeeping.	Multipurpose dry chemical fire extinguisher; Automatic sprinkler systems in both buildings.
Flammables and combustible liquids – high volatile organic compound cleaners, such as Varsol, or reagents in sections, mills, and laboratory areas, gasoline and diesel fuel in maintenance areas.	Store in approved containers in flammable storage cabinets or flammable storage rooms.	Multipurpose dry chemical fire extinguisher; Automatic sprinkler systems in sections, mills, shops, and flammable storage rooms.
Flammable solvent waste.	Store in approved waste containers; Weekly inspections of accumulation areas and regularly scheduled removal to the Hazardous Waste Storage Area.	Multipurpose dry chemical fire extinguisher; Automatic sprinkler system.
Compressed gas cylinders-acetylene and propane tanks.	Store in approved area; Regularly inspect cylinders, tanks and fittings for damage or leaks. Comply with Compressed Gas Association (CGA) guidelines for storage and handling.	Multipurpose dry chemical fire extinguisher; Automatic sprinkler system.
Diesel fuel tanks for emergency generator and fire pumps.	Tanks are double walled and inspected periodically.	Multipurpose dry chemical fire extinguisher; Automatic sprinkler system.

1.2 DCF's major potential fire ignition sources and their control procedures:

Ignition Source	Control Procedure
Energized electrical equipment.	Do not store flammable and combustible materials in close proximity to energized electrical equipment.
Hot Work, such as welding, grinding, soldering, similar operations producing heat, spark, or flame.	Follow the requirements specified in Burn Permits issued by the OEHS.
Laboratory operations involving heat or flame producing equipment.	Follow the manufacturer's recommendations for equipment use and maintenance. Keep flammable and combustible materials away from heat or flame producing equipment.
Cooking and food warming equipment.	Potential fires in the food preparation area are controlled by installed wet chemical suppression system, along with an automatic sprinkler system.
Smoking	No smoking is allowed in BEP buildings.

1.3 Personnel responsible for maintenance of fire suppression systems:

Testing and maintenance of portable fire extinguishers, fire detection and alarm systems, and fire suppression systems are performed by the Office of Facilities Support through contract vendors specializing in these activities. The Office of Facilities Support annually inspects and services all portable fire extinguishers. The Office of Environment, Health & Safety conducts periodic fire prevention inspections.

1.4 Personnel responsible for controlling fire fuel source hazards:

Supervisors at all levels are responsible for the control of fuel source hazards in their area of responsibility. Employees are also responsible for maintaining a fire-safe work environment and reporting any unsafe conditions to their supervisor. In addition, periodic fire prevention inspections are performed by OEHS to assist supervisors and employees in identification of potential fuel source hazards.

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

TRAINING AND CONTACTS

1.0 Training:

BEP must train each employee covered by the plan when*:* 1) the employee is initially assigned to a job, 2) the employees' responsibility under the plan change*,* and 3) the plan is changed.

2.0 Contacts: DCF Hotline Numbers

https://bepgov.sharepoint.com/sites/insite/SitePages/BEP-Special-Numbers.aspx

The following officials may also be contacted for additional information:

Chief, Office of Environment, Health & Safety

Chief, Office of Security

Manager, Safety and Health Division

Commander, Police Operations Division

Facility Emergency Coordinator, Office of Security

Chief, Office of Facilities Support

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

Appendix A


Evacuation Assembly Areas– Main Building

Assembly area is in the grassy area across R. Wallenberg Drive


Exit

Arrows denote direction of exit travel in alley to assembly areas

Arrows note direction from parking deck to 14th St. to South Alley



Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.



Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

REVISION	PURPOSE OF REVISION	EFFECTIVE DATE
1	Replace Appendix B, SOCC Memo, which contained procedural errors.	6/25/07
2	Add supervisor responsibilities of fire extinguisher inspections and update emergency evacuation procedures	8/11/09
3	Update critical plant operations procedural memos, assembly maps, and emergency response procedures.	8/31/12
4	Change emergency contact number from 874-7400 to 874-0911 per DO mandate.	7/3/13
5	Changed Document Numbers	4/21/14
6	Three year review and procedural memos update.	6/23/17
7	Replace outdated contacts and phone numbers.	3/8/18
8	Three year policy review. No change to procedural memos.	02/22/24

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

DEPARTMENT OF THE TREASURY
Bureau of Engraving and Printing
Washington, D.C.

March 28, 2017

MEMORANDUM FOR: **WASTEWATER PRETREATMENT PLANT (WWPP) PERSONNEL MAIN BUILDING BETWEEN C & D, INCLUDING D WINGS**

FROM: Myron N. Hodge, Environmental Protection Specialist
Office of Environment, Health and Safety

SUBJECT: Emergency Evacuation Procedures for WWPP Personnel

Fire evacuation shall be carried out in one of the following scenarios.

1. **Fire Alarm Sounds in the Main Building.** When fire alarms sound in the Main Building, the personnel shall confirm through the COR/Fire Safety Office/Police Communications that it is a
   a. Fire Drill,
   b. Fire in the Main Building not near the WWPP,
   c. Fire near the WWPP,
   d. Fire inside of the WWPP,
   e. Shelter-In-Place Drill,
   f. Shelter-In-Place emergency,
   g. Active Shooter Drill or Emergency,
   h. Other Emergency

   and according to the determination, follow the corresponding procedures.
   a. Fire Drill. When there is a fire drill in the Main Building, the two senior personnel shall stay, and the remaining personnel shall evacuate to the 15th Street staging area. The most junior personnel will account for all WWPP personnel that evacuated to the 15th Street staging area at BM-9.
   b. Fire in the Main Building not near the WWPP. When there is a fire in the Main Building not near the WWPP, the two senior personnel shall stay, and the remaining personnel shall evacuate to the 15th Street staging area. The most junior personnel will account for all WWPP personnel that evacuated to the 15th Street staging area at BM-9.

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

c. Fire in the Main Building near the WWPP. When there is a fire in the Main Building near the WWPP, then all personnel shall proceed in emptying the beginning tanks in the respective systems and shutting down the respective systems. When all plants are shut down then all personnel shall evacuate to the 15th Street staging area and the most junior personnel will account for all WWPP personnel.

d. Fire Inside the WWPP. If there is a minor fire in the plant, the personnel in the plant will attempt to contain and extinguish the fire, and also pull the local fire alarm and begin the shutdown procedures for the WWPP. If the personnel are able to contain the fire in the plant, Police Communications will again be notified and an incident report will be generated. If the personnel are not able to contain the fire in the plant, they will advise Police Communications and evacuate the WWPP. The personnel will assemble at 15th Street near BM-9. The most junior personnel will account for all WWPP personnel.

e. Shelter-in-place Drill. When there is a drill in the Main Building, the two senior personnel shall stay, and the remaining personnel shall evacuate to the center corridor of the Basement. The most junior personnel will account for all WWPP personnel that evacuated to the corridor.

f. Shelter-in-place emergency. WWPP personnel will perform shutdown procedures and immediately evacuate the WWPP to the center corridor of the Basement. The most junior personnel will account for all WWPP personnel that evacuated to the corridor.

g. Active Shooter Drill or Emergency. WWPP personnel will perform shutdown procedures and immediately evacuate to their safest location, run or fight, as applicable, for the circumstances.

h. Other Emergency. WWPP personnel will perform shutdown procedures and immediately evacuate the WWPP the appropriate location based on the directions provided. The most junior personnel will account for all WWPP personnel that evacuated.

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

DEPARTMENT OF THE TREASURY

BUREAU OF ENGRAVING AND PRINTING

WASHINGTON, D.C. 20228

DATE: Mar 17, 2017,

MEMORANDUM FOR: Power Plant Personnel, Room 19-2M

FROM: Joseph "Troy" Williams, Chief Stationary Engineer

SUBJECT: Emergency Evacuation Procedures for Power Plant Personnel

In the event of a BEP emergency evacuation, Power Plant personnel are to adhere to the following procedures;

The Power Plant supervisor(s) on duty shall contact the Central Police Operations Center (CPOC) on 4-1234 to determine the nature of the emergency, and verify the Power Plant contact phone number 4-2080. The Power Plant Supervisor will also verify with CPOC the location and cause of the emergency. All Power Plant Stationary Engineer's on duty at the time of the emergency will be contacted by the Power Plant supervisor(s), and instructed to report to the Power Plant, room 19-2M. The supervisor will then record all personnel on duty in the Power Plant's "Fire drill / Emergency Accountability log." Constant communication to insure coordination of tasks will occur during the duration of the emergency between Power Plant and CPOC personnel. During an emergency evacuation of the BEP, the Power Plant will provide portable radios to personnel who will be shutting down or placing various infrastructure systems in a "safe" condition.

Critical Task's to be carried out are listed below;

1. Establish communication control in the Main and Annex Buildings, and coordinate Power Plant response and required tasks with CPOC, and the Emergency Evacuation Team.

2. Identify which systems will have to be shut down or placed in a "safe" condition (i.e. elevators, water, steam, gas, electric, HVAC systems, etc.), and establish an approximate time line regarding how long it will take to safely secure the various systems.

3. During the emergency, identify personnel that will remain in the building (Main and / or Annex).

4. Insure Personal Protective Equipment (PPE) required is readily available to Power Plant personnel during an emergency such as but not limited to;

   Radios
   Boots
   Coats

5. Once the emergency event is over, Power Plant personnel will assist CPOC, and the Emergency Evacuation Team restoring the BEP back to normal operation.

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

BUREAU OF ENGRAVING AND PRINTING
POLICE OPERATIONS DIVISION
POLICE COMMUNICATIONS CENTER (PCC)
STANDARD OPERATING PROCEDURES (SOP)

NUMBER: 20
DATE: March 24, 2017

EMERGENCY EVACUATION PROCEDURES

1. **PURPOSE AND SCOPE:** The purpose of this SOP is to establish standards for operating and monitoring the Police Communications Security Systems.

2. **APPLICATION:** This SOP applies to the personnel assigned to the PCC.

3. **BACKGROUND:** PCC's mission is to ensure that all BEP employees, products and surrounding areas are safe and secured. This allows the PCC to effectively protect the Bureau employees and products from theft, diversion or other crime.

4. **INTRODUCTION:** The Police Communications Center (PCC) operators (PCO), under the direct supervision of the PCC Sergeant, shall continuously administer, operate and monitor BEP security systems and perform various tasks related to the PCC during both routine and emergency situations.

   A. These tasks include but are not limited to the following:

      1. Operate and monitor communications equipment to provide prompt and effective responses to calls for service.

      2. Operate and monitor security systems equipment to provide prompt and effective responses to alarms.

      3. Monitor and assess suspicious or unusual activities.

      4. Monitor and assess perimeter and other designated closed circuit television cameras (CCTV) for suspicious activity.

      5. Receive and transmit radio and telephone messages to and from police units in accordance with standardized procedures.

      6. Receive telephone calls for service and inquires and dispatch officers and respond per procedures.

      7. Operate local and National Crime Information Center (NCIC) terminal to transmit and receive messages.

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

8. Notify appropriate authorities in other BEP departments of situations requiring attention after regular business hours and operate the Dispatcher Log ensuring that all fields are appropriately filled in with required data.

5. **PURPOSE:** The PCC operators under direct supervision of the PCC Sergeant are responsible for processing and assessing all communications/alarms coming into and leaving the PCC. During emergency evacuations situations, PCC operators will remain the PCC and continue to receive and transmit communications, process information and monitor equipment until directed by the PCC Sergeant or other authority to evacuate the area.

6. **PREREQUISITES:**

A. Required training includes:

1. Training on MDI processing of alarms
2. Training on PCC processes and procedures
3. Training in NCIC and WALES systems
4. Additional training to be determined as needed

7. **PROCESS:**

A. During an emergency, PCC operators will remain in PCC and continue to dispatch, coordinate personnel assignments, receive and provide communications, record information and monitor alarms and equipment.

1. PCC operators are required to utilize the emergency notification sheets to capture pertinent information for any and all types of incidents.

2. In addition they should document all dispatches on the Dispatcher Log to include time and type of alarms received; officer dispatched, mobile units dispatched, traffic stops, disposition of, emergency notifications and the disposition of all dispatched personnel.

3. The results of all NCIC/WALES checks,

4. The names of personnel who arrived after initial emergency.

B. Based on the situation the PCC operators may elect to dispatch officers from the field prior to them responding to PCC. When directed by the PCC Sergeant, operators will announce, via radio, that all officers not currently on assignment should report to the PCC immediately.

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

C. The operator will dispatch police officers to any additional area(s), as needed or directed by the PCC supervisor.

D. When section supervisors state that all their personnel are accounted for in the staging areas, only then will personnel will be cleared to return to the building. The authorization to give the "ALL CLEAR" and return personnel to the BEP must come from the Safety Representative, OS Chief, Commander or their designee.

E. Personnel may not be allowed back into the building due to unforeseen circumstances. Contingency plans for such situations will be addressed by executive leadership.

F. When directed by the PCC Police Sergeant, the operator will dispatch officers to check and secure emergency exit doors, release the elevators etc.

8. **APPROVALS:** This policy and procedure is effective upon the signed approval of the Commander, Police Operations Division.

Troy L. High

Digitally signed by Troy L. High
DN: c=US, o=U.S. Government, ou=Department of the Treasury, ou=Bureau of Engraving and Printing, ou=People, serialNumber=684265, cn=Troy L. High
Date: 2017.03.24 09:20:56 -04'00'

_____Date:_____
Troy High, Commander
Police Operations Division

Information in printed paper copies of this document and any document referred to herein is guaranteed valid for only 24 hours of the print date.

DEPARTMENT OF THE TREASURY
BUREAU OF ENGRAVING AND PRINTING
WASHINGTON, D.C. 20228

April 18, 2017

MEMORANDUM FOR JOHN ROBERTS, MANAGER
SAFETY AND HEALTH DIVISION

FROM: Leticia Byrd, Program Analyst
Safety and Health Division

SUBJECT: BEP Medical Clinic Emergency Evacuation Procedures – Room 303M

In the event of an emergency that requires evacuation, the medical staff shall report to the following assembly areas and follow these written procedures:

Main Building

Raoul Wallenberg Place (15th Street)
Assembly on grassy area across from the BEP's Visitor Center entrance

Procedures

1. Provide appropriate care and evacuation for any employees in the Health Unit at the time of the fire emergency.
2. If transport assistant is required, then call Police Communication Center (formally CPOC) on ext. 4-0911 and advise them that the Health Unit is being evacuated and that patient assistance is required. State the number of patients that require assistance.
3. Evacuate the Health Unit staff by the designated/appropriate route to the designated area listed above. Additionally, notify BEP Police of your location and availability.
4. Assist EMS personnel, if requested, but do not re-enter the building until the all-clear instruction is given.

Rev. 04/18/17