| Boiler | Start | Binary Value | 300 |
|---------|------------------|---------------|-----|
| | Stop | | 301 |
| | Reset | | 302 |
| | CMD | | 303 |
| | Fault | | 304 |
| | State 1 | | 305 |
| | State 2 | | 306 |
| | State 3 | | 307 |
| | State 4 | | 308 |
| | State 5 | | 309 |
| | Boiler Temp SP | -Analog Value | 100 |
| | Boiler Temp Out | | 101 |
| | HeatEx Temp SP | | 102 |
| | HeatEx Temp Out | | 103 |
| Chiller | Start | Binary Value | 310 |
| | Stop | | 311 |
| | State 1 | | 312 |
| | State 2 | | 313 |
| | State 3 | | 314 |
| | State 4 | | 315 |
| | State 5 | | 316 |
| | CTW Temp SP | Analog Value | 110 |
| | CTW Temp Out | | 111 |
| | Chiller Temp SP | | 112 |
| | Chiller Temp Out | | 113 |
| AHU | Start | Binary Value | 317 |
| | Stop | | 318 |
| | State 1 | | 319 |
| | State 2 | | 320 |