OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of
NSF/ANSI 44 - Residential Cation Exchange Water Softeners

This is the Official Listing recorded on January 4, 2021.

Canature Health Technology Group Co., Ltd.
No. 508 & 518, Chuanda Road
Pudong New Area
Shanghai, 201200
China
86 21 5859 9999

Facility: Shanghai, China

Brand Name / Trade Name / Model	Flow Rate (gpm)	Claim	
Point-of-Entry [1] [Pb] [POE]			
CS8L-0722	4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS8H-0722	4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS8H PLUS-0815	4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS9H-0815	4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS4L-0817	4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS4H-0817	4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS8H PLUS-0824	5.18	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS12H-0926	4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS15H-1015	4.4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS17H-1015	4.4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS3L-1017	4.4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS3H-1017	4.4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]
CS5H-1017	4.4	Efficiency Rated	[ER]
		Hardness Reduction	[HR]

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

C0001710

CS6L-1017	4.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS6H-1017	4.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS7H-1017	4.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS10H-1017	4.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS13H-1017	4.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS16H-1017	4.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS18H-1017	4.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS8L-0735	5.3	Efficiency Rated [ER] Hardness Reduction [HR]
CS8H-0735	5.3	Efficiency Rated [ER] Hardness Reduction [HR]
CS4L-0835	6.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS4H-0835	6.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS8H PLUS-0835	6.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS9H-0835	6.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS4L-0844	7.5	Efficiency Rated [ER] Hardness Reduction [HR]
CS4H-0844	7.5	Efficiency Rated [ER] Hardness Reduction [HR]
CS9H-0844	7.5	Efficiency Rated [ER] Hardness Reduction [HR]
CS12H-0935	7.5	Efficiency Rated [ER] Hardness Reduction [HR]
CS6L-1026	7.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS6H-1026	7.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS7H-1026	7.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS11H-1026	7.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS1L-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

CS1H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS2L-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS2H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS3L-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS3H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS5H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS6L-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS6H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS7H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS10H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS11H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS13H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS15H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS16H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS17H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS18H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS3L-1044	11.5	Efficiency Rated [ER] Hardness Reduction [HR]
CS3H-1044	11.5	Efficiency Rated [ER] Hardness Reduction [HR]
CS17H-1044	11.5	Efficiency Rated [ER] Hardness Reduction [HR]
CN-0735-1811	6.4	Efficiency Rated [ER] Hardness Reduction [HR]
CN-0835-1811	6.4	Efficiency Rated [ER] Hardness Reduction [HR]
CN-18SEF	6.4	Efficiency Rated [ER] Hardness Reduction [HR]

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

CN-0835-2009	7.1	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1026-2094	7.4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-20SEF	7.4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0844-2123	7.5	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0935-2123	7.5	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-21SEF	7.5	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1030-2151	7.6	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0844-2207	7.8	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-22SEF	7.8	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0935-2406	8.5	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-24SEF	8.5	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0844-2490	8.8	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1035-2490	8.8	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-25SEF	8.8	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0942-2575	9.1	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-26SEF	9.1	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0948-2830	10	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-28SEF	10	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1035-2830	10	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1035-3000	10.6	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-30SEF	10.6	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1044-3000	10.6	Efficiency Rated [ER]
		Hardness Reduction [HR]

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

CN-1054-5009	10.6	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-50SEF	10.6	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1054-4245	11.1	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1054-3990	11.2	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-40SEF	11.2	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1047-3764	11.4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1044-3538	11.5	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-35SEF	11.5	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1144-4500	12	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-45SEF	12	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1354-9000	12.2	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-90SEF	12.2	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1252-5660	12.4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-55SEF	12.4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1248-5236	12.5	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1354-7075	12.6	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-70SEF	12.6	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1135-3113	12.8	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-31SEF	12.8	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1465-8490	12.9	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-85SEF	12.9	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1452-7669	13	Efficiency Rated [ER]
		Hardness Reduction [HR]

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

CN-75SEF	13	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1344-4330	13.3	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0717-679	4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-07SEF	4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0815-991	4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0817-792	4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-08SEF	4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0917-936	4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-09SEF	4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1015-1160	4.4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1017-1245	4.4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-12SEF	4.4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1017-1274	4.5	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0822-1303	4.6	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1017-1387	4.9	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0822-1302	5.18	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-13SEF	5.18	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-1024-1670	5.9	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0730-1047	4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-11SEF	4	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0830-1387	4.9	Efficiency Rated [ER]
		Hardness Reduction [HR]
CN-0826-1415	5	Efficiency Rated [ER]
		Hardness Reduction [HR]

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

CN-0735-1500	5.3	Efficiency Rated [ER] Hardness Reduction [HR]
CN-15SEF	5.3	Efficiency Rated [ER] Hardness Reduction [HR]
CN-0744-1613	5.7	Efficiency Rated [ER] Hardness Reduction [HR]
CS8F-0815	4	Efficiency Rated [ER] Hardness Reduction [HR]
CS18H-1044	11.5	Efficiency Rated [ER] Hardness Reduction [HR]
CS19H-1015	4.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS19H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS21H-0926	4	Efficiency Rated [ER] Hardness Reduction [HR]
CS21H-0935	7.5	Efficiency Rated [ER] Hardness Reduction [HR]
CS22H-1017	4.4	Efficiency Rated [ER] Hardness Reduction [HR]
MN 0935	7.5	Efficiency Rated [ER] Hardness Reduction [HR]
CS18H-1015	4.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS8F-0824	5.18	Efficiency Rated [ER] Hardness Reduction [HR]
CS8F-0835	6.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS20H-1026	7.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS22H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CS6H-1026	7.4	Efficiency Rated [ER] Hardness Reduction [HR]
CS20H-1035	8.8	Efficiency Rated [ER] Hardness Reduction [HR]
CSF25H-0817	4	Efficiency Rated [ER] Hardness Reduction [HR]

COMPONENTS: Tanks, Water Softener [1] [Pb]

Pressure Vessel 5x17	[2]	Pressure Vessel 5x20	[2]
Pressure Vessel 7x13	[2]	Pressure Vessel 7x17	[2]
Pressure Vessel 7x19	[2]	Pressure Vessel 7x22	[2]
Pressure Vessel 7x30	[2]	Pressure Vessel 7x35	[2]
Pressure Vessel 7x44	[2]	Pressure Vessel 8x15	[2]

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

Pressure Vessel 8x17 [2]
Pressure Vessel 8x30 [2]
Pressure Vessel 8x35 [2]
Pressure Vessel 8x44 [2]
Pressure Vessel 9x35 [2]
Pressure Vessel 9x42 [2]
Pressure Vessel 9x48 [2]
Pressure Vessel 10x15 [2]
Pressure Vessel 10x17 [2]
Pressure Vessel 10x24 [2]
Pressure Vessel 10x26 [2]
Pressure Vessel 10x30 [2]
Pressure Vessel 10x35 [2]
Pressure Vessel 10x40 [2]
Pressure Vessel 10x44 [2]
Pressure Vessel 10x47 [2]
Pressure Vessel 10x54 [2]
Pressure Vessel 11x35 [2]
Pressure Vessel 11x44 [2]
Pressure Vessel 12x48 [2]
Pressure Vessel 12x52 [2]
Pressure Vessel 13x44 [2]
Pressure Vessel 13x54 [2]
Pressure Vessel 14x52 [2]
Pressure Vessel 14x65 [2]
Pressure Vessel 16x24 [2]
Pressure Vessel 16x36 [2]
Pressure Vessel 16x44 [2]
Pressure Vessel 16x52 [2]
Pressure Vessel 16x65 [2]
Pressure Vessel 18x36 [2]
Pressure Vessel 18x53 [2]
Pressure Vessel 18x65 [2]
Pressure Vessel 21x36 [2]
Pressure Vessel 21x53 [2]
Pressure Vessel 21x62 [2]
Pressure Vessel 24x72 [2]
Pressure Vessel 2.5" 05x17
Pressure Vessel 2.5" 05x20
Pressure vessel 2.5" 06x13
Pressure Vessel 2.5" 06x17 [2]
Pressure Vessel 2.5" 06x18 [2]
Pressure Vessel 2.5" 06x22 [2]
Pressure vessel 2.5" 06x29
Pressure vessel 2.5" 06x30
Pressure Vessel 2.5" 06x35 [2]
Pressure Vessel 2.5" 07x13
Pressure Vessel 2.5" 07x17
Pressure Vessel 2.5" 07x19
Pressure Vessel 2.5" 07x22
pressure vessel 2.5" 07x24
Pressure Vessel 2.5" 07x30
Pressure Vessel 2.5" 07x35
Pressure Vessel 2.5" 07x44
Pressure Vessel 2.5" 08x13 [2]
Pressure vessel 2.5" 08x13D
Pressure Vessel 2.5" 08x15
Pressure Vessel 2.5" 08x17
Pressure Vessel 2.5" 08x18 [2]
Pressure Vessel 2.5" 08x22 [2]
Pressure Vessel 2.5" 08x24 [2]
Pressure Vessel 2.5" 08x26 [2]
Pressure Vessel 2.5" 08x30
Pressure Vessel 2.5" 08x35
Pressure vessel 2.5" 08x37
Pressure vessel 2.5" 08x40
Pressure Vessel 2.5" 08x44
Pressure Vessel 2.5" 09x13 [2]
Pressure Vessel 2.5" 09x15 [2]
Pressure Vessel 2.5" 09x17 [2]
Pressure Vessel 2.5" 09x18 [2]
Pressure Vessel 2.5" 09x24 [2]
Pressure Vessel 2.5" 09x26 [2]
Pressure Vessel 2.5" 09x30 [2]
Pressure Vessel 2.5" 09x35
Pressure Vessel 2.5" 09x42
Pressure Vessel 2.5" 09x48
Pressure Vessel 2.5" 10x13 [2]
Pressure Vessel 2.5" 10x15
Pressure Vessel 2.5" 10x17
Pressure vessel 2.5" 10x18
Pressure vessel 2.5" 10x19

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

Pressure Vessel 2.5" 10x24
Pressure Vessel 2.5" 10x26
Pressure Vessel 2.5" 10x30
Pressure Vessel 2.5" 10x35
Pressure Vessel 2.5" 10x40
Pressure Vessel 2.5" 10x44
Pressure vessel 2.5" 10×44DH
Pressure Vessel 2.5" 10x47
Pressure vessel 2.5" 10×47DH
Pressure Vessel 2.5" 10x54
Pressure vessel 2.5" 10×54DH
Pressure Vessel 2.5" 11x35
Pressure Vessel 2.5" 11x44
Pressure Vessel 2.5" 12x17 [2]
Pressure Vessel 2.5" 12x48
Pressure vessel 2.5" 12×48DH
Pressure Vessel 2.5" 12x52
Pressure vessel 2.5" 10×52DH
Pressure vessel 2.5" 13x24
Pressure Vessel 2.5" 13x44
Pressure Vessel 2.5" 13x54
Pressure Vessel 2.5" 14x52
Pressure Vessel 2.5" 14x65
Pressure Vessel 2.5" 16x24
Pressure Vessel 2.5" 16x36
Pressure Vessel 2.5" 16x44
Pressure Vessel 2.5" 16x52
Pressure Vessel 2.5" 16x65
Pressure Vessel 2.5 in 08x13D
Pressure Vessel 2.5 in 10x17D
Pressure Vessel 2.5 in 10x35D
Pressure Vessel 4" 12x17 [2]
Pressure Vessel 4" 12x48 [2]
Pressure vessel 4" 12×48DH
Pressure Vessel 4" 12x52 [2]
Pressure vessel 4" 12×52DH
Pressure vessel 4" 13x24
Pressure Vessel 4" 13x44
Pressure Vessel 4" 13x54
Pressure Vessel 4" 14x52
Pressure Vessel 4" 14x65
Pressure Vessel 4" 16x24
Pressure Vessel 4" 16x36
Pressure Vessel 4" 16x44
Pressure Vessel 4" 16x52
Pressure vessel 4" 16x52D
Pressure Vessel 4" 16x65
Pressure Vessel 4" 18x36
Pressure Vessel 4" 18x53
Pressure Vessel 4" 18x65
Pressure Vessel 4" 21x36
Pressure Vessel 4" 21x53
Pressure Vessel 4" 21x62
Pressure Vessel 4" 24x38 [2]
Pressure Vessel 4" 24x72
Pressure Vessel 4 in 16x65D
Pressure Vessel 4 in 18x65D
Pressure Vessel 4 in 24x72D
Pressure Vessel 4 in 24x38D
Pressure Vessel 4 in 21x62D

COMPONENTS: Valves, Water Softener / Filter [1] [Pb]

185HE [3]
485HE [3]
585HE [3]
585SE [3]
85HE [3]
BNT 7650F
BNT 7650T
BNT 7651F
BNT 7651T
BNT790T
BNT790F
BNT791T
BNT791F
BNT 2850HEF
BNT 2850HET
BNT 2851HEF
BNT 2851HET
BNT 850SEUF
BNT 851SEUF
BNT 850SEF

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

BNT 850SET
BNT 851SET
BNT 5851SEUF
BNT 5850SET
BNT 5851SET
BNT 7850HET
BNT 7851HET
BNT951MTS slave valve
BNT1890T
BNT1891T
BNT2890T
BNT2891T
BNT4890T
BNT4891T
BNT5890T
BNT5891T
CAN265 [3]
CAN465 [3]
CAN65 [3]
Control Valve BNT 1650T [3]
Control Valve BNT 1651T [3]
Control Valve BNT 1850HEF [3]
Control Valve BNT 1850T [3]
Control Valve BNT 1851HEF [3]
Control Valve BNT 1851T [3]
Control Valve BNT 2650T [3]
Control Valve BNT 2651T [3]
Control Valve BNT 3650T [3]
Control Valve BNT 3651T [3]
Control Valve BNT 4650T [3]
Control Valve BNT 4651T [3]
Control Valve BNT 4850HET [3]
Control Valve BNT 4851HET [3]
Control Valve BNT 5650T [3]
Control Valve BNT 5651T [3]
Control Valve BNT 5850HET [3]
Control Valve BNT 5851HET [3]
Control Valve BNT 650T [3]
Control Valve BNT 651T [3]
Control Valve BNT 6650T [3]
Control Valve BNT 6651T [3]
BNT 851SEF
BNT 5850SEUF
BNT 5850SEF
BNT 5851SEF
BNT7850HEF
BNT 7851HEF
BNT950 MTS slave valve
BNT1890F
BNT1891F
BNT2890F
BNT2891F
BNT4890F
BNT4891F
BNT5890F
BNT5891F
CAN165 [3]
CAN365 [3]
CAN565 [3]
Control Valve BNT 1650F [3]
Control Valve BNT 1651F [3]
Control Valve BNT 1850F [3]
Control Valve BNT 1850HET [3]
Control Valve BNT 1851F [3]
Control Valve BNT 1851HET [3]
Control Valve BNT 2650F [3]
Control Valve BNT 2651F [3]
Control Valve BNT 3650F [3]
Control Valve BNT 3651F [3]
Control Valve BNT 4650F [3]
Control Valve BNT 4651F [3]
Control Valve BNT 4850HEF [3]
Control Valve BNT 4851HEF [3]
Control Valve BNT 5650F [3]
Control Valve BNT 5651F [3]
Control Valve BNT 5850HEF [3]
Control Valve BNT 5851HEF [3]
Control Valve BNT 650F [3]
Control Valve BNT 651F [3]
Control Valve BNT 6650F [3]
Control Valve BNT 6651F [3]
Control Valve BNT 750S [3]

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

Control Valve BNT 850F [3]
Control Valve BNT 850HEF [3]
Control Valve BNT 850HET [3]
Control Valve BNT 850T [3]
Control Valve BNT 851F [3]
Control Valve BNT 851HEF [3]
Control Valve BNT 851HET [3]
Control Valve BNT 851T [3]
Control Valve BNT 8650F [3]
Control Valve BNT 8650T [3]
Control Valve BNT 8651F [3]
Control Valve BNT 8651T [3]
CONTROL VALVE BNT890F [4] [5]
CONTROL VALVE BNT890T [4] [5]
CONTROL VALVE BNT891F [4] [5]
CONTROL VALVE BNT891T [4] [5]
CONTROL VALVE BNT950T [6] [7]
CONTROL VALVE BNT950F [6] [7]
CONTROL VALVE BNT951T [6] [7]
CONTROL VALVE BNT951F [6] [7]
IWT165 [3]
IWT265 [3]
IWT365 [3]
IWT565 [3]
IWT65 [3]
NVO165 [3]
NVO465 [3]
NVO865 [3]
65 [3]
Control Valve BNT 5851T [3]
185 [3]
585HE [3]
265 [3]
465 [3]
665 [3]
85TA [3]
565 [3]
85 [3]
8650SEF [3]
8650SET [3]
89 [4] [5]
785HE [3]
365 [3]
485HE [3]
765 [3]
85HE [3]
865 [3]
8651SEF [3]
95 [6] [7]
CONTROL VALVE BNT3890F [4] [5]
CONTROL VALVE BNT3890T [4] [5]
CONTROL VALVE BNT3891F [4] [5]
CONTROL VALVE BNT3891T [4] [5]
Control Valve BNT 5850F [3]
Control Valve BNT5850T [3]
Control Valve BNT 5851F [3]
165 [3]

COMPONENTS: Valves, Control, Point-of-Entry [1] [8] [9] [Pb]

BNT1050(F)UF BNT1050(F)DF BNT1051F BNT1050(T)DF BNT1051T
BNT1050(T)UF

[1] Conforms to material and structural integrity requirements.

[2] Tank sizes 5xAA, 6xAA, 7xAA, 8xAA, 9xAA, 10xAA, and 11xAA, have a 2.5" opening.
Tank sizes 12xAA, 13xAA, 14xAA, 16xAA, and 24xAA have either a 2.5" or 4" opening.
Where AA represents the tank width.

[3] The 65, 75, 85 indicate the model of the valves and may be followed by either a 0 or a 1 and either an F or a T.
The 0 models are for use with water softeners.
The 1 models are for use with in-line water filters.
F indicates control valve with meter.
T indicates control valve with timer.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

S indicates the valve is controlled by a microswitch.
A complete model number example is "BNT 651F".
BNT indicates control valve trade name for all world markets.
IWT/NVO/CAN models are sold in North America by Canature North America.

[4] The 89 indicates the model of the valves and may be followed by either a 0 or a 1 and either an F or a T.
The 0 models are for use with water softeners.
The 1 models are for use with in-line water filters.
F indicates control valve with meter.
T indicates control valve with timer.
A complete model number example is "BNT 891F".
BNT indicates control valve trade name for all world markets.

[5] This product is Certified for a maximum use level of 0.05 units per L.

[6] The 95 indicates the model of the valves and may be followed by either a 0 or a 1 and either an F or a T.
The 0 models are for use with water softeners.
The 1 models are for use with in-line water filters.
F indicates control valve with meter.
T indicates control valve with timer.
A complete model number example is "BNT 951F".
BNT indicates control valve trade name for all world markets.

[7] This product is Certified for a maximum use level of 0.05 units per L.

[8] The 105 indicates the model of the valves and may be followed by either a 0 or a 1 and either an F or a T.
The 0 models are for use with water softeners.
The 1 models are for use with water filters.
F indicates control valve with meter.
T indicates control valve with timer.
UF indicates up flow regeneration.
DF indicates down flow regeneration.

[9] This product is certified for a maximum use level of 0.09 units per L.

[ER] Softener Efficiency indicates that the softener achieves a minimum of 3,350 grains of hardness removed per pound of regenerant salt (477 grams of hardness removed per kilogram of regenerant salt), and also that it uses 5 gallons or less of regenerant water per 1,000 grains of hardness removed (18.9 liters or less of regenerant water per 64.8 grams of hardness removed).

[HR] Hardness Reduction indicates that the published capacity ratings for reducing hardness have been verified.

[Pb] Product also evaluated and determined to possess weighted average lead content of <=0.25% and complies with lead content requirements for “lead free” plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

NOTE: These components do not bear the NSF Mark. Evidence of Certification will appear on the manufacturer's literature and packaging.

[POE] Product conforms to NSF/ANSI/CAN 61 health effects requirements.

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org