DETAILED WORKSHEET FOR FUNCTIONAL CRITICALITY ANALYSIS
FS CODE
FS DESCRIPTION
SYSTEM FAILURE WORKSHEET

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
1	1303-TFA-T01/00	TANK STORAGE NO.01	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
2	1303-T01-GV01/00	GATE VALVE INLET TANK T-01	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
3	1303-T01-FL01/00	FlEXIBLE JOINT INLET TANK T-01	No spare have issue	Combustible	sederhana	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
4	1303-T01-FL02/00	FlEXIBLE JOINT OUTLET TANK T-01	No spare have issue	Combustible	sederhana	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
5	1303-T01-GV02/00	GATE VALVE OUTLET TANK T-01	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
6	1303-T01-GV03/00	GATE VALVE DRAIN TANK T-01	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
7	1303-T01-CV01/00	CHECK VALVE INLET TANK T-01	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
8	1303-T01-CV02/00	CHECK VALVE OUTLET TANK T-01	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
9	1303-T01-ATG01/00	AUTOMATIC TANK GAUGING (ATG) TANK T-01	No spare have issue	N/A1	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
10	1303-T01-GV04/00	GATE VALVE REDUNDANT INLET TANK T-01	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
11	1303-T01-GV05/00	GATE VALVE REDUNDANT OUTLET TANK T-01	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
12	1303-T01-TT01/00	TEMPERATURE TRANSMITTER TANK T-01	No spare have issue	N/A2	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
13	1303-TFA-T02/00	TANK STORAGE NO.02	No spare have issue	Flameable	kompleksitas kecil	Almost	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
14	1303-T02-GV01/00	GATE VALVE INLET TANK T-02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
15	1303-T02-FL01/00	FlEXIBLE JOINT INLET TANK T-02	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
16	1303-T02-FL02/00	FlEXIBLE JOINT OUTLET TANK T-02	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
17	1303-T02-GV02/00	GATE VALVE OUTLET TANK T-02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
18	1303-T02-GV03/00	GATE VALVE DRAIN TANK T-02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
19	1303-T02-CV01/00	CHECK VALVE INLET TANK T-02	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
20	1303-T02-CV02/00	CHECK VALVE OUTLET TANK T-02	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
21	1303-T02-SDD01/00	DIPHATCH / SLOT DIPPING DEVICE TANK T-02	No Spare no issue	N/A1	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
22	1303-T02-ATG01/00	AUTOMATIC TANK GAUGING (ATG) TANK T-02	No spare have issue	N/A1	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
23	1303-T02-GV04/00	GATE VALVE REDUNDANT INLET TANK T-02	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
24	1303-T02-GV05/00	GATE VALVE REDUNDANT OUTLET TANK T-02	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
25	1303-T02-TT01/00	TEMPERATURE TRANSMITTER TANK T-02	No spare have issue	N/A2	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
26	1303-TFA-T03/00	TANK STORAGE NO.03	No spare have issue	Flameable	kompleksitas kecil	Almost	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
27	1303-T03-GV01/00	GATE VALVE INLET TANK T-03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
28	1303-T03-FL01/00	FlEXIBLE JOINT INLET TANK T-03	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
29	1303-T03-FL02/00	FlEXIBLE JOINT OUTLET TANK T-03	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
30	1303-T03-GV02/00	GATE VALVE OUTLET TANK T-03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
31	1303-T03-GV03/00	GATE VALVE DRAIN TANK T-03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
32	1303-T03-CV01/00	CHECK VALVE INLET TANK T-03	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
33	1303-T03-CV02/00	CHECK VALVE OUTLET TANK T-03	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
34	1303-T03-SDD01/00	DIPHATCH / SLOT DIPPING DEVICE TANK T-03	No Spare no issue	N/A1	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
35	1303-T03-ATG01/00	AUTOMATIC TANK GAUGING (ATG) TANK T-03	No spare have issue	N/A1	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
36	1303-T03-GV04/00	GATE VALVE REDUNDANT INLET TANK T-03	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
37	1303-T03-GV05/00	GATE VALVE REDUNDANT OUTLET TANK T-03	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
38	1303-T03-TT01/00	TEMPERATURE TRANSMITTER TANK T-03	No spare have issue	N/A2	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
39	1303-TFA-T04/00	TANK STORAGE NO.04	No spare have issue	Flameable	kompleksitas kecil	Almost	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
40	1303-T04-GV01/00	GATE VALVE INLET TANK T-04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
41	1303-T04-FL01/00	FlEXIBLE JOINT INLET TANK T-04	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
42	1303-T04-FL02/00	FlEXIBLE JOINT OUTLET TANK T-04	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
43	1303-T04-GV02/00	GATE VALVE OUTLET TANK T-04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
44	1303-T04-GV03/00	GATE VALVE DRAIN TANK T-04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
45	1303-T04-CV01/00	CHECK VALVE INLET TANK T-04	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
46	1303-T04-CV02/00	CHECK VALVE OUTLET TANK T-04	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
47	1303-T04-SDD01/00	DIPHATCH / SLOT DIPPING DEVICE TANK T-04	No Spare no issue	N/A1	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
48	1303-T04-ATG01/00	AUTOMATIC TANK GAUGING (ATG) TANK T-04	No spare have issue	N/A1	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
49	1303-T04-GV04/00	GATE VALVE REDUNDANT INLET TANK T-04	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
50	1303-T04-GV05/00	GATE VALVE REDUNDANT OUTLET TANK T-04	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
51	1303-T04-TT01/00	TEMPERATURE TRANSMITTER TANK T-04	No spare have issue	N/A2	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
52	1303-TFA-T05/00	TANK STORAGE NO.05	No spare have issue	Flameable	kompleksitas kecil	Almost	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
53	1303-T05-GV01/00	GATE VALVE INLET TANK T-05	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
54	1303-T05-FL01/00	FlEXIBLE JOINT INLET TANK T-05	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
55	1303-T05-FL02/00	FlEXIBLE JOINT OUTLET TANK T-05	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
56	1303-T05-GV02/00	GATE VALVE OUTLET TANK T-05	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
57	1303-T05-GV03/00	GATE VALVE DRAIN TANK T-05	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
58	1303-T05-CV01/00	CHECK VALVE INLET TANK T-05	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
59	1303-T05-CV02/00	CHECK VALVE OUTLET TANK T-05	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
60	1303-T05-SDD01/00	DIPHATCH / SLOT DIPPING DEVICE TANK T-05	No Spare no issue	N/A1	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
61	1303-T05-ATG01/00	AUTOMATIC TANK GAUGING (ATG) TANK T-05	No spare have issue	N/A1	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
62	1303-T05-GV04/00	GATE VALVE REDUNDANT INLET TANK T-05	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
63	1303-T05-GV05/00	GATE VALVE REDUNDANT OUTLET TANK T-05	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
64	1303-T05-TT01/00	TEMPERATURE TRANSMITTER TANK T-05	No spare have issue	N/A2	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
65	1303-TFA-T06/00	TANK STORAGE NO.06	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
66	1303-T06-GV01/00	GATE VALVE INLET TANK T-06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
67	1303-T06-FL01/00	FLEXIBLE JOINT INLET TANK T-06	No spare have issue	Combustible	sederhana	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
68	1303-T06-FL02/00	FLEXIBLE JOINT OUTLET TANK T-06	No spare have issue	Combustible	sederhana	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
69	1303-T06-GV02/00	GATE VALVE OUTLET TANK T-06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
70	1303-T06-GV03/00	GATE VALVE DRAIN TANK T-06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
71	1303-T06-CV01/00	CHECK VALVE INLET TANK T-06	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
72	1303-T06-CV02/00	CHECK VALVE OUTLET TANK T-06	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
73	1303-T06-SDD01/00	DIPHATCH / SLOT DIPPING DEVICE TANK T-06	No Spare no issue	N/A1	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
74	1303-T06-ATG01/00	AUTOMATIC TANK GAUGING (ATG) TANK T-06	No spare have issue	N/A1	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
75	1303-T06-GV04/00	GATE VALVE REDUNDANT INLET TANK T-06	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
76	1303-T06-GV05/00	GATE VALVE REDUNDANT OUTLET TANK T-06	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
77	1303-T06-TT01/00	TEMPERATURE TRANSMITTER TANK T-06	No spare have issue	N/A2	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
78	1303-TFA-T07/00	TANK STORAGE NO.07	No spare have issue	Flameable	kompleksitas kecil	Almost	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
79	1303-T07-GV01/00	GATE VALVE INLET TANK T-07	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
80	1303-T07-FL01/00	FlEXIBLE JOINT INLET TANK T-07	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
81	1303-T07-FL02/00	FlEXIBLE JOINT OUTLET TANK T-07	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
82	1303-T07-GV02/00	GATE VALVE OUTLET TANK T-07	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
83	1303-T07-GV03/00	GATE VALVE DRAIN TANK T-07	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
84	1303-T07-CV01/00	CHECK VALVE INLET TANK T-07	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
85	1303-T07-CV02/00	CHECK VALVE OUTLET TANK T-07	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
86	1303-T07-SDD01/00	DIPHATCH / SLOT DIPPING DEVICE TANK T-07	No Spare no issue	N/A1	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
87	1303-T07-ATG01/00	AUTOMATIC TANK GAUGING (ATG) TANK T-07	No spare have issue	N/A1	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
88	1303-T07-GV04/00	GATE VALVE REDUNDANT INLET TANK T-07	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
89	1303-T07-GV05/00	GATE VALVE REDUNDANT OUTLET TANK T-07	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
90	1303-T07-TT01/00	TEMPERATURE TRANSMITTER TANK T-07	No spare have issue	N/A2	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
91	1303-TFA-T08/00	TANK STORAGE NO.08	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
92	1303-T08-GV01/00	GATE VALVE INLET TANK T-08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
93	1303-T08-FL01/00	FLEXIBLE JOINT INLET TANK T-08	No spare have issue	Combustible	sederhana	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
94	1303-T08-FL02/00	FLEXIBLE JOINT OUTLET TANK T-08	No spare have issue	Combustible	sederhana	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
95	1303-T08-GV02/00	GATE VALVE OUTLET TANK T-08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
96	1303-T08-GV03/00	GATE VALVE DRAIN TANK T-08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
97	1303-T08-CV01/00	CHECK VALVE INLET TANK T-08	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
98	1303-T08-CV02/00	CHECK VALVE OUTLET TANK T-08	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
99	1303-T08-ATG01/00	AUTOMATIC TANK GAUGING (ATG) TANK T-08	No spare have issue	N/A1	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
100	1303-T08-GV04/00	GATE VALVE REDUNDANT INLET TANK T-08	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
101	1303-T08-GV05/00	GATE VALVE REDUNDANT OUTLET TANK T-08	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
102	1303-T08-TT01/00	TEMPERATURE TRANSMITTER TANK T-08	No spare have issue	N/A2	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
103	1303-TFA-T09/00	TANK STORAGE NO.09	No spare have issue	Flameable	kompleksitas kecil	Almost	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
104	1303-T09-GV01/00	GATE VALVE INLET TANK T-09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
105	1303-T09-FL01/00	FLEXIBLE JOINT INLET TANK T-09	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
106	1303-T09-FL02/00	FLEXIBLE JOINT OUTLET TANK T-09	No spare have issue	Flameable	sederhana	Almost	minor	0%<LP<10%	Cost<USD1000	H	Vital	V
107	1303-T09-GV02/00	GATE VALVE OUTLET TANK T-09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
108	1303-T09-GV03/00	GATE VALVE DRAIN TANK T-09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
109	1303-T09-CV01/00	CHECK VALVE INLET TANK T-09	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
110	1303-T09-CV02/00	CHECK VALVE OUTLET TANK T-09	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
111	1303-T09-SDD01/00	DIPHATCH / SLOT DIPPING DEVICE TANK T-09	No Spare no issue	N/A1	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
112	1303-T09-ATG01/00	AUTOMATIC TANK GAUGING (ATG) TANK T-09	No spare have issue	N/A1	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
113	1303-T09-GV04/00	GATE VALVE REDUNDANT INLET TANK T-09	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
114	1303-T09-GV05/00	GATE VALVE REDUNDANT OUTLET TANK T-09	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
115	1303-T09-TT01/00	TEMPERATURE TRANSMITTER TANK T-09	No spare have issue	N/A2	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
116	1303-TFA-T10/00	TANK STORAGE NO.10	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
117	1303-T10-GV01/00	GATE VALVE INLET TANK T-10	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
118	1303-T10-FL01/00	FLEXIBLE JOINT INLET TANK T-10	No spare have issue	Combustible	sederhana	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
119	1303-T10-FL02/00	FLEXIBLE JOINT OUTLET TANK T-10	No spare have issue	Combustible	sederhana	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
120	1303-T10-GV02/00	GATE VALVE OUTLET TANK T-10	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
121	1303-T10-GV03/00	GATE VALVE DRAIN TANK T-10 NO.1	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
122	1303-T10-GV04/00	GATE VALVE DRAIN TANK T-10 NO.2	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
123	1303-T10-GV05/00	GATE VALVE DRAIN TANK T-10 NO.3	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
124	1303-T10-CV01/00	CHECK VALVE INLET TANK T-10	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
125	1303-T10-CV02/00	CHECK VALVE OUTLET TANK T-10	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
126	1303-T10-GV06/00	GATE VALVE REDUNDANT INLET TANK T-10	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
127	1303-T10-GV07/00	GATE VALVE REDUNDANT OUTLET TANK T-10	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
128	1303-T01-PP01/00	PIPING INLET TANK T-01	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
129	1303-T01-PP02/00	PIPING OUTLET TANK T-01	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
130	1303-T01-PP03/00	PIPING CLOSED DRAIN TANK T-01	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
131	1303-T02-PP01/00	PIPING INLET TANK T-02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
132	1303-T02-PP02/00	PIPING OUTLET TANK T-02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
133	1303-T02-PP03/00	PIPING CLOSED DRAIN TANK T-02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
134	1303-T03-PP01/00	PIPING INLET TANK T-03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
135	1303-T03-PP02/00	PIPING OUTLET TANK T-03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
136	1303-T03-PP03/00	PIPING CLOSED DRAIN TANK T-03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
137	1303-T04-PP01/00	PIPING INLET TANK T-04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
138	1303-T04-PP02/00	PIPING OUTLET TANK T-04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
139	1303-T04-PP03/00	PIPING CLOSED DRAIN TANK T-04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
140	1303-T05-PP01/00	PIPING INLET TANK T-05	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
141	1303-T05-PP02/00	PIPING OUTLET TANK T-05	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
142	1303-T05-PP03/00	PIPING CLOSED DRAIN TANK T-05	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
143	1303-T06-PP01/00	PIPING INLET TANK T-06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
144	1303-T06-PP02/00	PIPING OUTLET TANK T-06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
145	1303-T06-PP03/00	PIPING CLOSED DRAIN TANK T-06	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
146	1303-T07-PP01/00	PIPING INLET TANK T-07	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
147	1303-T07-PP02/00	PIPING OUTLET TANK T-07	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
148	1303-T07-PP03/00	PIPING CLOSED DRAIN TANK T-07	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
149	1303-T08-PP01/00	PIPING INLET TANK T-08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
150	1303-T08-PP02/00	PIPING OUTLET TANK T-08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
151	1303-T08-PP03/00	PIPING CLOSED DRAIN TANK T-08	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
152	1303-T09-PP01/00	PIPING INLET TANK T-09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
153	1303-T09-PP02/00	PIPING OUTLET TANK T-09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
154	1303-T09-PP03/00	PIPING CLOSED DRAIN TANK T-09	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
155	1303-T10-PP01/00	PIPING INLET TANK T-10	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
156	1303-T10-PP02/00	PIPING OUTLET TANK T-10	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
157	1303-T10-PP03/00	PIPING CLOSED DRAIN NO.1 TANK T-10	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
158	1303-T10-PP04/00	PIPING CLOSED DRAIN NO.2 TANK T-10	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
159	1303-T10-PP05/00	PIPING CLOSED DRAIN NO.3 TANK T-10	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
160	1303-TFA-PP01/00	PIPING RECEIVING FUEL PRODUK 1	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
161	1303-TFA-PP02/00	PIPING RECEIVING FUEL PRODUK 2	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
162	1303-TFA-PP03/00	PIPING RECEIVING FUEL PRODUK 3	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
163	1303-TFA-PP04/00	PIPING RECEIVING FUEL PRODUK 4	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
164	1303-TFA-PP05/00	PIPING DISTRIBUTION FUEL PRODUK 1	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
165	1303-TFA-PP06/00	PIPING DISTRIBUTION FUEL PRODUK 2	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
166	1303-TFA-PP07/00	PIPING DISTRIBUTION FUEL PRODUK 3	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
167	1303-TFA-PP08/00	PIPING DISTRIBUTION FUEL PRODUK 4	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
168	1303-T01-GV06/00	GATE VALVE FIRE WATER TO TANK T-01	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
169	1303-T02-GV06/00	GATE VALVE FIRE WATER TO TANK T-02	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
170	1303-T03-GV06/00	GATE VALVE FIRE WATER TO TANK T-03	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
171	1303-T04-GV06/00	GATE VALVE FIRE WATER TO TANK T-04	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
172	1303-T05-GV06/00	GATE VALVE FIRE WATER TO TANK T-05	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
173	1303-T06-GV06/00	GATE VALVE FIRE WATER TO TANK T-06	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
174	1303-T07-GV06/00	GATE VALVE FIRE WATER TO TANK T-07	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
175	1303-T08-GV06/00	GATE VALVE FIRE WATER TO TANK T-08	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
176	1303-T09-GV06/00	GATE VALVE FIRE WATER TO TANK T-09	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
177	1303-T10-GV08/00	GATE VALVE FIRE WATER TO TANK T-10	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
178	1303-T02-BV01/00	BALL VALVE FOAM SYSTEM TO TANK T-02	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
179	1303-T03-BV01/00	BALL VALVE FOAM SYSTEM TO TANK T-03	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
180	1303-T04-GV07/00	GATE VALVE FOAM SYSTEM TO TANK T-04	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
181	1303-T05-BV01/00	BALL VALVE FOAM SYSTEM TO TANK T-05	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
182	1303-T06-BV01/00	BALL VALVE FOAM SYSTEM TO TANK T-06	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
183	1303-T07-GV07/00	GATE VALVE FOAM SYSTEM TO TANK T-07	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
184	1303-T08-BV01/00	BALL VALVE FOAM SYSTEM TO TANK T-08	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
185	1303-T09-BV01/00	BALL VALVE FOAM SYSTEM TO TANK T-09	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
186	1303-T10-BV01/00	BALL VALVE FOAM SYSTEM TO TANK T-10	No spare have issue	Non Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
187	1303-PSU-P01/00	PUMP PRODUCT P-01	No spare have issue	Flameable	kompleksitas sedang	Almost	minor	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
188	1303-P01-EM01/00	MOTOR DRIVER PUMP P-01	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
189	1303-P01-GV01/00	GATE VALVE SUCTION PUMP P-01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
190	1303-P01-GV02/00	GATE VALVE DISCHARGE PUMP P-01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
191	1303-P01-STR01/00	STRAINER PUMP P-01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
192	1303-P01-CV02/00	CHECK VALVE DISCHARGE PUMP P-01	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
193	1303-P01-PG02/00	PRESSURE GAUGE OUTLET PUMP P-01	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
194	1303-P01-PG01/00	PRESSURE GAUGE INLET PUMP P-01	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
195	1303-P01-GND01/00	GROUNDING PUMP P-01	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
196	1303-P01-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-01	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
197	1303-P01-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-01	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
198	1303-PSU-P02/00	PUMP PRODUCT P-02	No spare have issue	Flameable	kompleksitas sedang	Almost	minor	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
199	1303-P02-EM01/00	MOTOR DRIVER PUMP P-02	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
200	1303-P02-GV01/00	GATE VALVE SUCTION PUMP P-02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
201	1303-P02-GV02/00	GATE VALVE DISCHARGE PUMP P-02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
202	1303-P02-STR01/00	STRAINER PUMP P-02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
203	1303-P02-CV02/00	CHECK VALVE DISCHARGE PUMP P-02	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
204	1303-P02-PG02/00	PRESSURE GAUGE,PUMP P-02	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
205	1303-P02-PG01/00	VACUUM GAUGE,PUMP P-02	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
206	1303-P02-GND01/00	GROUNDING PUMP P-02	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
207	1303-P02-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
208	1303-P02-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
209	1303-PSU-P03/00	PUMP PRODUCT P-03	No spare have issue	Flameable	kompleksitas sedang	Almost	minor	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
210	1303-P03-EM01/00	MOTOR DRIVER PUMP P-03	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
211	1303-P03-GV01/00	GATE VALVE SUCTION PUMP P-03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
212	1303-P03-GV02/00	GATE VALVE DISCHARGE PUMP P-03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
213	1303-P03-STR01/00	STRAINER PUMP P-03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
214	1303-P03-CV02/00	CHECK VALVE DISCHARGE PUMP P-03	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
215	1303-P03-PG02/00	PRESSURE GAUGE,PUMP P-03	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
216	1303-P03-PG01/00	VACUUM GAUGE,PUMP P-03	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
217	1303-P03-GND01/00	GROUNDING PUMP P-03	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
218	1303-P03-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
219	1303-P03-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
220	1303-P03-PT01/00	PRESSURE TRANSMITTER OULET PUMP P-03	No spare have issue	N/A2	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
221	1303-PSU-P04/00	PUMP PRODUCT P-04	No spare have issue	Flameable	kompleksitas sedang	Almost	minor	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
222	1303-P04-EM01/00	MOTOR DRIVER PUMP P-04	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
223	1303-P04-GV01/00	GATE VALVE SUCTION PUMP P-04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
224	1303-P04-GV02/00	GATE VALVE DISCHARGE PUMP P-04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
225	1303-P04-STR01/00	STRAINER PUMP P-04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
226	1303-P04-CV02/00	CHECK VALVE DISCHARGE PUMP P-04	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
227	1303-P04-PG02/00	PRESSURE GAUGE,PUMP P-04	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
228	1303-P04-PG01/00	VACUUM GAUGE,PUMP P-04	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
229	1303-P04-GND01/00	GROUNDING PUMP P-04	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
230	1303-P04-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
231	1303-P04-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
232	1303-PSU-P05/00	PUMP PRODUCT P-05	No spare have issue	Combustible	kompleksitas sedang	Likely	moderate	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
233	1303-P05-EM01/00	MOTOR DRIVER PUMP P-05	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
234	1303-P05-GV01/00	GATE VALVE SUCTION PUMP P-05	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
235	1303-P05-GV02/00	GATE VALVE DISCHARGE PUMP P-05	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
236	1303-P05-STR01/00	STRAINER PUMP P-05	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
237	1303-P05-CV02/00	CHECK VALVE DISCHARGE PUMP P-05	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
238	1303-P05-PG02/00	PRESSURE GAUGE,PUMP P-05	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
239	1303-P05-PG01/00	VACUUM GAUGE,PUMP P-05	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
240	1303-P05-GND01/00	GROUNDING PUMP P-05	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
241	1303-P05-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-05	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
242	1303-P05-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-05	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
243	1303-PSU-P06/00	PUMP PRODUCT P-06	No spare have issue	Combustible	kompleksitas sedang	Likely	moderate	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
244	1303-P06-EM01/00	MOTOR DRIVER PUMP P-06	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
245	1303-P06-GV01/00	GATE VALVE SUCTION PUMP P-06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
246	1303-P06-GV02/00	GATE VALVE DISCHARGE PUMP P-06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
247	1303-P06-STR01/00	STRAINER PUMP P-06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
248	1303-P06-CV02/00	CHECK VALVE DISCHARGE PUMP P-06	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
249	1303-P06-PG02/00	PRESSURE GAUGE,PUMP P-06	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
250	1303-P06-PG01/00	VACUUM GAUGE,PUMP P-06	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
251	1303-P06-GND01/00	GROUNDING PUMP P-06	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
252	1303-P06-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-06	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
253	1303-P06-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-06	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
254	1303-PSU-P07/00	PUMP PRODUCT P-07	No spare have issue	Combustible	kompleksitas sedang	Likely	moderate	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
255	1303-P07-EM01/00	MOTOR DRIVER PUMP P-07	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
256	1303-P07-GV01/00	GATE VALVE SUCTION PUMP P-07	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
257	1303-P07-GV02/00	GATE VALVE DISCHARGE PUMP P-07	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
258	1303-P07-STR01/00	STRAINER PUMP P-07	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
259	1303-P07-CV02/00	CHECK VALVE DISCHARGE PUMP P-07	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
260	1303-P07-PG02/00	PRESSURE GAUGE,PUMP P-07	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
261	1303-P07-PG01/00	VACUUM GAUGE,PUMP P-07	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
262	1303-P07-GND01/00	GROUNDING PUMP P-07	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
263	1303-P07-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-07	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
264	1303-P07-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-07	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
265	1303-PSU-P08/00	PUMP PRODUCT P-08	No spare have issue	Combustible	kompleksitas sedang	Likely	moderate	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
266	1303-P08-EM01/00	MOTOR DRIVER PUMP P-08	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
267	1303-P08-GV01/00	GATE VALVE SUCTION PUMP P-08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
268	1303-P08-GV02/00	GATE VALVE DISCHARGE PUMP P-08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
269	1303-P08-STR01/00	STRAINER PUMP P-08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
270	1303-P08-CV02/00	CHECK VALVE DISCHARGE PUMP P-08	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
271	1303-P08-PG02/00	PRESSURE GAUGE,PUMP P-08	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
272	1303-P08-PG01/00	VACUUM GAUGE,PUMP P-08	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
273	1303-P08-GND01/00	GROUNDING PUMP P-08	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
274	1303-P08-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-08	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
275	1303-P08-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-08	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
276	1303-PSU-P09/00	PUMP PRODUCT P-09	No spare have issue	Flameable	kompleksitas sedang	Almost	minor	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
277	1303-P09-EM01/00	MOTOR DRIVER PUMP P-09	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
278	1303-P09-GV01/00	GATE VALVE SUCTION PUMP P-09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
279	1303-P09-GV02/00	GATE VALVE DISCHARGE PUMP P-09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
280	1303-P09-STR01/00	STRAINER PUMP P-09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
281	1303-P09-CV02/00	CHECK VALVE DISCHARGE PUMP P-09	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
282	1303-P09-PG02/00	PRESSURE GAUGE,PUMP P-09	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
283	1303-P09-PG01/00	VACUUM GAUGE,PUMP P-09	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
284	1303-P09-GND01/00	GROUNDING PUMP P-09	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
285	1303-P09-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-09	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
286	1303-P09-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-09	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
287	1303-PSU-P10/00	PUMP PRODUCT P-10	No spare have issue	Flameable	kompleksitas sedang	Almost	minor	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
288	1303-P10-EM01/00	MOTOR DRIVER PUMP P-10	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
289	1303-P10-GV01/00	GATE VALVE SUCTION PUMP P-10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
290	1303-P10-GV02/00	GATE VALVE DISCHARGE PUMP P-10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
291	1303-P10-STR01/00	STRAINER PUMP P-10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
292	1303-P10-CV02/00	CHECK VALVE DISCHARGE PUMP P-10	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
293	1303-P10-PG02/00	PRESSURE GAUGE,PUMP P-10	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
294	1303-P10-PG01/00	VACUUM GAUGE,PUMP P-10	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
295	1303-P10-GND01/00	GROUNDING PUMP P-10	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
296	1303-P10-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-10	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
297	1303-P10-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-10	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
298	1303-PSU-P11/00	PUMP PRODUCT P-11	No spare have issue	Combustible	kompleksitas sedang	Likely	moderate	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
299	1303-P11-EM01/00	MOTOR DRIVER PUMP P-11	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
300	1303-P11-GV01/00	GATE VALVE SUCTION PUMP P-11	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
301	1303-P11-GV02/00	GATE VALVE DISCHARGE PUMP P-11	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
302	1303-P11-STR01/00	STRAINER PUMP P-11	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
303	1303-P11-CV02/00	CHECK VALVE DISCHARGE PUMP P-11	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
304	1303-P11-PG02/00	PRESSURE GAUGE,PUMP P-11	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
305	1303-P11-PG01/00	VACUUM GAUGE,PUMP P-11	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
306	1303-P11-GND01/00	GROUNDING PUMP P-11	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
307	1303-P11-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-11	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
308	1303-P11-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-11	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
309	1303-PSU-P12/00	PUMP PRODUCT P-12	No spare have issue	Flameable	kompleksitas sedang	Almost	minor	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
310	1303-P12-EM01/00	MOTOR DRIVER PUMP P-12	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
311	1303-P12-GV01/00	GATE VALVE SUCTION PUMP P-12	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
312	1303-P12-GV02/00	GATE VALVE DISCHARGE PUMP P-12	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
313	1303-P12-STR01/00	STRAINER PUMP P-12	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
314	1303-P12-CV02/00	CHECK VALVE DISCHARGE PUMP P-12	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
315	1303-P12-PG02/00	PRESSURE GAUGE,PUMP P-12	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
316	1303-P12-PG01/00	VACUUM GAUGE,PUMP P-12	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
317	1303-P12-GND01/00	GROUNDING PUMP P-12	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
318	1303-P12-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-12	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
319	1303-P12-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-12	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
320	1303-PSU-P13/00	PUMP PRODUCT P-13	No spare have issue	Flameable	kompleksitas sedang	Almost	minor	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
321	1303-P13-EM01/00	MOTOR DRIVER PUMP P-13	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
322	1303-P13-GV01/00	GATE VALVE SUCTION PUMP P-13	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
323	1303-P13-GV02/00	GATE VALVE DISCHARGE PUMP P-13	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
324	1303-P13-STR01/00	STRAINER PUMP P-13	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
325	1303-P13-CV02/00	CHECK VALVE DISCHARGE PUMP P-13	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
326	1303-P13-PG02/00	PRESSURE GAUGE,PUMP P-13	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
327	1303-P13-PG01/00	VACUUM GAUGE,PUMP P-13	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
328	1303-P13-GND01/00	GROUNDING PUMP P-13	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
329	1303-P13-FL01/00	FLEXIBLE JOINT SUCTION PUMP P-13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
330	1303-P13-FL02/00	FLEXIBLE JOINT DISCHARGE PUMP P-13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
331	1303-P01-PP01/00	PIPING INLET PUMP P-01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
332	1303-P01-PP02/00	PIPING OUTLET PUMP P-01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
333	1303-P02-PP01/00	PIPING INLET PUMP P-02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
334	1303-P02-PP02/00	PIPING OUTLET PUMP P-02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
335	1303-P03-PP01/00	PIPING INLET PUMP P-03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
336	1303-P03-PP02/00	PIPING OUTLET PUMP P-03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
337	1303-P04-PP01/00	PIPING INLET PUMP P-04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
338	1303-P04-PP02/00	PIPING OUTLET PUMP P-04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
339	1303-P05-PP01/00	PIPING INLET PUMP P-05	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
340	1303-P05-PP02/00	PIPING OUTLET PUMP P-05	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
341	1303-P06-PP01/00	PIPING INLET PUMP P-06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
342	1303-P06-PP02/00	PIPING OUTLET PUMP P-06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
343	1303-P07-PP01/00	PIPING INLET PUMP P-07	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
344	1303-P07-PP02/00	PIPING OUTLET PUMP P-07	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
345	1303-P08-PP01/00	PIPING INLET PUMP P-08	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
346	1303-P08-PP02/00	PIPING OUTLET PUMP P-08	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
347	1303-P09-PP01/00	PIPING INLET PUMP P-09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
348	1303-P09-PP02/00	PIPING OUTLET PUMP P-09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
349	1303-P10-PP01/00	PIPING INLET PUMP P-10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
350	1303-P10-PP02/00	PIPING OUTLET PUMP P-10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
351	1303-P11-PP01/00	PIPING INLET PUMP P-11	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
352	1303-P11-PP02/00	PIPING OUTLET PUMP P-11	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
353	1303-P12-PP01/00	PIPING INLET PUMP P-12	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
354	1303-P12-PP02/00	PIPING OUTLET PUMP P-12	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
355	1303-P13-PP01/00	PIPING INLET PUMP P-13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
356	1303-P13-PP02/00	PIPING OUTLET PUMP P-13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
357	1303-RF3-PP04/00	PIPING RECEIVING FUEL PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
358	1303-RF3-PP05/00	PIPING RECEIVING FUEL PERTAMAX	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
359	1303-RF3-PP06/00	PIPING RECEIVING FUEL BIOSOLAR	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
360	1303-RF4-PP02/00	PIPING RECEIVING FUEL PERTADEX	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
361	1303-PSU-PP01/00	PIPING DISTRIBUTION FUEL PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
362	1303-PSU-PP02/00	PIPING DISTRIBUTION FUEL PERTAMAX	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
363	1303-PSU-PP03/00	PIPING DISTRIBUTION FUEL BIOSOLAR	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
364	1303-PSU-PP04/00	PIPING DISTRIBUTION FUEL PERTADEX	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
365	1303-PSU-GV01/00	GATE VALVE MAIN PRODUK FROM TANK PL	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
366	1303-PSU-GV02/00	GATE VALVE MAIN PRODUK FROM TANK PX	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
367	1303-PSU-GV03/00	GATE VALVE MAIN PRODUK FROM TANK BIO	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
368	1303-PSU-GV19/00	GATE VALVE P01 TO PERTALITE HEADER	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
369	1303-PSU-GV21/00	GATE VALVE P01 TO PERTALITE HEADER	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
370	1303-PSU-GV23/00	GATE VALVE P02 TO PERTALITE HEADER	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
371	1303-PSU-GV25/00	GATE VALVE BY PASS P02 TO P01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
372	1303-PSU-GV26/00	GATE VALVE BY PASS P02 TO P03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
373	1303-PSU-GV34/00	GATE VALVE BYPASS P05 TO PERTADEX HEADER	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
374	1303-PSU-GV37/00	GATE VALVE BY PASS P05 TO P07	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
375	1303-PSU-GV39/00	GATE VALVE P06 TO BIOSOLAR HEADER	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
376	1303-PSU-GV41/00	GATE VALVE P07 TO BIOSOLAR HEADER	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
377	1303-PSU-GV50/00	GATE VALVE PERTAMAX HEADER TO P10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
378	1303-PSU-GV52/00	GATE VALVE P10 TO PERTAMAX HEADER	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
379	1303-PSU-GV53/00	GATE VALVE PERTAMAX HEADER TO P12	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
380	1303-PSU-GV54/00	GATE VALVE FROM HEADER PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
381	1303-PSU-GV55/00	GATE VALVE FROM HEADER PERTAMAX	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
382	1303-PSU-GV56/00	GATE VALVE TO HEADER PERTAMAX	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
383	1303-PSU-GV61/00	GATE VALVE IN,PIPE REC PROD 4,P13	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
384	1303-PSU-GV63/00	GATE VALVE OUT,PIPE REC PROD 4,P13	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
385	1303-PSU-GV46/00	GATE VALVE PERTAMAX HEADER TO P09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
386	1303-PSU-GV48/00	GATE VALVE P09 TO PERTAMAX HEADER	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
387	1303-PSU-GV18/00	GATE VALVE PERTALITE HEADER TO P01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
388	1303-PSU-GV20/00	GATE VALVE P01 TO PERTALITE HEADER	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
389	1303-PSU-GV22/00	GATE VALVE PERTALITE HEADER TO P02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
390	1303-PSU-GV24/00	GATE VALVE P02 TO PERTALITE HEADER	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
391	1303-PSU-GV27/00	GATE VALVE PERTALITE HEADER TO P03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
392	1303-PSU-GV28/00	GATE VALVE BY PASS P03 TO P02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
393	1303-PSU-GV29/00	GATE VALVE PERTALITE HEADER TO P04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
394	1303-PSU-GV30/00	GATE VALVE P04 TO P03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
395	1303-PSU-GV31/00	GATE VALVE BY PASS P04 TO P03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
396	1303-PSU-GV33/00	GATE VALVE P05 TO PERTADEX HEADER	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
397	1303-PSU-GV32/00	GATE VALVE PERTADEX HEADER TO P05	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
398	1303-PSU-GV35/00	GATE VALVE P06 TO P05	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
399	1303-PSU-GV36/00	GATE VALVE BIOSOLAR HEADER TO P06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
400	1303-PSU-GV38/00	GATE VALVE P06 TO BIOSOLAR HEADER	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
401	1303-PSU-GV40/00	GATE VALVE BIOSOLAR HEADER TO P07	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
402	1303-PSU-GV42/00	GATE VALVE P07 TO BIOSOLAR HEADER	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
403	1303-PSU-GV43/00	GATE VALVE BIOSOLAR HEADER TO P08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
404	1303-PSU-GV44/00	GATE VALVE P08 TO BIOSOLAR HEADER	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
405	1303-PSU-GV45/00	GATE VALVE PERTAMAX HEADER TO P09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
406	1303-PSU-GV47/00	GATE VALVE P09 TO PERTAMAX HEADER	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
407	1303-PSU-GV57/00	GATE VALVE TO HEADER PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
408	1303-PSU-GV58/00	GATE VALVE P12 TO HEADER PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
409	1303-PSU-GV59/00	GATE VALVE P12 TO HEADER PERTAMAX	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
410	1303-PSU-GV60/00	GATE VALVE IN,PIPE DIST PROD 4,P13	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
411	1303-PSU-GV62/00	GATE VALVE OUT,PIPE DIST PROD 4,P13	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
412	1303-PSU-GV49/00	GATE VALVE PERTAMAX HEADER TO P10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
413	1303-PSU-GV51/00	GATE VALVE P10 TO PERTAMAX HEADER	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
414	1303-PSU-GV08/00	GATE VALVE TO TANK PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
415	1303-PSU-GV10/00	GATE VALVE FROM PUMP TO TANK PERTAMAX	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
416	1303-PSU-GV12/00	GATE VALVE FROM RECEIV TO PUMP BIOSOLAR	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
417	1303-PSU-GV09/00	GATE VALVE FROM RECEIV TO PUMP PERTAMAX	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
418	1303-PSU-STR01/00	STRAINER FROM REC TO PUMP PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
419	1303-PSU-GV04/00	GATE VALVE FROM REC TO PUMP PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
420	1303-PSU-GV05/00	GATE VALVE ISOTANK AND RTW REC PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
421	1303-PSU-GV06/00	GATE VALVE FROM ISOTANK AND RTW REC	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
422	1303-PSU-GV07/00	GATE VALVE TO PUMP PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
423	1303-PSU-STR02/00	STRAINER FROM REC TO PUMP PERTAMAX	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
424	1303-PSU-GV11/00	GATE VALVE FROM RECEIV TO PUMP BIOSOLAR	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
425	1303-PSU-STR03/00	STRAINER FROM REC TO PUMP BIOSOLAR	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
426	1303-PSU-STR04/00	STRAINER FROM REC TO PUMP PERTADEX	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
427	1303-PSU-GV13/00	GATE VALVE FROM REC TO PUMP PERTADEX	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
428	1303-PSU-GV14/00	GATE VALVE FROM RECEIV TO PUMP PERTADEX	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
429	1303-PSU-GV15/00	GATE VALVE FRM PUMP PERTADEX TO FILLSHED	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
430	1303-PSU-GV16/00	GATE VALVE FROM TANK PERTADEX	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
431	1303-PSU-GV17/00	GATE VALVE TO TANK PERTADEX	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
432	1303-PSU-CV01/00	CHECK VALVE FROM REC TO PUMP PERTALITE	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
433	1303-PSU-CV02/00	CHECK VALVE FROM REC TO PUMP PERTAMAX	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
434	1303-PSU-CV03/00	CHECK VALVE FROM REC TO PUMP BIOSOLAR	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
435	1303-PSU-CV04/00	CHECK VALVE FROM REC TO PUMP PERTADEX	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
436	1303-PSU-DV01/00	DELUGE VALVE FOAM SYSTEM PUMP STATION 01	No spare have issue	Non Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
437	1303-RF1-PP01/00	PIPING RECEIVING RTW JALUR 1 PROD 1	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
438	1303-RF1-GV01/00	GATE VALVE LINE REC JALUR 1 PROD 1 NO.01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
439	1303-RF1-GV02/00	GATE VALVE LINE REC JALUR 1 PROD 1 NO.02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
440	1303-RF1-GV03/00	GATE VALVE LINE REC JALUR 1 PROD 1 NO.03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
441	1303-RF1-GV04/00	GATE VALVE LINE REC JALUR 1 PROD 1 NO.04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
442	1303-RF1-GV05/00	GATE VALVE LINE REC JALUR 1 PROD 1 NO.05	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
443	1303-RF1-GV06/00	GATE VALVE LINE REC JALUR 1 PROD 1 NO.06	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
444	1303-RF1-GV07/00	GATE VALVE LINE REC JALUR 1 PROD 1 NO.07	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
445	1303-RF1-GV08/00	GATE VALVE LINE REC JALUR 1 PROD 1 NO.08	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
446	1303-RF1-GV09/00	GATE VALVE LINE REC JALUR 1 PROD 1 NO.09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
447	1303-RF2-PP01/00	PIPING RECEIVING RTW JALUR 2 PROD 1	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
448	1303-RF2-GV01/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
449	1303-RF2-GV02/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
450	1303-RF2-GV03/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
451	1303-RF2-GV04/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
452	1303-RF2-GV05/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.05	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
453	1303-RF2-GV06/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.06	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
454	1303-RF2-GV07/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.07	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
455	1303-RF2-GV08/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.08	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
456	1303-RF2-GV09/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
457	1303-RF2-GV10/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
458	1303-RF2-GV11/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.11	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
459	1303-RF2-GV12/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.12	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
460	1303-RF2-GV13/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.13	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
461	1303-RF2-GV14/00	GATE VALVE LINE REC JALUR 2 PROD 1 NO.14	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
462	1303-RF2-PP02/00	PIPING RECEIVING RTW JALUR 2 PROD 2	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
463	1303-RF2-GV15/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
464	1303-RF2-GV16/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
465	1303-RF2-GV17/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
466	1303-RF2-GV18/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
467	1303-RF2-GV19/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.05	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
468	1303-RF2-GV20/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.06	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
469	1303-RF2-GV21/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.07	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
470	1303-RF2-GV22/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.08	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
471	1303-RF2-GV23/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
472	1303-RF2-GV24/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
473	1303-RF2-GV25/00	GATE VALVE LINE REC JALUR 2 PROD 2 NO.11	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
474	1303-RF2-PP03/00	PIPING RECEIVING RTW JALUR 2 PROD 3	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
475	1303-RF2-GV26/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.01	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
476	1303-RF2-GV27/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.02	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
477	1303-RF2-GV28/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.03	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
478	1303-RF2-GV29/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.04	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
479	1303-RF2-GV30/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.05	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
480	1303-RF2-GV31/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
481	1303-RF2-GV32/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.07	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
482	1303-RF2-GV33/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
483	1303-RF2-GV34/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.09	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
484	1303-RF2-GV35/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.10	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
485	1303-RF2-GV36/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.11	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
486	1303-RF2-GV37/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.12	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
487	1303-RF2-GV38/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.13	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
488	1303-RF2-GV39/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.14	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
489	1303-RF2-GV40/00	GATE VALVE LINE REC JALUR 2 PROD 3 NO.15	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
490	1303-RF3-PP01/00	PIPING RECEIVING RTW JALUR 3 PROD 1	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
491	1303-RF3-GV01/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
492	1303-RF3-GV02/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
493	1303-RF3-GV03/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
494	1303-RF3-GV04/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
495	1303-RF3-GV05/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.05	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
496	1303-RF3-GV06/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.06	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
497	1303-RF3-GV07/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.07	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
498	1303-RF3-GV08/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.08	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
499	1303-RF3-GV09/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
500	1303-RF3-GV10/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
501	1303-RF3-GV11/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.11	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
502	1303-RF3-GV12/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.12	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
503	1303-RF3-GV13/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.13	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
504	1303-RF3-GV14/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.14	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
505	1303-RF3-GV15/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.15	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
506	1303-RF3-GV16/00	GATE VALVE LINE REC JALUR 3 PROD 1 NO.16	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
507	1303-RF3-PP02/00	PIPING RECEIVING RTW JALUR 3 PROD 2	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
508	1303-RF3-GV17/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.01	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
509	1303-RF3-GV18/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.02	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
510	1303-RF3-GV19/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.03	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
511	1303-RF3-GV20/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.04	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
512	1303-RF3-GV21/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.05	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
513	1303-RF3-GV22/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.06	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
514	1303-RF3-GV23/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.07	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
515	1303-RF3-GV24/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.08	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
516	1303-RF3-GV25/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.09	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
517	1303-RF3-GV26/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.10	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
518	1303-RF3-GV27/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.11	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
519	1303-RF3-GV28/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.12	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
520	1303-RF3-GV29/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.13	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
521	1303-RF3-GV30/00	GATE VALVE LINE REC JALUR 3 PROD 2 NO.14	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
522	1303-RF3-PP03/00	PIPING RECEIVING RTW JALUR 3 PROD 3	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
523	1303-RF3-GV31/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.01	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
524	1303-RF3-GV32/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.02	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
525	1303-RF3-GV33/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.03	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
526	1303-RF3-GV34/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.04	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
527	1303-RF3-GV35/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.05	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
528	1303-RF3-GV36/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
529	1303-RF3-GV37/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.07	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
530	1303-RF3-GV38/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.08	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
531	1303-RF3-GV39/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.09	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
532	1303-RF3-GV40/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.10	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
533	1303-RF3-GV41/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.11	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
534	1303-RF3-GV42/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.12	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
535	1303-RF3-GV43/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.13	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
536	1303-RF3-GV44/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.14	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
537	1303-RF3-GV45/00	GATE VALVE LINE REC JALUR 3 PROD 3 NO.15	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
538	1303-RF4-PP01/00	PIPING RECEIVING ISOTANK	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
539	1303-RF4-GV01/00	GATE VALVE LINE RECEIVING ISOTANK NO.01	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
540	1303-RF4-GV02/00	GATE VALVE LINE RECEIVING ISOTANK NO.02	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
541	1303-RF4-GV03/00	GATE VALVE LINE RECEIVING ISOTANK NO.03	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
542	1303-RF4-GV04/00	GATE VALVE LINE RECEIVING ISOTANK NO.04	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
543	1303-RF4-GV05/00	GATE VALVE LINE RECEIVING ISOTANK NO.05	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
544	1303-RF4-GV06/00	GATE VALVE LINE RECEIVING ISOTANK NO.06	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
545	1303-LB01-FM07/00	FLOW METER / BULK METER NO.07	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
546	1303-LB01-FM12/00	FLOW METER / BULK METER NO.12	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
547	1303-LB01-FM14/00	FLOW METER / BULK METER NO.14	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
548	1303-LB01-FM15/00	FLOW METER / BULK METER NO.15	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
549	1303-LB01-DCV07/00	CONTROL VALVE METER NO.07	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
550	1303-LB01-DCV12/00	CONTROL VALVE METER NO.12	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
551	1303-LB01-DCV14/00	CONTROL VALVE METER NO.14	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
552	1303-LB01-DCV15/00	CONTROL VALVE METER NO.15	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
553	1303-LB01-BC07/00	DISPLAY CONTROL,METER NO.07	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
554	1303-LB01-BC12/00	DISPLAY CONTROL,METER NO.12	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
555	1303-LB01-BC14/00	DISPLAY CONTROL,METER NO.14	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
556	1303-LB01-BC15/00	DISPLAY CONTROL,METER NO.15	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
557	1303-LB01-STR07/00	STRAINER,METER NO.07	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
558	1303-LB01-STR12/00	STRAINER,METER NO.12	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
559	1303-LB01-STR14/00	STRAINER,METER NO.14	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
560	1303-LB01-STR15/00	STRAINER,METER NO.15	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
561	1303-LB01-AS07/00	AIR ELIMINATOR,METER NO.07	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
562	1303-LB01-AS12/00	AIR ELIMINATOR,METER NO.12	No spare have issue	Combustible	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
563	1303-LB01-AS14/00	AIR ELIMINATOR,METER NO.14	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
564	1303-LB01-AS15/00	AIR ELIMINATOR,METER NO.15	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
565	1303-LB02-FM08/00	FLOW METER / BULK METER NO.08	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
566	1303-LB02-FM13/00	FLOW METER / BULK METER NO.13	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
567	1303-LB02-FM18/00	FLOW METER / BULK METER NO.18	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
568	1303-LB02-DCV08/00	CONTROL VALVE METER NO.08	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
569	1303-LB02-DCV13/00	CONTROL VALVE METER NO.13	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
570	1303-LB02-DCV18/00	CONTROL VALVE METER NO.18	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
571	1303-LB02-BC08/00	DISPLAY CONTROL,METER NO.08	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
572	1303-LB02-BC13/00	DISPLAY CONTROL,METER NO.13	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
573	1303-LB02-BC18/00	DISPLAY CONTROL,METER NO.18	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
574	1303-LB02-STR08/00	STRAINER,METER NO.08	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
575	1303-LB02-STR13/00	STRAINER,METER NO.13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
576	1303-LB02-STR18/00	STRAINER,METER NO.18	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
577	1303-LB02-AS08/00	AIR ELIMINATOR,METER NO.08	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
578	1303-LB02-AS13/00	AIR ELIMINATOR,METER NO.13	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
579	1303-LB02-AS18/00	AIR ELIMINATOR,METER NO.18	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
580	1303-LB03-FM02/00	FLOW METER / BULK METER NO.02	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
581	1303-LB04-FM09/00	FLOW METER / BULK METER NO.09	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
582	1303-LB03-FM16/00	FLOW METER / BULK METER NO.16	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
583	1303-LB03-FM17/00	FLOW METER / BULK METER NO.17	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
584	1303-LB03-DCV02/00	CONTROL VALVE METER NO.02	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
585	1303-LB04-DCV09/00	CONTROL VALVE METER NO.09	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
586	1303-LB03-DCV16/00	CONTROL VALVE METER NO.16	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
587	1303-LB03-DCV17/00	CONTROL VALVE METER NO.17	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
588	1303-LB03-BC02/00	DISPLAY CONTROL,METER NO.02	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
589	1303-LB04-BC09/00	DISPLAY CONTROL,METER NO.09	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
590	1303-LB03-BC16/00	DISPLAY CONTROL,METER NO.16	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
591	1303-LB03-BC17/00	DISPLAY CONTROL,METER NO.17	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
592	1303-LB03-STR02/00	STRAINER,METER NO.02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
593	1303-LB04-STR09/00	STRAINER,METER NO.09	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
594	1303-LB03-STR16/00	STRAINER,METER NO.16	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
595	1303-LB03-STR17/00	STRAINER,METER NO.17	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
596	1303-LB03-AS02/00	AIR ELIMINATOR,METER NO.02	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
597	1303-LB04-AS09/00	AIR ELIMINATOR,METER NO.09	No spare have issue	Combustible	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
598	1303-LB03-AS16/00	AIR ELIMINATOR,METER NO.16	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
599	1303-LB03-AS17/00	AIR ELIMINATOR,METER NO.17	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
600	1303-LB03-FM03/00	FLOW METER / BULK METER NO.03	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
601	1303-LB04-FM05/00	FLOW METER / BULK METER NO.05	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
602	1303-LB04-FM06/00	FLOW METER / BULK METER NO.06	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
603	1303-LB03-FM11/00	FLOW METER / BULK METER NO.11	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
604	1303-LB03-DCV03/00	CONTROL VALVE METER NO.03	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
605	1303-LB04-DCV05/00	CONTROL VALVE METER NO.05	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
606	1303-LB04-DCV06/00	CONTROL VALVE METER NO.06	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
607	1303-LB03-DCV11/00	CONTROL VALVE METER NO.11	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
608	1303-LB03-BC03/00	DISPLAY CONTROL,METER NO.03	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
609	1303-LB04-BC05/00	DISPLAY CONTROL,METER NO.05	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
610	1303-LB04-BC06/00	DISPLAY CONTROL,METER NO.06	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
611	1303-LB03-BC11/00	DISPLAY CONTROL,METER NO.11	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
612	1303-LB03-STR03/00	STRAINER,METER NO.03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
613	1303-LB04-STR05/00	STRAINER,METER NO.05	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
614	1303-LB04-STR06/00	STRAINER,METER NO.06	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
615	1303-LB03-STR11/00	STRAINER,METER NO.11	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
616	1303-LB03-AS03/00	AIR ELIMINATOR,METER NO.03	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
617	1303-LB04-AS05/00	AIR ELIMINATOR,METER NO.05	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
618	1303-LB04-AS06/00	AIR ELIMINATOR,METER NO.06	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
619	1303-LB03-AS11/00	AIR ELIMINATOR,METER NO.11	No spare have issue	Combustible	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
620	1303-LB05-FM01/00	FLOW METER / BULK METER NO.01	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
621	1303-LB05-FM04/00	FLOW METER / BULK METER NO.04	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
622	1303-LB05-FM10/00	FLOW METER / BULK METER NO.10	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
623	1303-LB05-DCV01/00	CONTROL VALVE METER NO.01	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
624	1303-LB05-DCV04/00	CONTROL VALVE METER NO.04	No spare have issue	Flameable	kompleksitas kecil	Almost	insignificant	0%<LP<10%	Cost<USD1000	H	Vital	V
625	1303-LB05-DCV10/00	CONTROL VALVE METER NO.10	No spare have issue	Combustible	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
626	1303-LB05-BC01/00	DISPLAY CONTROL,METER NO.01	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
627	1303-LB05-BC04/00	DISPLAY CONTROL,METER NO.04	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
628	1303-LB05-BC10/00	DISPLAY CONTROL,METER NO.10	No spare have issue	N/A1	kompleksitas kecil	Likely	moderate	0%<LP<10%	Cost<USD1000	H	Vital	V
629	1303-LB05-STR01/00	STRAINER,METER NO.01	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
630	1303-LB05-STR04/00	STRAINER,METER NO.04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
631	1303-LB05-STR10/00	STRAINER,METER NO.10	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
632	1303-LB05-AS01/00	AIR ELIMINATOR,METER NO.01	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
633	1303-LB05-AS04/00	AIR ELIMINATOR,METER NO.04	No spare have issue	N/A1	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
634	1303-LB05-AS10/00	AIR ELIMINATOR,METER NO.10	No spare have issue	Combustible	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
635	1303-FSU-PP01/00	PIPING HEADER,FILLING HOUSE PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
636	1303-FSU-PP02/00	PIPING HEADER,FILLING HOUSE PERTAMAX	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
637	1303-FSU-PP03/00	PIPING HEADER,FILLING HOUSE BIOSOLAR	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
638	1303-FSU-PP04/00	PIPING HEADER,FILLING HOUSE PERTADEX	No spare have issue	Combustible	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
639	1303-FSU-GV01/00	GATE VALVE HEADER FILLING HOUSE PRODUK 1	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
640	1303-FSU-GV02/00	GATE VALVE HEADER FILLING HOUSE PRODUK 2	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
641	1303-FSU-GV03/00	GATE VALVE HEADER FILLING HOUSE PRODUK 3	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
642	1303-FSU-GV04/00	GATE VALVE HEADER FILLING HOUSE PRODUK 4	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
643	1303-FM01-PP01/00	PIPING FLOW METER,METER NO.01	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
644	1303-FM02-PP01/00	PIPING FLOW METER,METER NO.02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
645	1303-FM03-PP01/00	PIPING FLOW METER,METER NO.03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
646	1303-FM04-PP01/00	PIPING FLOW METER,METER NO.04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
647	1303-FM05-PP01/00	PIPING FLOW METER,METER NO.05	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
648	1303-FM06-PP01/00	PIPING FLOW METER,METER NO.06	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
649	1303-FM07-PP01/00	PIPING FLOW METER,METER NO.07	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
650	1303-FM08-PP01/00	PIPING FLOW METER,METER NO.08	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
651	1303-FM09-PP01/00	PIPING FLOW METER,METER NO.09	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
652	1303-FM10-PP01/00	PIPING FLOW METER,METER NO.10	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
653	1303-FM11-PP01/00	PIPING FLOW METER,METER NO.11	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
654	1303-FM12-PP01/00	PIPING FLOW METER,METER NO.12	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
655	1303-FM13-PP01/00	PIPING FLOW METER,METER NO.13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
656	1303-FM14-PP01/00	PIPING FLOW METER,METER NO.14	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
657	1303-FM15-PP01/00	PIPING FLOW METER,METER NO.15	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
658	1303-FM16-PP01/00	PIPING FLOW METER,METER NO.16	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
659	1303-FM17-PP01/00	PIPING FLOW METER,METER NO.17	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
660	1303-FM18-PP01/00	PIPING FLOW METER,METER NO.18	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
661	1303-FM01-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.01	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
662	1303-FM01-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.01	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
663	1303-FM02-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
664	1303-FM02-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
665	1303-FM03-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
666	1303-FM03-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
667	1303-FM04-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
668	1303-FM04-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
669	1303-FM05-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.05	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
670	1303-FM05-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.05	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
671	1303-FM06-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.06	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
672	1303-FM06-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.06	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
673	1303-FM07-GV03/00	GATE VALVE INLET FLOW METER NO.07	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
674	1303-FM07-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.07	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
675	1303-FM07-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.07	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
676	1303-FM08-GV03/00	GATE VALVE INLET FLOW METER NO.08	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
677	1303-FM08-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.08	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
678	1303-FM08-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.08	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
679	1303-FM09-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.09	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
680	1303-FM09-GV02/00	GATE VALVE INLET PROD 3 FLOW METER NO.09	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
681	1303-FM10-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.10	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
682	1303-FM10-GV02/00	GATE VALVE INLET PROD 3 FLOW METER NO.10	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
683	1303-FM11-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.11	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
684	1303-FM11-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.11	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
685	1303-FM11-GV03/00	GATE VALVE INLET PROD 3 FLOW METER NO.11	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
686	1303-FM12-GV01/00	GATE VALVE INLET PROD 3 NO.1 FM NO.12	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
687	1303-FM12-GV02/00	GATE VALVE INLET PROD 4 NO.1 FM NO.12	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
688	1303-FM12-BV01/00	BALL VALVE INLET MIX P3&P4 NO1 FM NO.12	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
689	1303-FM12-BV02/00	BALL VALVE INLET PROD 3 NO.2 FM NO.12	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
690	1303-FM13-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
691	1303-FM13-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
692	1303-FM14-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.14	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
693	1303-FM14-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.14	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
694	1303-FM15-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.15	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
695	1303-FM15-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.15	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
696	1303-FM15-GV03/00	GATE VALVE INLET PROD 3 FLOW METER NO.15	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
697	1303-FM16-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.16	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
698	1303-FM16-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.16	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
699	1303-FM17-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.17	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
700	1303-FM17-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.17	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
701	1303-FM18-GV01/00	GATE VALVE INLET PROD 1 FLOW METER NO.18	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
702	1303-FM18-GV02/00	GATE VALVE INLET PROD 2 FLOW METER NO.18	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
703	1303-FM01-GV03/00	GATE VALVE OUTLET FLOW METER NO.01	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
704	1303-FM02-GV03/00	GATE VALVE OUTLET FLOW METER NO.02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
705	1303-FM03-GV03/00	GATE VALVE OUTLET FLOW METER NO.03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
706	1303-FM04-GV03/00	GATE VALVE OUTLET FLOW METER NO.04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
707	1303-FM05-GV03/00	GATE VALVE OUTLET FLOW METER NO.05	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
708	1303-FM06-GV03/00	GATE VALVE OUTLET FLOW METER NO.06	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
709	1303-FM07-GV04/00	GATE VALVE OUTLET FLOW METER NO.07	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
710	1303-FM08-GV04/00	GATE VALVE OUTLET FLOW METER NO.08	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
711	1303-FM09-GV03/00	GATE VALVE OUTLET FLOW METER NO.09	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
712	1303-FM10-GV03/00	GATE VALVE OUTLET FLOW METER NO.10	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
713	1303-FM11-GV04/00	GATE VALVE OUTLET FLOW METER NO.11	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
714	1303-FM12-GV03/00	GATE VALVE OUTLET FLOW METER NO.12	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
715	1303-FM13-GV03/00	GATE VALVE OUTLET FLOW METER NO.13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
716	1303-FM14-GV03/00	GATE VALVE OUTLET FLOW METER NO.14	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
717	1303-FM15-GV04/00	GATE VALVE OUTLET FLOW METER NO.15	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
718	1303-FM16-GV03/00	GATE VALVE OUTLET FLOW METER NO.16	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
719	1303-FM17-GV03/00	GATE VALVE OUTLET FLOW METER NO.17	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
720	1303-FM18-GV03/00	GATE VALVE OUTLET FLOW METER NO.18	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
721	1303-LB01-BL07/00	BOTTOM LOADING ARM NO.07	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
722	1303-BL07-SWL07/00	SWIVEL JOINT,LOADING ARM,NO.07	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
723	1303-BL07-FL07/00	FLEXIBLE JOINT,LOADING ARM,NO.07	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
724	1303-LB01-BL12/00	BOTTOM LOADING ARM NO.12	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
725	1303-BL12-SWL12/00	SWIVEL JOINT,LOADING ARM,NO.12	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
726	1303-BL12-FL12/00	FLEXIBLE JOINT,LOADING ARM,NO.12	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
727	1303-LB01-BL14/00	BOTTOM LOADING ARM NO.14	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
728	1303-BL14-SWL14/00	SWIVEL JOINT,LOADING ARM,NO.14	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
729	1303-BL14-FL14/00	FLEXIBLE JOINT,LOADING ARM,NO.14	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
730	1303-LB01-BL15/00	BOTTOM LOADING ARM NO.15	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
731	1303-BL15-SWL15/00	SWIVEL JOINT,LOADING ARM,NO.15	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
732	1303-BL15-FL15/00	FLEXIBLE JOINT,LOADING ARM,NO.15	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
733	1303-LB02-BL08/00	BOTTOM LOADING ARM NO.08	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
734	1303-BL08-SWL08/00	SWIVEL JOINT,LOADING ARM,NO.08	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
735	1303-BL08-FL08/00	FLEXIBLE JOINT,LOADING ARM,NO.08	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
736	1303-LB02-BL13/00	BOTTOM LOADING ARM NO.13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
737	1303-BL13-SWL13/00	SWIVEL JOINT,LOADING ARM,NO.13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
738	1303-BL13-FL13/00	FLEXIBLE JOINT,LOADING ARM,NO.13	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
739	1303-LB02-BL18/00	BOTTOM LOADING ARM NO.18	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
740	1303-BL18-SWL18/00	SWIVEL JOINT,LOADING ARM,NO.18	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
741	1303-BL18-FL18/00	FLEXIBLE JOINT,LOADING ARM,NO.18	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
742	1303-LB03-BL02/00	BOTTOM LOADING ARM NO.02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
743	1303-BL02-SWL02/00	SWIVEL JOINT,LOADING ARM,NO.02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
744	1303-BL02-FL02/00	FLEXIBLE JOINT,LOADING ARM,NO.02	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
745	1303-LB04-BL09/00	BOTTOM LOADING ARM NO.09	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
746	1303-BL09-SWL09/00	SWIVEL JOINT,LOADING ARM,NO.09	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
747	1303-BL09-FL09/00	FLEXIBLE JOINT,LOADING ARM,NO.09	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
748	1303-LB03-BL16/00	BOTTOM LOADING ARM NO.16	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
749	1303-BL16-SWL16/00	SWIVEL JOINT,LOADING ARM,NO.16	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
750	1303-BL16-FL16/00	FLEXIBLE JOINT,LOADING ARM,NO.16	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
751	1303-LB03-BL17/00	BOTTOM LOADING ARM NO.17	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
752	1303-BL16-SWL17/00	SWIVEL JOINT,LOADING ARM,NO.17	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
753	1303-BL16-FL17/00	FLEXIBLE JOINT,LOADING ARM,NO.17	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
754	1303-LB03-BL03/00	BOTTOM LOADING ARM NO.03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
755	1303-BL03-SWL03/00	SWIVEL JOINT,LOADING ARM,NO.03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
756	1303-BL03-FL03/00	FLEXIBLE JOINT,LOADING ARM,NO.03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
757	1303-LB04-BL05/00	BOTTOM LOADING ARM NO.05	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
758	1303-BL05-SWL05/00	SWIVEL JOINT,LOADING ARM,NO.05	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
759	1303-BL05-FL05/00	FLEXIBLE JOINT,LOADING ARM,NO.05	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
760	1303-LB04-BL06/00	BOTTOM LOADING ARM NO.06	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
761	1303-BL06-SWL06/00	SWIVEL JOINT,LOADING ARM,NO.06	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
762	1303-BL06-FL06/00	FLEXIBLE JOINT,LOADING ARM,NO.06	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
763	1303-LB03-BL11/00	BOTTOM LOADING ARM NO.11	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
764	1303-BL11-SWL11/00	SWIVEL JOINT,LOADING ARM,NO.11	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
765	1303-BL11-FL11/00	FLEXIBLE JOINT,LOADING ARM,NO.11	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
766	1303-LB05-BL01/00	BOTTOM LOADING ARM NO.01	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
767	1303-BL01-SWL01/00	SWIVEL JOINT,LOADING ARM,NO.01	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
768	1303-BL01-FL01/00	FLEXIBLE JOINT,LOADING ARM,NO.01	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
769	1303-LB05-BL04/00	BOTTOM LOADING ARM NO.04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
770	1303-BL04-SWL04/00	SWIVEL JOINT,LOADING ARM,NO.04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
771	1303-BL04-FL04/00	FLEXIBLE JOINT,LOADING ARM,NO.04	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
772	1303-LB05-BL10/00	BOTTOM LOADING ARM NO.10	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
773	1303-BL10-SWL10/00	SWIVEL JOINT,LOADING ARM,NO.10	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
774	1303-BL10-FL10/00	FLEXIBLE JOINT,LOADING ARM,NO.10	No spare have issue	Combustible	sederhana	Likely	minor	0%<LP<10%	Cost<USD1000	M	Important	T
775	1303-FP01-GV01/00	GATE VALVE INLET FIRE PUMP NO.01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
776	1303-FP01-GV02/00	GATE VALVE OUTLET FIRE PUMP NO.01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
777	1303-FP01-CV01/00	CHECK VLAVE FIRE PUMP NO.01	No spare have issue	Non Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
778	1303-FP01-PG01/00	VACUUM GAUGE,FIRE PUMP NO.01	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
779	1303-FP01-PG02/00	PRESSURE GAUGE,FIRE PUMP NO.01	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
780	1303-FP01-GND01/00	GROUNDING FIRE PUMP NO.01	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
781	1303-FP02-GV01/00	GATE VALVE INLET FIRE PUMP NO.02	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
782	1303-FP02-GV02/00	GATE VALVE OUTLET FIRE PUMP NO.02	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
783	1303-FP02-STR01/00	STRAINER,FIRE PUMP NO.02	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
784	1303-FP02-CV01/00	CHECK VLAVE FIRE PUMP NO.02	No spare have issue	Non Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
785	1303-FP02-PG01/00	VACUUM GAUGE,FIRE PUMP NO.02	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
786	1303-FP02-PG02/00	PRESSURE GAUGE,FIRE PUMP NO.02	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
787	1303-FP02-GND01/00	GROUNDING FIRE PUMP NO.02	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
788	1303-JP01-GV01/00	GATE VALVE INLET JOCKEY PUMP	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
789	1303-JP01-GV02/00	GATE VALVE OUTLET JOCKEY PUMP	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
790	1303-JP01-CV01/00	CHECK VLAVE JOCKEY PUMP	No spare have issue	Non Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
791	1303-JP01-PG02/00	PRESS GAUGE DISCHARGE JOCKEY PUMP	No Spare no issue	N/A2	sederhana	Moderate	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
792	1303-JP01-GND01/00	GROUNDING JOCKEY PUMP	No spare have issue	N/A1	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
793	1303-PFW-GV06/00	GATE VALVE FW TO WATER POND NO.03	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
794	1303-PFW-GV01/00	GATE VALVE HEADER TO FIRE PUMP	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
795	1303-PFW-GV02/00	GATE VALVE WATER POND NO.01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
796	1303-HYS-APAB01/00	SHELTER APAB NO.01	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
797	1303-HYS-APAB02/00	SHELTER APAB NO.02	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
798	1303-HYS-APAB03/00	SHELTER APAB NO.03	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
799	1303-HYS-APAB04/00	SHELTER APAB NO.04	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
800	1303-HYS-APAB05/00	SHELTER APAB NO.05	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
801	1303-HYS-APAB06/00	SHELTER APAB NO.06	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
802	1303-HYS-APAB07/00	SHELTER APAB NO.07	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
803	1303-HYS-APAB08/00	SHELTER APAB NO.08	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
804	1303-HYS-APAB09/00	SHELTER APAB NO.09	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
805	1303-HYS-APAB10/00	SHELTER APAB NO.10	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
806	1303-HYS-APAB11/00	SHELTER APAB NO.11	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
807	1303-HYS-APAB12/00	SHELTER APAB NO.12	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
808	1303-HYS-APAB13/00	SHELTER APAB NO.13	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
809	1303-HYS-APAB14/00	SHELTER APAB FILLINGSHED NO.1	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
810	1303-HYS-APAR01/00	BOX APAR NO.01	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
811	1303-HYS-APAR02/00	BOX APAR NO.02	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
812	1303-HYS-APAR03/00	BOX APAR NO.03	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
813	1303-HYS-APAR04/00	BOX APAR NO.04	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
814	1303-HYS-APAR05/00	BOX APAR NO.05	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
815	1303-HYS-APAR06/00	BOX APAR NO.06	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
816	1303-HYS-APAR07/00	BOX APAR NO.07	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
817	1303-HYS-APAR08/00	BOX APAR NO.08	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
818	1303-HYS-APAR09/00	BOX APAR NO.09	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
819	1303-HYS-APAR10/00	BOX APAR NO.10	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
820	1303-HYS-APAR11/00	BOX APAR NO.11	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
821	1303-HYS-APAR12/00	BOX APAR NO.12	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
822	1303-HYS-APAR13/00	BOX APAR NO.13	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
823	1303-HYS-APAR14/00	BOX APAR NO.14	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
824	1303-HYS-APAR15/00	BOX APAR NO.15	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
825	1303-HYS-APAR16/00	BOX APAR NO.16	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
826	1303-HYS-APAR17/00	BOX APAR NO.17	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
827	1303-HYS-APAR18/00	BOX APAR NO.18	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
828	1303-HYS-APAR19/00	BOX APAR NO.19	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
829	1303-HYS-APAR20/00	BOX APAR NO.20	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
830	1303-HYS-APAR21/00	BOX APAR NO.21	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
831	1303-HYS-APAR22/00	BOX APAR NO.22	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
832	1303-HYS-APAR23/00	BOX APAR NO.23	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
833	1303-HYS-APAR24/00	BOX APAR NO.24	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
834	1303-HYS-APAR25/00	BOX APAR NO.25	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
835	1303-HYS-APAR26/00	BOX APAR NO.26	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
836	1303-JP01-PF01/00	PIPING INLET JOCKEY PUMP	No spare have issue	Non Combustible	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
837	1303-JP01-PF02/00	PIPING OUTLET JOCKEY PUMP	No spare have issue	Non Combustible	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
838	1303-PFW-GV03/00	GATE VALVE WATER POND NO.02	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
839	1303-PFW-GV04/00	GATE VALVE FIRE WATER TO WATER POND 01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
840	1303-PFW-GV05/00	GATE VALVE FW TO WATER POND NO.01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
841	1303-PFW-PF06/00	PIPING WATER POND NO.03	No spare have issue	Non Combustible	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
842	1303-PFW-GV07/00	GATE VALVE WATER POND NO.03	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
843	1303-PFW-GV08/00	GATE VALVE FIRE WATER WALL NO.01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
844	1303-PFW-GV09/00	GATE VALVE FIRE WATER WALL NO.02	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
845	1303-FOS-GV01/00	GATE VALVE SUCTION FOAM PUMP NO.01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
846	1303-FOS-GV02/00	GATE VALVE DISCHARGE FOAM PUMP NO.01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
847	1303-FOS-FOM01/00	PORTABLE FOAM MONITOR NO.01	No Spare no issue	Non Combustible	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
848	1303-FOS-FOM02/00	PORTABLE FOAM MONITOR NO.02	No Spare no issue	Non Combustible	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
849	1303-PWR-PNL01/00	PANEL INCOMING PLN	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
850	1303-DEG-DE01/00	GENERATOR ENGINE NO.01	No spare have issue	N/A1	kompleksitas sedang	Likely	moderate	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
851	1303-DEG-G01/00	GENERATOR NO.01	No spare have issue	N/A1	kompleksitas sedang	Likely	moderate	0%<LP<10%	USD1000<Cost<USD10000	H	Vital	V
852	1303-DEG-T01/00	FUEL TANK,GENERATOR NO.01	No spare have issue	Combustible	kompleksitas kecil	Likely	minor	LP=0%	USD1000<Cost<USD10000	M	Important	T
853	1303-SWG-SWG01/00	SWITCHGEAR NO.01	No spare have issue	N/A2	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
854	1303-SWG-MCC08/00	PANEL MCC/LVMDP	No spare have issue	N/A2	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
855	1303-SWG-MCC06/00	PANEL POMPA PRODUK NO.06	No spare have issue	N/A2	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
856	1303-SWG-MCC07/00	PANEL POMPA PRODUK NO.07	No spare have issue	N/A2	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
857	1303-WB3-SDB01/00	BAK DRYING BED NO.01	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
858	1303-WB3-SDB02/00	BAK DRYING BED NO.02	No spare have issue	Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
859	1303-OC-OC01/00	OIL CATCHER NO.01	No spare have issue	Combustible	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
860	1303-OC01-GV01/00	GATE VALVE OIL CATCHER NO.1	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
861	1303-OC-OC02/00	OIL CATCHER NO.02	No spare have issue	Combustible	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
862	1303-OC02-GV01/00	GATE VALVE OIL CATCHER NO.2	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
863	1303-OC-OC03/00	OIL CATCHER NO.03	No spare have issue	Combustible	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
864	1303-OC03-GV01/00	GATE VALVE OIL CATCHER NO.3	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
865	1303-OC-OC04/00	OIL CATCHER NO.04	No spare have issue	Combustible	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
866	1303-OC04-GV01/00	GATE VALVE OIL CATCHER NO.4	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
867	1303-OC-OC05/00	OIL CATCHER NO.05	No spare have issue	Combustible	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
868	1303-OC05-GV01/00	GATE VALVE OIL CATCHER NO.5	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
869	1303-OC-OC06/00	OIL CATCHER NO.06	No spare have issue	Combustible	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
870	1303-OC06-GV01/00	GATE VALVE OIL CATCHER NO.6	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
871	1303-MBL-FLT01/00	FORKLIFT	No Spare no issue	N/A2	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
872	1303-MBL-PFP01/00	PORTABLE,FIRE PUMP,NO.01	No spare have issue	Non Combustible	sederhana	Likely	insignificant	LP=0%	USD1000<Cost<USD10000	M	Important	T
873	1303-PFP01-DE01/00	PORTABLE,ENGINE PUMP NO.01	No spare have issue	N/A1	sederhana	Likely	insignificant	LP=0%	USD1000<Cost<USD10000	M	Important	T
874	1303-LAB-DST01/00	DISTILASI ANALYZER NO.01	No Spare no issue	N/A2	sederhana	Moderate	significant	LP=0%	Cost<USD1000	H	Vital	V
875	1303-LAB-DST02/00	DISTILASI ANALYZER NO.02	No Spare no issue	N/A2	sederhana	Moderate	minor	LP=0%	Cost<USD1000	M	Important	T
876	1303-LAB-FPT01/00	FLASH POINT TESTER NO.01	No Spare no issue	N/A2	sederhana	Moderate	significant	LP=0%	Cost<USD1000	H	Vital	V
877	1303-LAB-FPT02/00	FLASH POINT TESTER NO.02	No Spare no issue	N/A2	sederhana	Moderate	minor	LP=0%	Cost<USD1000	M	Important	T
878	1303-LAB-WA01/00	WATER CONTENT ANALYZER NO.01	No Spare no issue	N/A2	sederhana	Moderate	significant	LP=0%	Cost<USD1000	H	Vital	V
879	1303-LAB-SA01/00	SULFUR CONTENT ANALYZER NO.01	No Spare no issue	N/A2	sederhana	Moderate	significant	LP=0%	Cost<USD1000	H	Vital	V
880	1303-LAB-EW01/00	EYEWASH LABORATORY NO.01	No Spare no issue	N/A2	sederhana	Moderate	minor	LP=0%	Cost<USD1000	M	Important	T
881	1303-HYS-APAR27/00	BOX APAR OFFICE NO.01	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
882	1303-HYS-APAR28/00	BOX APAR OFFICE NO.02	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
883	1303-HYS-APAR29/00	BOX APAR OFFICE NO.03	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
884	1303-HYS-APAR30/00	BOX APAR OFFICE NO.04	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
885	1303-HYS-APAR31/00	BOX APAR OFFICE NO.05	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
886	1303-HYS-APAR32/00	BOX APAR OFFICE NO.06	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
887	1303-HYS-APAR33/00	BOX APAR OFFICE NO.07	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
888	1303-HYS-APAR34/00	BOX APAR OFFICE NO.08	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
889	1303-HYS-APAR35/00	BOX APAR OFFICE NO.09	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
890	1303-HYS-APAR36/00	BOX APAR OFFICE NO.10	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
891	1303-FSU-Pf05/00	PIPING INLET WATER SPRAY FILLING BAY	No spare have issue	Non Combustible	sederhana	Likely	insignificant	0%<LP<10%	Cost<USD1000	M	Important	T
892	1303-FSU-GV05/00	GATE VALVE WATER SPRAY FILLING BAY	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
893	1303-FSU-STR01/00	STRAINER,WATER SPRAY,FILLING BAY	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
894	1303-FSU-WS01/00	WATER SPRAY FILLING BAY 01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
895	1303-FSU-WS02/00	WATER SPRAY FILLING BAY 02	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
896	1303-FSU-WS03/00	WATER SPRAY FILLING BAY 03	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
897	1303-FSU-WS04/00	WATER SPRAY FILLING BAY 04	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
898	1303-FSU-WS05/00	WATER SPRAY FILLING BAY 05	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
899	1303-TFA-GV01/00	GATE VALVE CONNECT T-10 AND T-05	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
900	1303-TFA-GV02/00	GATE VALVE CONNECT T-02 AND T-06	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
901	1303-TFA-GV03/00	GATE VALVE CONNECT T08 AND PIPE PERTAMAX	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
902	1303-TFA-GV04/00	GATE VALVE CONNECT PIPE BIOSOLAR AND T06	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
903	1303-TFA-GV05/00	GATE VALVE CONNECT T03 AND PIPE PERTAMAX	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
904	1303-TFA-GV06/00	GATE VALVE CONNECT T4 AND PIPE PERTALITE	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
905	1303-TFA-GV07/00	GATE VALVE CONNECT T03 AND T04 PERTALITE	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
906	1303-TFA-GV08/00	GATE VALVE CONNECT T04 AND PIPE BIOSOLAR	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
907	1303-TFA-GV09/00	GATE VALVE CONNECT T03 AND T04 BI0S0LAR	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
908	1303-TFA-GV10/00	GATE VALVE CONNECT PIPE PERTAMAX TO T03	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
909	1303-T02-STR01/00	STRAINER FIRE WATER TANK T-02	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
910	1303-T04-STR01/00	STRAINER FIRE WATER TANK T-04	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
911	1303-T08-STR01/00	STRAINER FIRE WATER TANK T-08	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
912	1303-T10-STR01/00	STRAINER FIRE WATER TANK T-10	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
913	1303-T03-STR01/00	STRAINER FOAM SYSTEM TANK T-03	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
914	1303-T05-STR01/00	STRAINER FOAM SYSTEM TANK T-05	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
915	1303-T06-STR01/00	STRAINER FOAM SYSTEM TANK T-06	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
916	1303-T07-STR01/00	STRAINER FOAM SYSTEM TANK T-07	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
917	1303-T10-STR02/00	STRAINER FOAM SYSTEM TANK T-10	No spare have issue	N/A1	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
918	1303-PFW-GV10/00	GATE VALVE HEADER FIRE WATER TO T-01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
919	1303-PFW-GV11/00	GATE VALVE HEADER FIRE WATER TO T-02	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
920	1303-PFW-GV12/00	GATE VALVE HEADER FIRE WATER TO T-03	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
921	1303-PFW-GV13/00	GATE VALVE HEADER FIRE WATER TO T-04	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
922	1303-PFW-GV14/00	GATE VALVE HEADER FIRE WATER TO T-05	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
923	1303-PFW-GV15/00	GATE VALVE HEADER FIRE WATER TO T-06	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
924	1303-PFW-GV16/00	GATE VALVE HEADER FIRE WATER TO T-07	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
925	1303-PFW-GV17/00	GATE VALVE HEADER FIRE WATER TO T-08	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
926	1303-PFW-GV18/00	GATE VALVE HEADER FIRE WATER TO T-09	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
927	1303-PFW-GV19/00	GATE VALVE HEADER FIRE WATER TO T-10	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
928	1303-PFW-GV20/00	GATE VALVE HEADER FIRE WATER SPARE	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
929	1303-PFW-GV21/00	GATE VALVE HEADER FIRE WATER SPARE	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
930	1303-PFW-GV22/00	GATE VALVE HEADER FIRE WATER SPARE	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
931	1303-PFW-GV23/00	GATE VALVE HEADER FIRE WATER SPARE	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
932	1303-T01-DH01/00	DIP HATCH TANK T-01	No Spare no issue	N/A1	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
933	1303-T08-DH01/00	DIP HATCH TANK T-08	No Spare no issue	N/A1	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y

			KARAKTERISTIK KEKRITISAN				DAMPAK KEKRITISAN					
Sr.	Tag No	Equipment Description	Duty	Produk	Pemeliharaan	Likelihood	H&S Impact	Produksi	Finance	Risk Criticality	PCE	CRITICALITY
934	1303-T10-DH01/00	DIP HATCH TANK T-10	No Spare no issue	N/A1	kompleksitas kecil	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
935	1303-RF1-PP02/00	PIPING RECEIVING FUEL PERTALITE	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
936	1303-PSU-PP05/00	PIPING PERTALITE TO PUMP P-12	No spare have issue	Flameable	sederhana	Almost	minor	LP=0%	Cost<USD1000	H	Vital	V
937	1303-PSU-PP06/00	PIPING PERTAMAX PUMP SYSTEM	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
938	1303-TFA-PP09/00	PIPING PERTAMAX TANK FARM AREA	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
939	1303-TFA-PP10/00	PIPING PERTAMAX TANK FARM AREA	No spare have issue	Flameable	sederhana	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
940	1303-TFA-PP11/00	PIPING BIOSOLAR TANK FARM AREA	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
941	1303-TFA-PP12/00	PIPING BIOSOLAR TANK FARM AREA	No spare have issue	Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
942	1303-PWR-TRF01/00	TRANSFORMATOR 01	No spare-stop	N/A1	kompleksitas sedang	Almost	insignificant	LP=0%	Cost<USD1000	M	Important	T
943	1303-SWG-ATS01/00	AUTOMATIC TRANFER SWITCH	No spare have issue	N/A2	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
944	1303-FNG-BEA01/00	SOUNDER BEACON 01 POS SECURITY/GATE	No spare have issue	N/A2	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
945	1303-FNG-BEA02/00	SOUNDER BEACON 02 PUMP STATION	No spare have issue	N/A2	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
946	1303-FNG-SIR01/00	SIRINE AREA REAR TANK T-05	No spare have issue	N/A2	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
947	1303-FNG-SIR02/00	SIRINE AREA SCRAB	No spare have issue	N/A2	sederhana	Likely	moderate	LP=0%	Cost<USD1000	H	Vital	V
948	1303-HYS-GV01/00	GATE VALVE FFM FIRE WATER,TF NO.1	No spare have issue	Non Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
949	1303-HYS-GV02/00	GATE VALVE FFM FIRE WATER,TF NO.2	No spare have issue	Non Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
950	1303-HYS-GV03/00	GATE VALVE FFM FIRE WATER,TF NO.3	No spare have issue	Non Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
951	1303-HYS-GV04/00	GATE VALVE FFM FIRE WATER,TF NO.4	No spare have issue	Non Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
952	1303-HYS-GV05/00	GATE VALVE FFM FIRE WATER,TF NO.5	No spare have issue	Non Combustible	sederhana	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
953	1303-HYS-APAR37/00	BOX APAR RUMAH DINAS NO.01	No Spare no issue	Non Combustible	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
954	1303-PFW-BV01/00	BALL VALVE WATER POND 01	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
955	1303-PFW-BV02/00	BALL VALVE WATER POND 02	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
956	1303-PFW-PG01/00	PRESSURE GAUGE FIRE WATER	No Spare no issue	N/A2	sederhana	Moderate	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
957	1303-PFW-FM01/00	FLOW METER WATER POND 01	No spare have issue	Non Combustible	kompleksitas kecil	Likely	insignificant	LP=0%	Cost<USD1000	L	Secondary Equipment	Y
958	1303-PFW-GV24/00	GATE VALVE FIRE WATER BLIND END HYDRANT	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
959	1303-PFW-GV25/00	GATE VALVE FIRE WATER BLIND FLANGE	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
960	1303-PFW-GV26/00	GATE VALVE FIRE WATER TO RING SYSTEM	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
961	1303-PFW-GV27/00	GATE VALVE FIRE WATER RING SYSTEM	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
962	1303-PFW-GV28/00	GATE VALVE FIRE WATER END LINE HYDRANT	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
963	1303-FP02-GV03/00	GATE VALVE OUTLT FIRE PUMP TO RING SYSTM	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
964	1303-FP01-GV03/00	GATE VALVE OUTLT PRV TO WATER POND 02	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T
965	1303-FP02-SG01/00	SIGHT GLASS OUTLT PRV TO WATER POND 02	No Spare no issue	N/A2	sederhana	Moderate	minor	LP=0%	Cost<USD1000	M	Important	T
966	1303-PFW-CV01/00	CHECK VALVE FIRE WATER BLIND FLANGE	No spare have issue	Non Combustible	sederhana	Likely	minor	LP=0%	Cost<USD1000	M	Important	T

DISETUJUI
FUEL TERMINAL MALANG

(.....)

PT PERTAMINA TRAINING & CONSULTING

(Hasudungan Siahaan)