



STANDPIPE AND HOSE SYSTEMS INSPECTION, TESTING, AND MAINTENANCE

Name of Property:

Inspector:

Address:

Contract No.:

Property Phone Number:

Date:

Inspection Frequency: Daily Weekly Monthly Quarterly Annual
Five-Year

Inspections: Daily

Yes No N/A

Dry/Deluge Valve (Cold Weather/Heating Season Only)

Enclosure, not equipped with a low temperature alarm, is inspected during cold weather to verify a minimum temperature of 40°F (4°C)

Inspection: Weekly

Yes No N/A

Backflow

Isolation valves — open position and locked or supervised

Yes No N/A

RPA and RPDA — differential-sensing relief valve operating correctly

Control Valves

Yes No N/A

In the correct (open or closed) position

Yes No N/A

Sealed

Yes No N/A

Accessible

Yes No N/A

Post Indicator Valves (PIVs) are provided with correct wrenches

Yes No N/A

Free from damage or leaks

Yes No N/A

Proper signage

Dry/Deluge Valve

Yes No N/A

Enclosure, where equipped with low temperature alarm, is inspected during cold weather to verify a minimum temperature of 40°F (4°C)

Master Pressure-Regulating Device

Yes No N/A

Downstream pressures are in accordance with design criteria psi

Yes No N/A

Supply pressure is in accordance with design criteria psi

Yes No N/A

Free of damage or leaks

Yes No N/A

Trim in good operating condition

Inspections: Monthly

Yes No N/A

Gauges are operable and not physically damaged

Yes No N/A

Gauges — normal air or nitrogen pressure maintained (not supervised)

Yes No N/A

Gauge on system side of dry valve reads proper ratio of air or nitrogen (not supervised) psi

Yes No N/A

Gauge on quick-opening device reads the same as system side dry valve gauge (not supervised) psi

STANDPIPE AND HOSE SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Inspections: Monthly

Control Valves (Locked or Supervised)

Yes	No	N/A	In the correct (open or closed) position
Yes	No	N/A	Locked or supervised
Yes	No	N/A	Accessible
Yes	No	N/A	Post Indicator Valves (PIVs) are provided with correct wrenches
Yes	No	N/A	Free from damage or leaks
Yes	No	N/A	Proper signage

Dry Pipe Valve (Automatic Dry Systems)

Yes	No	N/A	Exterior is free of damage
Yes	No	N/A	Trim valves are in correct (open or closed) position
Yes	No	N/A	Intermediate chamber is not leaking

Deluge Valve (Semiautomatic Dry System)

Yes	No	N/A	Free from physical damage or leaks
Yes	No	N/A	Electrical components are in service
Yes	No	N/A	Trim valves are in the correct (open or closed) position
Yes	No	N/A	Valve seat is not leaking

Inspections: Quarterly

Yes	No	N/A	Waterflow alarm and supervisory devices are free of damage
Yes	No	N/A	Gauges — normal air or nitrogen pressure maintained when supervised at a constantly attended location psi
Yes	No	N/A	Gauge on system side of dry valve reads proper ratio of air or nitrogen when supervised at a constantly attended location psi
Yes	No	N/A	Gauge on quick-opening device reads the same as system side dry valve gauge when supervised at a constantly attended location psi
Yes	No	N/A	Gauge on supply side of valve reads normal psi

Control Valves (Electronically Supervised)

Yes	No	N/A	In the correct (open or closed) position
Yes	No	N/A	Electronically supervised
Yes	No	N/A	Accessible
Yes	No	N/A	Post Indicator Valves (PIVs) are provided with correct wrenches
Yes	No	N/A	Free from damage or leaks
Yes	No	N/A	Proper signage

STANDPIPE AND HOSE SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Inspections: Quarterly

Yes	No	N/A	Caps are in place and not damaged
Yes	No	N/A	Hose threads are not damaged
Yes	No	N/A	Valve handles are present and not damaged
Yes	No	N/A	Gaskets are not damaged or deteriorated
Yes	No	N/A	Valves are not leaking
Yes	No	N/A	Valves are not obstructed
Yes	No	N/A	Valves are capable of normal operation

Fire Department Connections

Yes	No	N/A	Visible and accessible
Yes	No	N/A	Couplings/swivels operate correctly
Yes	No	N/A	Plugs/caps are in place
Yes	No	N/A	Gaskets are not damaged
Yes	No	N/A	Identification signs are in place
Yes	No	N/A	Check valve is not leaking
Yes	No	N/A	Automatic drain valve in place and operating properly
Yes	No	N/A	FDC clapper is functional
Yes	No	N/A	Interior is clear of obstructions (unless locked)
Yes	No	N/A	Visible piping supplying the fire department connection is undamaged

Inspections: Annual

Yes	No	N/A	Dry pipe valve interior inspection following trip test
Yes	No	N/A	Deluge valve interior inspection following trip test
Yes	No	N/A	Hydraulic design information attached securely and legible

Hose Cabinet

Yes	No	N/A	Visible and accessible
Yes	No	N/A	No damaged or corroded components
Yes	No	N/A	Cabinet door is not difficult to open and opens fully
Yes	No	N/A	Glass is not broken
Yes	No	N/A	Glass break device is present and attached
Yes	No	N/A	Cabinet is properly identified
Yes	No	N/A	Lock (in break-glass type) is functional
Yes	No	N/A	Contents are present and accessible

Fire Department Connections

Yes	No	N/A	Interior of connection with locked plugs or caps is free of obstructions
-----	----	-----	--

STANDPIPE AND HOSE SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Inspections: Annual

Nozzle (Inspected per NFPA 1962)

Yes	No	N/A	Hose nozzle is present
Yes	No	N/A	Gasket is not missing or deteriorated
Yes	No	N/A	Nozzle is not obstructed
Yes	No	N/A	Nozzle operates smoothly

Hose (Inspected per NFPA 1962)

Yes	No	N/A	No mildew, cuts, abrasions, and deterioration
Yes	No	N/A	Gaskets are not missing or deteriorated
Yes	No	N/A	Threads on coupling are not incompatible
Yes	No	N/A	Hose connected to hose rack nipple or valve
Yes	No	N/A	Hose test is to date
Yes	No	N/A	Hose has been reracked, rereeled, or rerolled

Hose Storage Device

Yes	No	N/A	Visible and accessible
Yes	No	N/A	Not damaged and operates correctly
Yes	No	N/A	Hose is properly racked or rolled
Yes	No	N/A	Nozzle clip in place and nozzle correctly contained
Yes	No	N/A	If installed in cabinet, will swing out at least 90 degrees

Hose Connections

Yes	No	N/A	Valve cap(s) are not missing or damaged
Yes	No	N/A	Fire hose connection is not damaged
Yes	No	N/A	Valve handles are not missing or damaged
Yes	No	N/A	Cap gaskets are not missing or deteriorated
Yes	No	N/A	Valve is not leaking
Yes	No	N/A	Valve does not have any visible or physical obstruction
Yes	No	N/A	Pressure reducing device is not missing
Yes	No	N/A	Manual, semiautomatic, or dry standpipe valves operate smoothly
Yes	No	N/A	Valve is not damaged

STANDPIPE AND HOSE SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Inspections: Annual

Yes	No	N/A	In good condition with no external corrosion
Yes	No	N/A	No leaks or mechanical damage
Yes	No	N/A	Correct alignment with no external loads
Yes	No	N/A	Control valves are not damaged
Yes	No	N/A	No missing or damaged supporting devices

Pipe and Fittings

Building

Yes	No	N/A	Prior to onset of freezing weather, all openings are closed and water-filled pipe is not exposed to freezing temperatures
Yes	No	N/A	Heat trace is per manufacturer's instructions
Yes	No	N/A	Low temp alarm is free of physical damage

Inspection: Five Year

Yes	No	N/A	Obstruction inspection — no foreign or obstructing material found
Yes	No	N/A	Check valve — internal moves freely and in good condition
Yes	No	N/A	Backflow — internal inspection
Yes	No	N/A	Internal inspection of dry pipe and preaction/deluge valve strainers filters and orifices

Test: Quarterly

Yes	No	N/A	Alarm devices — water motor gong
Yes	No	N/A	Main drain test — if the sole supply is through a backflow preventer or pressure-reducing valve
			Static psi: Residual psi:
Yes	No	N/A	Do results differ by more than 10% from previous test?
Yes	No	N/A	Priming water level tested
Yes	No	N/A	Quick-opening device tested

Master Pressure-Regulating Device

Yes	No	N/A	Partial flow test performed to exercise valve
-----	----	-----	---

Test: Semiannual

Yes	No	N/A	Valve supervisory switch(es) functioning
Yes	No	N/A	Alarm devices (vane and pressure switch type) — inspector's test or bypass opened and observed waterflow



STANDPIPE AND HOSE SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Test: Annual

Yes	No	N/A	Supervisory switch functioning
Yes	No	N/A	Automatic air pressure maintenance device functioning
Yes	No	N/A	Backflow preventer — forward flow test at a minimum flow rate of the system demand
Yes	No	N/A	Valve status test performed
Yes	No	N/A	Low temperature alarm (if installed) at the beginning of heating season
Yes	No	N/A	Low air alarm tested per manufacturer's instructions
Yes	No	N/A	Partial flow test for hose connection and hose rack assembly pressure regulating device
Yes	No	N/A	Hose valves — Class I and Class III — fully open and close valves
Yes	No	N/A	Hose nozzle — per NFPA 1962 (tested at same frequency as the hose it is attached)

Main Drain Test

			Static psi	Residual psi
Yes	No	N/A	Do results differ by more than 10% from previous test?	
Yes	No	N/A	All control valves operated through full range of motion and returned to normal position	

Dry Pipe Valve Trip Test (Partial Flow)

			Water pressure	(psi)	Air pressure	(psi)
			Tripping air pressure	(psi)	Trip time	(sec)
Yes	No	N/A	Results compared to previous test			

Deluge Valve Full Flow Trip Test

			Pressure reading at deluge valve	psi
Yes	No	N/A	Compare if pressure readings to hydraulic design/water supply meets requirements	
Yes	No	N/A	Air maintenance device (if provided) works correctly	

Master Pressure-Regulating Device

Yes	No	N/A	Full flow test performed and compared to previous test
-----	----	-----	--

Tests: Three Years

Yes	No	N/A	Hose hydrostatically tested in accordance with NFPA 1962 (for hose older than 5 years)
Yes	No	N/A	Hose valves — Class II — fully open and close valves

Dry Pipe Valve Full Flow Trip Test

			Water pressure	(psi)	Air pressure	(psi)
			Tripping air pressure	(psi)	Trip time	(sec)
			Water delivery time	(min.)		(sec)
Yes	No	N/A	Results comparable to previous years			
Yes	No	N/A	Dry pipe system tested for leakage			

STANDPIPE AND HOSE SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Test: Five Years

Yes	No	N/A	Gauges tested or replaced
Yes	No	N/A	Hydrostatic test (manual and semiautomatic dry only)
Yes	No	N/A	Flow test (all automatic systems)
			Static pressure (psi)
			Total flow (gpm)
			Pressure at topmost outlet (psi)
Yes	No	N/A	Hose connection pressure-reducing/restricting valves — flow test

Fire Department Connections

Yes	No	N/A	Piping from fire department connection to fire department connection check valve has been hydrostatically tested at 150 psi (10 bar) for at least 2 hours
-----	----	-----	---

Routine Maintenance

Yes	No	N/A	Re-rack hose with folds in different position annually
Yes	No	N/A	Drain water from all low point drains in dry systems prior to freezing temperatures
Yes	No	N/A	OS&Y — stems lubricated annually
Yes	No	N/A	Lubricate, repair, or replace hose valves that do not open smoothly or fully

Comments

Signature:

Date:

Contractor Name:

Contractor Address:

License/Certification No.:

STANDPIPE AND HOSE SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

[illegible]

NFPA 25 Handbook (p. 7 of 8)



© 2019 National Fire Protection Association. This form may be copied for individual use other than for resale. It may not be copied for commercial sale or distribution. No other reproduction or transmission in any form permitted without written permission of NFPA. For inquiries or to report unauthorized use, contact licensing@nfpa.org.

STANDPIPE AND HOSE SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

This form covers weekly inspections over a 6-month period.

Year:

System:

Location:

General

1. If valves are sealed, note "yes" in this block. If any are not sealed, reseal and note "resealed" in this block.
2. Record any notes about the system that the inspector believes to be significant.

Date	Inspector	Valves Sealed (1)	Notes (2)