



WATER SPRAY SYSTEMS INSPECTION, TESTING, AND MAINTENANCE

Name of Property:

Inspector:

Address:

Contract No.:

Property Phone Number:

Date:

Inspection Frequency:	Daily	Weekly	Quarterly	Semiannual	Annual
Inspections: Daily			Deluge Valve (Cold Weather/Heating Season Only)		
Yes	No	N/A	Enclosure, not equipped with a low temperature alarm, is inspected during cold weather to verify a minimum temperature of 40°F (4°C)		
Inspections Weekly			Backflow		
Yes	No	N/A	Isolation valves — open position and locked or supervised		
Yes	No	N/A	RPA and RPDA — differential-sensing relief valve operating correctly		
			Control Valves		
Yes	No	N/A	In the correct (open or closed) position		
Yes	No	N/A	Sealed		
Yes	No	N/A	Accessible		
Yes	No	N/A	Post Indicator Valves (PIVs) are provided with correct wrenches		
Yes	No	N/A	Free from damage or leaks		
Yes	No	N/A	Proper signage		
			Deluge Valve		
Yes	No	N/A	Enclosure, where equipped with low temperature alarm, is inspected during cold weather to verify a minimum temperature of 40°F (4°C)		
Inspections: Monthly					
Yes	No	N/A	Gauges are operable and not physically damaged		
Yes	No	N/A	Gauges — normal air or nitrogen pressure maintained (not supervised) psi		
			Control Valves (Locked or Supervised)		
Yes	No	N/A	In the correct (open or closed) position		
Yes	No	N/A	Locked or supervised		
Yes	No	N/A	Accessible		
Yes	No	N/A	Post Indicator Valves (PIVs) are provided with correct wrenches		
Yes	No	N/A	Free from damage or leaks		
Yes	No	N/A	Proper signage		
			Deluge Valve		
Yes	No	N/A	Free from physical damage or leaks		
Yes	No	N/A	Electrical components are in service		
Yes	No	N/A	Trim valves are in the correct (open or closed) position		
Yes	No	N/A	Valve seat is not leaking		
Yes	No	N/A	Detection system gauge (if provided) — normal pressure is being maintained		

NFPA 25 Handbook (p. 1 of 5)

WATER SPRAY SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Inspections: Monthly

Yes	No	N/A
Yes	No	N/A

UHSWSS Detectors

Free of physical damage

Optical detectors (where used) — lenses clean

Inspections: Quarterly

Yes	No	N/A
Yes	No	N/A

Gauges — normal supply water pressure is being maintained psi

Gauges — normal air or nitrogen pressure maintained when supervised at a constantly attended location psi

Control Valves (Electronically Supervised)

Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A

In the correct (open or closed) position

Electronically supervised

Accessible

Post Indicator Valves (PIVs) are provided with correct wrenches

Free from damage or leaks

Proper signage

Drainage

Yes	No	N/A
Yes	No	N/A

Method is in good operating condition

Retention embankments or dikes are in good condition

Inspections: Annual

Yes	No	N/A
Yes	No	N/A
Yes	No	N/A

Support/Hangers

In good condition (no missing or damaged paint or coating, rust, or corrosion)

Securely attached to structure and piping

No damaged or missing hangers, braces, and support

Pipes and Fittings

Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A

In good condition with no external corrosion

No leaks or mechanical damage

Correct alignment with no external loads

Low point drains maintained and in proper working order

Rubber-gasketed fittings in good condition

Nozzles

Yes	No	N/A
Yes	No	N/A
Yes	No	N/A

In place, aimed, and pointed in the direction intended

Free from external loading and corrosion

Caps or plugs are in place (where required)

Note:

For fire pumps refer to NFPA 25, Chapter 8, and the appropriate inspection forms.

For water storage tanks refer to NFPA 25, Chapter 9, and the appropriate inspection forms.

For detection systems refer to *NFPA 72® National Fire Alarm and Signaling Code*, and the appropriate inspection forms.

WATER SPRAY SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Test: Annual

Full Flow Trip Test (Deluge Valve)

Yes	No	N/A	Compare pressure readings to hydraulic design and water supply meets requirements
Yes	No	N/A	Manual release functions correctly
Yes	No	N/A	Valve status test performed
Yes	No	N/A	Nozzle spray patterns and direction verified
Yes	No	N/A	Air maintenance device functions correctly
Yes	No	N/A	Mainline strainer flushed after trip test
Yes	No	N/A	Backflow — forward flow test at a minimum flow rate of the system demand
Yes	No	N/A	Detection system tested in accordance with <i>NFPA 72</i> [®]

System Response Time

Yes	No	N/A	Heat detection responded in _____ sec
Yes	No	N/A	Flammable gas detection responded in _____ sec

Discharge Time

Yes	No	N/A	Time lapse between operation of detection systems and water delivery time to protected area _____ sec
Yes	No	N/A	UHSWSS/response time does not exceed 100 milliseconds

Routine Maintenance

Yes	No	N/A	OS&Y — stems lubricated annually
-----	----	-----	----------------------------------

Comments

Signature:

Date:

Contractor Name:

Contractor Address:

License/Certification No.:

NFPA 25 Handbook (p. 4 of 5)

WATER SPRAY SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

This form covers a 6-month period.

Year:

System:

Location:

Inspection

Weekly

General

1. If valves are sealed, note "yes" in this block. If any are not sealed, reseal and note "resealed" in this block.
2. If all nozzles are in good condition and not blocked, note "yes" in block. If not, see that corrections are made and briefly describe under "notes."
3. Assure valve enclosure is maintained above 40°F (4°C).
4. Assure deluge or preaction valve is free of damage, trim valves are in proper position, and electrical components are operational.
5. Record any notes about the system that the inspector believes to be significant.

Date	Inspector	Valves Sealed (1)	Nozzles OK (2)	Alarm Valve OK (3)	Deluge Valve OK (4)	Notes (5)