



DRY PIPE SPRINKLER SYSTEMS INSPECTION, TESTING, AND MAINTENANCE

Property Name:

Inspector:

Property Address:

Contract No.:

Property Phone Number:

Date:

Inspection Frequency: **Daily** **Weekly** **Monthly** **Quarterly** **Annual** **Five-Year**

Inspections: Daily

Dry Pipe Valve (Cold Weather/Heating Season Only)

Yes	No	N/A	Enclosure, not equipped with a low temperature alarm, is inspected during cold weather to verify a minimum temperature of 40°F (4°C)
-----	----	-----	--

Inspections: Weekly

Backflow

Yes	No	N/A	Isolation valves — open position and locked or supervised
-----	----	-----	---

Yes	No	N/A	RPA and RPDA — differential-sensing relief valve operating correctly
-----	----	-----	--

Control Valves

Yes	No	N/A	In the correct (open or closed) position
-----	----	-----	--

Yes	No	N/A	Sealed
-----	----	-----	--------

Yes	No	N/A	Accessible
-----	----	-----	------------

Yes	No	N/A	Post Indicator Valves (PIVs) are provided with correct wrenches
-----	----	-----	---

Yes	No	N/A	Free from damage or leaks
-----	----	-----	---------------------------

Yes	No	N/A	Proper Signage
-----	----	-----	----------------

Dry Pipe Valve

Yes	No	N/A	Enclosure, where equipped with low temperature alarm, is inspected during cold weather to verify a minimum temperature of 40°F (4°C)
-----	----	-----	--

Master Pressure-Regulating Device

Yes	No	N/A	Downstream pressures are in accordance with design criteria psi
-----	----	-----	--

Yes	No	N/A	Supply pressure is in accordance with design criteria psi
-----	----	-----	--

Yes	No	N/A	Free of damage or leaks
-----	----	-----	-------------------------

Yes	No	N/A	Trim in good operating condition
-----	----	-----	----------------------------------

Inspections: Monthly

Yes	No	N/A	Gauges are in good operating condition
-----	----	-----	--

Yes	No	N/A	Gauge on system side of dry valve reads proper ratio of air or nitrogen (when not supervised) psi
-----	----	-----	--

Yes	No	N/A	Gauge on quick-opening device reads the same as system side dry valve gauge (when not supervised) psi
-----	----	-----	--

Control Valves (Locked or Supervised)

Yes	No	N/A	In the correct (open or closed) position
-----	----	-----	--

Yes	No	N/A	Locked or supervised
-----	----	-----	----------------------

Yes	No	N/A	Accessible
-----	----	-----	------------

Yes	No	N/A	Post Indicator Valves (PIVs) are provided with correct wrenches
-----	----	-----	---

Yes	No	N/A	Free from damage or leaks
-----	----	-----	---------------------------

Yes	No	N/A	Proper signage
-----	----	-----	----------------

NFPA 25 Handbook (p. 1 of 6)

DRY PIPE SPRINKLER SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Inspections: Monthly

Yes	No	N/A
Yes	No	N/A
Yes	No	N/A

Dry Pipe Valves

Exterior is free of damage

Trim valves are in correct (open or closed) position

Intermediate chamber is not leaking

Inspections: Quarterly

Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A

Waterflow alarm and supervisory devices are free of damage

Gauge on supply side of dry valve reads normal psi

Gauge on system side of dry valve reads proper ratio of air or nitrogen when supervised at a constantly attended location psi

Gauge on quick-opening device reads the same as system side dry valve gauge when supervised at a constantly attended location psi

Fire Department Connections

Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A

Visible and accessible

Coupling/swivels operate correctly

Plugs/caps are in place

Gaskets are not damaged

Identification signs are in place

Automatic drain valve in place and operational

Clapper operates correctly

Interior is clear of obstructions (unless locked)

Check valve is not leaking

Visible piping supplying the fire department connection is undamaged

Pressure-Reducing Valve

Yes	No	N/A
Yes	No	N/A
Yes	No	N/A

In the open position and not leaking

Maintaining downstream pressure

In good condition, with handwheel installed and unbroken

Control Valves (Electronically Supervised)

Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A
Yes	No	N/A

In the correct (open or closed) position

Electronically supervised

Accessible

Post Indicator Valves (PIVs) are provided with correct wrenches

Free from damage or leaks

Proper signage

DRY PIPE SPRINKLER SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Test: Quarterly

Yes	No	N/A	Partial flow test performed to exercise valve
-----	----	-----	---

Test: Semiannual

Yes	No	N/A	Valve supervisory switch(es) function
Yes	No	N/A	Alarm devices — inspector's test or bypass opened and observed waterflow

Test: Annual

Yes	No	N/A	Supervisory switch functions
Yes	No	N/A	Low temperature alarm (if installed) at the beginning of heating season
Yes	No	N/A	Low air alarm — test per manufacturer's instructions
Yes	No	N/A	Automatic air pressure maintenance device
Yes	No	N/A	All control valves operated through full range of motion and returned to normal position
Yes	No	N/A	Backflow preventer — forward flow test at a minimum flow rate of the system demand
Yes	No	N/A	Valve status test performed
Yes	No	N/A	Pressure reducing valve partial flow test

Main Drain Test

			Static psi	Residual psi
Yes	No	N/A	Do results differ by more than 10% from previous test?	

Dry Pipe Valve Trip Test (Partial Flow)

			Water pressure	(psi)	Air pressure	(psi)
			Tripping air pressure	(psi)	Trip time	(sec)
Yes	No	N/A	Results comparable to previous tests			

Master Pressure-Regulating Device

Yes	No	N/A	Full flow test performed and compared to previous test results
-----	----	-----	--

Test: Three Years

Dry Pipe Valve Trip Test (Full Flow)

			Water pressure	(psi)	Air pressure	(psi)
			Tripping air pressure	(psi)	Trip time	(sec)
			Water delivery time	(min.)		
Yes	No	N/A	Results comparable to previous years			
Yes	No	N/A	Dry pipe system tested for leakage			

Test: Five Years

Yes	No	N/A	Gauges tested or replaced
Yes	No	N/A	Sprinkler pressure-reducing valve — flow test performed and compared to previous results

Fire Department Connections

Yes	No	N/A	Piping from fire department connection to fire department connection check valve has been hydrostatically tested at 150 psi (10 bar) for at least 2 hours
-----	----	-----	---

NFPA 25 Handbook (p. 4 of 6)

DRY PIPE SPRINKLER SYSTEMS INSPECTION, TESTING, AND MAINTENANCE (Continued)

Routine Maintenance

Yes	No	N/A	Sprinklers tested or replaced per appropriate testing schedule
Yes	No	N/A	OS&Y — stems lubricated annually
Yes	No	N/A	Operate all auxiliary drains after operation and before freezing conditions

Comments:

Signature:

Date:

Contractor Name:

Contractor Address:

License/Certification No.:

NFPA 25 Handbook (p. 5 of 6)



