

Test Cable Project

Report Generated: 2025-03-13 11:13
Client: Test Client
Company: Cable Analysis Ltd.

Analysis Summary

Metric	Value
Depth Compliance Percentage	83.00
Depth Problem Section Count	3
Depth Total Problem Length	88.00
Depth Anomaly Count	102

Problem Sections

Depth Problem Sections

Found 3 problem sections.
Severity distribution: 1 High, 1 Low, 1 Medium

Recommendations

- **Depth (High):** Found 1 high severity burial depth issues
Action: Remedial burial required for these sections
- **Depth (Medium):** Found 1 medium severity burial depth issues
Action: Consider additional protection for these sections
- **Depth (Low):** Found 1 low severity burial depth issues
Action: Monitor these sections during maintenance

Regulatory Requirements

Burial depth must meet minimum 1.5m target.