


SIMPLE INVERTER

FR-S520E-0.1K to 3.7K (-C) FR-S540E-0.4K to 3.7K FR-S520SE-0.1K to 1.5K FR-S510WE-0.1K to 0.75K



WIRING Chapter 1

FUNCTIONS Chapter 2

PROTECTIVE FUNCTIONS Chapter 3

SPECIFICATIONS Chapter 4

Thank you for choosing this Mitsubishi Transistorized inverter.

This instruction manual (detailed) provides instructions for advanced use of the FR-S500 series inverters.

Incorrect handling might cause an unexpected fault. Before using the inverter, always read this instruction manual and the instruction manual (basic) [IB-0600151E] packed with the product carefully to use the equipment to its optimum.

This section is specifically about safety matters

Do not attempt to install, operate, maintain or inspect the inverter until you have read through this instruction manual (basic) and appended documents carefully and can use the equipment correctly. Do not use the inverter until you have a full knowledge of the equipment, safety information and instructions.

In this instruction manual (detailed), the safety instruction levels are classified into "WARNING" and "CAUTION".

MARNING

Assumes that incorrect handling may cause hazardous conditions, resulting in death or severe injury.

⚠CAUTION

Assumes that incorrect handling may cause hazardous conditions, resulting in medium or slight injury, or may cause physical damage only.

Note that even the **CAUTION** level may lead to a serious consequence according to conditions. Please follow the instructions of both levels because they are important to personnel safety.

1. Electric Shock Prevention

WARNING

- While power is on or when the inverter is running, do not open the front cover. You
 may get an electric shock.
- Do not run the inverter with the front cover or wiring cover removed. Otherwise, you may access the exposed high-voltage terminals or the charging part of the circuitry and get an electric shock. Also, the inverter's ability to withstand earthquakes will deteriorate.
- Even if power is off, do not remove the front cover except for wiring or periodic inspection. You may access the charged inverter circuits and get an electric shock.
- Before starting wiring or inspection, check to make sure that the 3-digit LED inverter monitor is off, wait for at least 10 minutes after the power supply has been switched off, and check to make sure that there are no residual voltage using a tester or the like.
- This inverter must be earthed (grounded). Earthing (grounding) must conform to the requirements of national and local safety regulations and electrical codes. (NEC section 250, IEC 536 class 1 and other applicable standards)
- Any person who is involved in the wiring or inspection of this equipment should be fully competent to do the work.
- Always install the inverter before wiring. Otherwise, you may get an electric shock or be injured.
- Perform setting dial and key operations with dry hands to prevent an electric shock.
- Do not subject the cables to scratches, excessive stress, heavy loads or pinching.
 Otherwise, you may get an electric shock.
- Do not change the cooling fan while power is on. It is dangerous to change the cooling fan while power is on.
- When you have removed the front cover, do not touch the connector above the 3digit monitor LED display. Otherwise, you get an electrick shock.

2. Fire Prevention

ACAUTION

- Install the inverter and brake resistor on an incombustible wall without holes, etc.
 Installing the inverter and brake resistor directly on or near a combustible surface could lead to a fire.
- If the inverter has become faulty, switch off the inverter power. A continuous flow of large current could cause a fire.
- When using a brake resistor, make up a sequence that will turn off power when an alarm signal is output. Otherwise, the brake resistor may excessively overheat due to damage of the brake transistor and such, causing a fire.
- Do not connect the resistor directly to the DC terminals P and N. This could cause a fire.

3. Injury Prevention

∴ CAUTION

- Apply only the voltage specified in the instruction manual to each terminal to prevent damage, etc.
- Always connect to the correct terminal to prevent damage, etc.
- Always make sure that polarity is correct to prevent damage, etc.
- While power is on or for some time after power-off, do not touch the inverter as it is hot and you may get burnt.

4. Additional Instructions

Also note the following points to prevent an accidental failure, injury, electric shock, etc.

(1) Transportation and installation

∴ CAUTION

- When carrying products, use correct lifting gear to prevent injury.
- Do not stack the inverter boxes higher than the number recommended.
- Ensure that installation position and material can withstand the weight of the inverter. Install according to the information in the instruction manual.
- Do not install or operate if the inverter is damaged or has parts missing.
- When carrying the inverter, do not hold it by the front cover or setting dial; it may fall off or fail.
- Do not stand or rest heavy objects on the inverter.
- Check the inverter mounting orientation is correct.
- Prevent other conductive bodies as screws and metal fragments or other flammable substance as oil from entering the inverter.
- As the inverter is a precision instrument, do not drop or subject it to impact.
- Use the inverter under the following environmental conditions: This could cause the inverter damage.

	Temperature	-10°C to +50°C (non-freezing) (-10°C to +40°C for totally enclosed structure feature)
⊏	Ambient humidity	90%RH maximum (non-condensing)
	lStorage	-20°C to +65°C *
		Indoors (free from corrosive gas, flammable gas, oil mist, dust and dirt)
	Altitude/ vibration	Max.1000m above sea level 5.9m/s ² or less

^{*}Temperatures applicable for a short time, e.g. in transit.

(2) Wiring

↑ CAUTION

- Do not fit capacitive equipment such as power factor correction capacitor, capacitor type filter (option FR-BIF(-H)) or surge suppressor to the output of the inverter.
- The connection orientation of the output cables U, V, W to the motor will affect the direction of rotation of the motor.

(3) Trial run

↑ CAUTION

- Check all parameters, and ensure that the machine will not be damaged by a sudden start-up.
- When the load GD² is small (at the motor GD or smaller) for 400V from 1.5K to 3.7K, the output current may vary when the output frequency is in the 20Hz to 30Hz range.
 If this is a problem, set the Pr.72 "PWM frequency selection" to 6kHz or higher. (When setting the PWM to a higher frequency, check for noise or leakage current problem and take countermeasures against it.)

(4) Operation

WARNING

- When you have chosen the retry function, stay away from the equipment as it will restart suddenly after an alarm stop.
- Since the [STÓP] key is valid only when functions are set (refer to page 115), provide a circuit and switch separately to make an emergency stop (power off, mechanical brake operation for emergency stop, etc).
- Make sure that the start signal is off before resetting the inverter alarm. A failure to do so may restart the motor suddenly.
- The load used should be a three-phase induction motor only. Connection of any other electrical equipment to the inverter output may damage the equipment.
- Do not modify the equipment.
- Do not perform parts removal which is not instructed in this manual. Doing so may lead to fault or damage of the inverter.

ACAUTION

- The electronic thermal relay function does not guarantee protection of the motor from overheating.
- Do not use a magnetic contactor on the inverter input for frequent starting/stopping
 of the inverter.
- Use a noise filter to reduce the effect of electromagnetic interference. Otherwise nearby electronic equipment may be affected.
- Take measures to suppress harmonics. Otherwise power supply harmonics from the inverter may heat/damage the power capacitor and generator.
- When a 400V class motor is inverter-driven, please use an insulation-enhanced motor or measures taken to suppress surge voltages. Surge voltages attributable to the wiring constants may occur at the motor terminals, deteriorating the insulation of the motor.
- When parameter clear or all clear is performed, reset the required parameters before starting operations. Each parameter returns to the factory setting.
- The inverter can be easily set for high-speed operation. Before changing its setting, fully examine the performances of the motor and machine.
- In addition to the inverter's holding function, install a holding device to ensure safety.
- Before running an inverter which had been stored for a long period, always perform inspection and test operation.

(5) Emergency stop

↑ CAUTION

- Provide a safety backup such as an emergency brake which will prevent the machine and equipment from hazardous conditions if the inverter fails.
- When the breaker on the inverter primary side trips, check for the wiring fault (short circuit), damage to internal parts of the inverter, etc. Identify the cause of the trip, then remove the cause and power on the breaker.
- When any protective function is activated, take the appropriate corrective action, then reset the inverter, and resume operation.

(6) Maintenance, inspection and parts replacement

↑ CAUTION

 Do not carry out a megger (insulation resistance) test on the control circuit of the inverter.

(7) Disposing of the inverter

ACAUTION

Treat as industrial waste.

(8) General instructions

Many of the diagrams and drawings in this instruction manual (detailed) show the inverter without a cover, or partially open. Never operate the inverter in this manner. Always replace the cover and follow this instruction manual (detailed) when operating the inverter.

CONTENTS

1. WIRING 1

1.1	Standard connection diagram and terminal specifications	2
1.1.1	Standard connection diagram	2
1.1.2	Explanation of main circuit terminals	3
1.2	Main circuit terminals	6
1.2.1	Terminal block layout	6
1.2.2	Cables, wiring length, and crimping terminals	
1.2.3	Wiring instructions	
1.2.4	Selection of peripheral devices	
1.2.5	Leakage current and installation of earth (ground) leakage circuit breaker	12
1.2.6	Power-off and magnetic contactor (MC)	. 16
1.2.7	Regarding the installation of the reactor	. 17
1.2.8	Regarding noise and the installation of a noise filter	. 18
1.2.9	Earthing (Grounding) precautions	. 19
1.2.10	Power supply harmonics	. 20
1.2.11	• • • • • • • • • • • • • • • • • • • •	
1.2.12	2 Inverter-driven 400V class motor	. 25
1.3 H	How to use the control circuit terminals	.26
1.3.1	Terminal block layout	. 26
1.3.2	Wiring instructions	. 26
1.3.3	Changing the control logic	. 27
1.4 I	nput terminals	.29
1.4.1	Run (start) and stop (STF, STR, STOP)	. 29
1.4.2	Connection of frequency setting potentiometer and	
	output frequency meter (10, 2, 5, 4, AU)	. 32
1.4.3	External frequency selection (REX, RH, RM, RL)	. 33
1.4.4	Indicator connection and adjustment (FM)	. 35
1.4.5	Control circuit common terminals (SD, 5, SE)	. 37
1.4.6	Signal inputs by contactless switches	. 37
1.5 H	How to use the input signals	
(assigned terminals RL, RM, RH, STR)	.38
1.5.1	Multi-speed setting (RL, RM, RH, REX signals):	
	Pr. 60 to Pr. 63 setting "0, 1, 2, 8"	
	Remote setting (RL, RM, RH signals):	
	Pr. 60 to Pr. 63 setting "0, 1, 2"	
1.5.2	Second function selection (RT signal): Pr. 60 to Pr. 63 setting "3"	. 38

	1.5.3	Current input selection "AU signal": Pr. 60 to Pr. 63 setting "4"	ა၀
	1.5.4	Start self-holding selection (STOP signal): Pr. 60 to Pr. 63 setting "5"	39
	1.5.5	Output shut-off (MRS signal): Pr. 60 to Pr. 63 setting "6"	39
	1.5.6	External thermal relay input: Pr. 60 to Pr. 63 setting "7"	40
	1.5.7	Jog operation (JOG signal): Pr. 60 to Pr. 63 setting "9"	40
	1.5.8	Reset signal: Pr. 60 to Pr. 63 setting "10"	
	1.5.9	PID control valid terminal: Pr. 60 to Pr. 63 setting "14"	
	1.5.10	PU operation/external operation switchover: Pr. 60 to Pr. 63 setting "16	8" 42
	1.6 C	onnection to the stand-alone option	43
	1.6.1	Connection of the dedicated external brake resistor (option) (FR-S5208 to 3.7K only)	43
	1.6.2	Connection of the brake unit (BU type)	
	1.6.3	Connection of the high power factor converter (FR-HC)	
	1.6.4	Connection of the power regeneration common converter (FR-CV)	46
	1.7 H	andling of the RS-485 connector	47
	1.7.1	Connection of the parameter unit (FR-PU04)	47
	1.7.2	Wiring of RS-485 communication	48
	1.8 D	esign information	51
	1.9 F	ailsafe of the system which uses the inverter	52
	1.9 1	ansare of the system winch uses the inverter	52
2	. FUNC		55
2	. FUNC		55
2	. FUNC	TIONS	55 56
2	. FUNC 2.1 F 2.2 L	TIONS unction (Parameter) list	55 56 69
2	. FUNC 2.1 F 2.2 L	TIONS unction (Parameter) listist of parameters classified by purpose of use	55 56 69
2	2.1 F 2.2 L 2.3 E	TIONS unction (Parameter) list ist of parameters classified by purpose of use xplanation of functions (parameters)	56 69 71
2	2.1 F 2.2 L 2.3 E 2.3.1	unction (Parameter) listist of parameters classified by purpose of usexplanation of functions (parameters)	56 69 71 72
2	2.1 F 2.2 L 2.3 E 2.3.1 2.3.2	unction (Parameter) list ist of parameters classified by purpose of use xplanation of functions (parameters) Torque boost (Pr. 0 , Pr. 46) Maximum and minimum frequency (Pr. 1 , Pr. 2)	56 69 71 72 73
2	2.1 F 2.2 L 2.3 E 2.3.1 2.3.2 2.3.3	unction (Parameter) list ist of parameters classified by purpose of use xplanation of functions (parameters) Torque boost (Pr. 0 , Pr. 46) Maximum and minimum frequency (Pr. 1 , Pr. 2) Base frequency, base frequency voltage (Pr.3 , Pr.19 , Pr.47)	55 56 69 71 72 73 87)75
2	2.1 F 2.2 L 2.3 E 2.3.1 2.3.2 2.3.3 2.3.4	unction (Parameter) list ist of parameters classified by purpose of use xplanation of functions (parameters) Torque boost (Pr. 0 , Pr. 46) Maximum and minimum frequency (Pr. 1 , Pr. 2) Base frequency, base frequency voltage (Pr.3 , Pr.19 , Pr.47) Multi-speed operation (Pr. 4, Pr. 5, Pr. 6, Pr. 24 to Pr. 27, Pr. 80 to Pr.	55 56 69 71 72 73 87)75 76
2	2.1 F 2.2 L 2.3 E 2.3.1 2.3.2 2.3.3 2.3.4 2.3.5	unction (Parameter) list	55 56 71 71 72 73 87)75 76 78
2	2.1 F 2.2 L 2.3 E 2.3.1 2.3.2 2.3.3 2.3.4 2.3.5 2.3.6	unction (Parameter) list	55 56 71 72 73 87)75 76 78 80 81
2	2.1 F 2.2 L 2.3 E 2.3.1 2.3.2 2.3.3 2.3.4 2.3.5 2.3.6 2.3.7	unction (Parameter) list	55 56 71 72 73 87)75 76 78 80 81
2	2.1 F 2.2 L 2.3 E 2.3.1 2.3.2 2.3.3 2.3.4 2.3.5 2.3.6 2.3.7 2.3.8 2.3.9 2.3.10	unction (Parameter) list	55 56 71 71 72 73 87)75 76 78 80 81 82 83
2	2.1 F 2.2 L 2.3 E 2.3.1 2.3.2 2.3.3 2.3.4 2.3.5 2.3.6 2.3.7 2.3.8 2.3.9 2.3.10 2.3.11	unction (Parameter) list	55 56 71 71 72 76 76 80 81 82 83
2	2.1 F 2.2 L 2.3 E 2.3.1 2.3.2 2.3.3 2.3.4 2.3.5 2.3.6 2.3.7 2.3.8 2.3.9 2.3.10 2.3.11 2.3.12	unction (Parameter) list	55 56 71 71 72 76 76 80 81 82 83

	2.3.14	Acceleration/deceleration pattern (Pr. 29)	88
	2.3.15	Extended function display selection (Pr. 30)	89
	2.3.16	Frequency jump (Pr. 31 to Pr. 36)	89
	2.3.17	Speed display (Pr. 37)	90
	2.3.18	Biases and gains of the frequency setting voltage (current)	
		(Pr. 38 , Pr. 39 , C2 to C7)	
		Start-time earth (ground) fault detection selection (Pr. 40)	
2	.4 O	utput terminal function	95
	2.4.1	Up-to-frequency sensitivity (Pr. 41)	9
	2.4.2	Output frequency detection (Pr. 42 , Pr. 43)	96
2	.5 C	urrent detection function	97
	2.5.1	Output current detection functions (Pr. 48 , Pr. 49)	97
	2.5.2	Zero current detection (Pr. 50 , Pr. 51)	
2	.6 D	isplay function	
_	2.6.1	Monitor display (Pr. 52 , Pr. 54)	
	2.6.2	Setting dial function selection (Pr. 53)	
	2.6.3	Monitoring reference (Pr. 55 , Pr. 56)	
^			
_		estart operation function	
	2.7.1	Restart setting (Pr. 57 , Pr. 58 , H6)	
2	.8 A	dditional function	
	2.8.1	Remote setting function selection (Pr. 59)	104
2	.9 To	erminal function selection	108
	2.9.1	Input terminal function selection (Pr. 60 , Pr. 61 , Pr. 62 , Pr. 63)	108
	2.9.2	Output terminal function selection (Pr. 64 , Pr. 65)	
2	.10 O	peration selection function	111
		Retry function (Pr. 66 , Pr. 67 , Pr. 68 , Pr. 69)	
		PWM carrier frequency and long wiring mode (Pr. 70 , Pr. 72)	
		Voltage input selection (Pr. 73)	
	2.10.4	Input filter time constant (Pr. 74)	115
	2.10.5	Reset selection/PU stop selection (Pr. 75)	11
		Cooling fan operation selection (Pr. 76)	
		Parameter write disable selection (Pr. 77)	
		Reverse rotation prevention selection (Pr. 78)	
		Operation mode selection (Pr. 79)	
		PID control (Pr. 88 to Pr. 94)	
2	.11 A	uxiliary function	131
	2 11 1	Slin compensation (Pr. 95, Pr. 96, Pr. 97.)	13.

	Automatic torque boost selection (Pr. 98) Motor primary resistance (Pr. 99)	
	Maintenance function	
2.12.1	Maintenance output function (H1, H2)	133
	Current average value monitor signal (H3, H4, H5)	
	Brake parameters (FR-S520E-0.4K to 3.7K only)	
2.13.1	Regenerative braking operation (b1 , b2)	137
2.14	Calibration parameters	138
2.14.1	Meter (frequency meter) calibration (C1)	138
2.15	Clear parameters	141
2.15.1	Parameter clear (CLr)	141
2.15.2	Alarm history clear (ECL)	141
2.16	Communication parameters	142
2.16.1	Communication settings (n1 to n7, n11)	144
2.16.2	Operation and speed command source (n8 , n9)	160
	Link startup mode selection (n10)	
	EEPROM write selection (n12)	
2.17 F	Parameter unit (FR-PU04) setting	164
	PU display language selection (n13)	
	PU buzzer control (n14)	
	PU contrast adjustment (n15)	
	PU main display screen data selection (n16)	
2.17.5	Disconnected PU detection/PU setting lock selection (n17)	166
3. PRO1	ECTIVE FUNCTIONS	169
3.1 E	Errors (Alarms)	170
3.1.1	Error (alarm) definitions	171
3.1.2	To know the operating status at the occurrence of alarm	
	(only when FR-PU04 is used)	
3.1.3	Correspondence between digital and actual characters	
3.1.4	Resetting the inverter	
3.1.5	Checking of the alarm history	
3.2 1	roubleshooting	181
3.2.1	Motor remains stopped	
3.2.2	Motor rotates in opposite direction	
3.2.3	Speed greatly differs from the setting	182

3.2.4	Acceleration/deceleration is not smooth	182
3.2.5	Motor current is large	182
3.2.6	Speed does not increase	182
3.2.7	Speed varies during operation	
3.2.8	Operation mode is not changed properly	183
3.2.9	Operation panel display is not operating	183
3.2.10	Parameter write cannot be performed	183
3.2.11	Motor produces annoying sound	183
3.3 P	recautions for maintenance and inspection	184
3.3.1	Precautions for maintenance and inspection	184
3.3.2	Inspection item	184
3.3.3	Periodic inspection	184
3.3.4	Insulation resistance test using megger	185
3.3.5	Pressure test	185
3.3.6	Daily and periodic inspection	186
3.3.7	Checking the inverter and converter module	188
3.3.8	Replacement of parts	189
3.3.9	Measurement of main circuit voltages, currents and powers	192
4. SPECI	FICATIONS	195
4.1 S	pecification list	196
4.1.1	Ratings	196
4.1.2	Common specifications	
4.2 O	utline dimension drawings	202
APPENI	DIX	205
ADDEN	DIX 1 Parameter instruction code list	206

1. WIRING

This chapter explains the basic "wiring" for use of this product. Always read the instructions before use.

For description of "installation", refer to the instruction manual (basic).

1.1	Standard connection diagram and terminal specifications	2
1.2	Main circuit terminals	6
1.3	How to use the control circuit terminals	26
1.4	Input terminals	29
1.5	How to use the input signals (assigned terminals RL, RM, RH, STR)	38
1.6	Connection to the stand-alone option	43
1.7	Handling of the RS-485 connector	47
1.8	Design information	51

<Abbreviations>

•PU

Operation panel and parameter unit (FR-PU04)

Inverter

Mitsubishi transistorized inverter FR-S500 series

•FR-S500

Mitsubishi transistorized inverter FR-S500 series

•Pr.

Parameter number

Chapter 1

Chapter 2


Chapter 3

Chapter 4

1.1 Standard connection diagram and terminal specifications

1.1.1 Standard connection diagram

- Three-phase 200V power input
- Three-phase 400V power input



REMARKS

- *1. The N/- terminal is not provided for the FR-S520E-0.1K to 0.75K.
- *2. The PR terminal is provided for the FR-S520E-0.4K to 3.7K.
- *3. Not needed when the setting dial is used for calibration. Used when calibration must be made near the frequency meter for such a reason as a remote frequency meter. However, the frequency meter needle may not deflect to full-scale if the calibration resistor is connected. In this case, use this resistor and setting dial together.
- *4. You can switch the position of sink and source logic. (Refer to page 27.)
- *5. When the setting potentiometer is used frequently, use a 2W1kΩ potentiometer.
- *6. The terminal functions change with input terminal function selection (Pr. 60 to Pr. 63). (Refer to page 108.) (RES, RL, RM, RH, RT, AU, STOP, MRS, OH, REX, JOG, X14, X16, (STR) signal selection)
- *7. The terminal function changes according to the setting of output terminal function selection (Pr. 64, Pr. 65). (Refer to page 110.) (RUN, SU, OL, FU, RY, Y12, Y13, FDN, FUP, RL, Y93, Y95, LF, ABC signal selection)

CAUTION

To prevent a malfunction due to noise, keep the signal cables more than 10cm away from the power cables.

- Single-phase 200V power input
- Single-phase 100V power input



REMARKS

- •To ensure safety, connect the power input to the inverter via a magnetic contactor and earth leakage circuit breaker or moulded case circuit breaker, and use the magnetic contactor to switch power on-off.
- •The output is three-phase 200V.

1.1.2 Explanation of main circuit terminals

(1) Main circuit

Terminal Symbol	Terminal Name	Description
R/L1, S/L2, T/L3 (*1)	AC power input	Connect to the commercial power supply.
U, V, W	Inverter output	Connect a three-phase squirrel-cage motor.
P/+, PR (*2)	Brake resistor connection	Connect the optional brake resistor (MRS/MYS type, FRABR) (The brake resistor can be connected to the FRS520E-0.4K to 3.7K only.)
P/+, N/-	Brake unit connection	Connect the brake unit (BU), power regeneration common converter (FR-CV) or high power factor converter (FR-HC). (The N/- terminal is not provided for the FR-S520E-0.1K to 0.75K.)
P/+, P1	DC reactor connection	Remove the jumper across terminals P - P1 and connect the optional DC reactor (FR-HEL(-H)/FR-BEL(-H)). (The single-phase 100V power input model cannot be connected.)
	Earth (ground)	For earthing (grounding) the inverter chassis. Must be earthed (grounded).

^{*1.} When using single-phase power input, terminals are R/L1 and S/L2.

^{*2.} The PR terminal is provided for the FR-S520E-0.4K to 3.7K.

(2) Control circuit

5	Sym	nbol	Terminal Name	Definition				
		STF	Forward rotation start	Turn on the STF signal to start forward rotation and turn it off to stop. When the STF and STR signals are turned on simultaneously, the stop command is given.				
	Contact input	STR	Reverse rotation start	Turn on the STR signal to start reverse rotation and turn it off to stop.		The terminal functions change		
		RH RM RL	Multi-speed selection	Turn on the RH, RM and RL si appropriate combinations to se multiple speeds. The priorities of the speed comare in order of jog, multi-speed (RH, RM, RL, REX) and AU.	elect nmands	with input terminal function selection (Pr. 60 to Pr. 63). (*3)		
als			Contact input common (sink) (initial setting)	Common terminal for contact input terminal (sink logic) and terminal FM.				
Input signals	(*1, 6) External transistor common (source) 24VDC power supply common			When connecting the transistor output (open collector output), such as a programmable controller (PLC), wh source logic is selected, connect the external power s common for transistor output to this terminal to prever malfunction caused by undesirable currents.				
			<u>-</u>	Common output terminal for 24VDC 0.1A power supply (PC terminal) Isolated from terminals 5 and SE.				
	PC		External transistor common (sink) (initial setting)	When connecting the transistor output (open collector output), such as a programmable controller (PLC), wher logic is selected, connect the external power supply con for transistor output to this terminal to prevent a malfunc caused by undesirable currents.				
	((*1)	Contact input common (source)	Common terminal for contact input terminal (source logic)				
			24VDC power supply	Can be used as 24VDC 0.1A po	n be used as 24VDC 0.1A power supply.			
	10 Frequency setting power supply 5VDC, Permissible load current 10mA.							

S	Symbol		Terminal Name	Definition				
		2	Frequency setting (voltage signal)	Inputting 0 to 5VDC (or 0 to 10V) provides the maximum output frequency at 5V (10V) and makes input and output proportional. Switch between 5V and 10V using Pr. 73 "0-5V, 0-10V selection". Input resistance $10k\Omega$. Maximum permissible input voltage $20V$				
Input signals	Frequency setting	4	Frequency setting (current signal)	Input 4 to 20mADC. It is factory set at 0Hz for 4mA and at 60Hz for 20mA. Maximum permissible input current 30mA. Input resistance approximately 250 Ω . Turn ON signal AU for current input. Turning the AU signal on makes voltage input invalid. Use any of Pr. 60 to Pr. 63 (input terminal function selection) to set the AU signal.				
		5	Frequency setting input common	Frequency setting signal (terminal 2, 4) co (*6)	ommon terminal.			
	A B C		Alarm output	1 changeover contact output indicates that the inverter protective function has activated and the output stopped. 230VAC 0.3A, 30VDC 0.3A. Alarm: discontinuity across B-C (continuity across A-C), Normal: continuity across B-C (discontinuity across A-C).(*5)	The function of the terminals changes according to the output terminal			
Output signals	Open collector	RUN Inverter running		Switched low when the inverter output frequency is equal to or higher than the starting frequency (factory set to 0.5Hz variable). Switched high during stop or DC injection brake operation. (*2) Permissible load 24VDC 0.1A (a voltage drop is 3.4V maximum when the signal is on)	function selection (Pr. 64, Pr. 65). (*4)			
utpu	;	SE Open collector common		Common terminal for inverter running terminal RUN. (*6)				
0	FM For meter		For meter	The output signal across terminals FM-SD is factory set to about 1mA at 60Hz and is proportional to the corresponding output frequency. Since output voltage is pulse waveform, a digital meter can be connected. Frequency permissible load current 1mA Pulse specification 1440 pulses/s at 60Hz				
ommunication	_		RS-485 connector	Using the parameter unit connection cable (FR-CB201 to 205), the parameter unit (FR-PU04) can be connected. Communication operation can be performed using RS-485. For details of RS-485 communication, refer to page 48.				


- Do not connect terminals SD and PC each other or to the earth (ground). For sink logic (factory setting), terminal SD acts as the common terminal of contact input. For source logic, terminal PC acts as the common terminal of contact input. (Refer to page 27 for switching method.)
- *2. Low indicates that the open collector output transistor is on (conducts). High indicates that the transistor is off (does not conduct).
- RL, RM, RH, RT, AU, STOP, MRS, OH, REX, JOG, RES, X14, X16, (STR) signal selection (Refer to page 108.)
- *4. RUN, SU, OL, FU, RY, Y12, Y13, FDN, FUP, RL, Y93, Y95, LF, ABC signal selection (Refer to page 110.)
 *5. To be compliant with the European Directive (Low Voltage Directive), the operating capacity of
- relay outputs (A, B, C) should be 30VDC 0.3A.
- *6. Terminals SD, SE and 5 are isolated from each other. Do not earth (ground).

ၓ


1.2 Main circuit terminals

1.2.1 Terminal block layout


1) Three-phase 200V power input




2) Three-phase 400V power input



3) Single-phase 200V power input



4) Single-phase 100V power input



CAUTION

- •Make sure the power cables are connected to the R/L1, S/L2, T/L3 of the inverter. Never connect the power cable to the U, V, W of the inverter. Doing so will damage the inverter. (Phase need not be matched)
- •Connect the motor to U, V, W. At this time, turning on the forward rotation switch (signal) rotates the motor in the counterclockwise direction when viewed from the motor shaft.

1.2.2 Cables, wiring length, and crimping terminals

The following table indicates a selection example for the wiring length of 20m.

1) Three-phase 200V power input

	Ter-	Tight-			Cable Size					
Applied Inverter	minal Screw	ening Torque			HIV cable (mm ²)		AWG		PVC cable (mm ²)	
	size	N⋅m	R , S , T	U, V, W	R , S , T	U, V, W	R , S , T	U, V, W	R , S , T	U, V, W
FR-S520E-0.1K to 0.75K (-C)	M3.5	1.2	2-3.5	2-3.5	2	2	14	14	2.5	2.5
FR-S520E- 1.5K, 2.2K (-C)	M4	1.5	2-4	2-4	2	2	14	14	2.5	2.5
FR-S520E-3.7K (-C)	M4	1.5	5.5-4	5.5-4	3.5	3.5	12	12	4	2.5

2) Three-phase 400V power input

	Ter-	Tight-	Crimping Terminal		Cable Size					
Applied Inverter	minal Screw	ening Torque			HIV cable (mm ²)		AWG		PVC cable (mm ²)	
	size N·m	R, S, T	U, V, W	R, S, T	U, V, W	R, S, T	U, V, W	R, S, T	U, V, W	
FR-S540E-0.4K to 3.7K	M4	1.5	2-4	2-4	2	2	14	14	2.5	2.5

3) Single-phase 200V power input

o) olligic-phase z	.00 v pc	WCI IIIP	ut								
	Termi-	Tight-	Cuin	0 :		Cable					
Applied Inverter	nal Screw	ening Torque		nping minal		cable ım²)	A	WG		Cable nm²)	
	size	N⋅m	R, S	U, V, W	R, S	U, V, W	R, S	U, V, W	R, S	U, V, W	
FR-S520SE-0.1K to 0.75K	M3.5	1.2	2-3.5	2-3.5	2	2	14	14	2.5	2.5	
FR-S520SE-1.5K	M4	1.5	2-4	2-4	2	2	14	14	2.5	2.5	

4) Single-phase 100V power input

	Termi-	Tight-	Crin	Crimping		Cable Size				
Applied Inverter	nal Screw	ening Torque		minal		cable ım²)	A	WG		cable ım²)
	size	N⋅m	R, S	U, V, W	R, S	U, V, W	R, S	U, V, W	R, S	U, V, W
FR-S510WE-0.1K to 0.4K	M3.5	1.2	2-3.5	2-3.5	2	2	14	14	2.5	2.5
FR-S510WE-0.75K	M4	1.5	5.5-4	2-4	3.5	2	12	14	4	2.5

Wiring length

100m maximum. (50m maximum for the FR-S540E-0.4K.)

CAUTION

•When the wiring length of the 0.1K and 0.2K of the three-phase 200V, single-phase 200V, and single-phase 100V class and the 0.4K and 0.75K of the three-phase 400V class is 30m or more, set the carrier frequency to 1kHz.

•When automatic torque boost is selected in Pr. 98 "automatic torque boost selection (motor capacity)", the wiring length should be 30m maximum. (Refer to page 132.)

1.2.3 Wiring instructions

- 1) Use crimping terminals with insulation sleeve to wire the power supply and motor.
- 2) Application of power to the output terminals (U, V, W) of the inverter will damage the inverter. Never perform such wiring.
- After wiring, wire offcuts must not be left in the inverter.
 Wire offcuts can cause an alarm, failure or malfunction. Always keep the inverter clean.
 - When drilling mounting holes in an enclosure etc., take care not to allow chips and other foreign matter to enter the inverter.
- 4) Use cables of the recommended size to make a voltage drop 2% maximum. If the wiring distance is long between the inverter and motor, a main circuit cable voltage drop will cause the motor torque to decrease especially at the output of a low frequency.
- 5) For long distance wiring, the fast-response current limit function may be reduced or the devices connected to the secondary side may malfunction or become faulty under the influence of a charging current due to the stray capacity of wiring. Therefore, note the maximum overall wiring length.
- 6) Electromagnetic wave interference The input/output (main circuit) of the inverter includes high frequency components, which may interfere with the communication devices (such as AM radios) used near the inverter. In this case, install a FR-BIF(-H) optional capacitor type filter (for use on the input side only) or FR-BSF01 or FR-BLF common mode filter to minimize interference.
- 7) Do not install a power capacitor, surge suppressor or capacitor type filter (FR-BIF(-H) option) on the output side of the inverter.

 This will cause the inverter to trip or the capacitor and surge suppressor to be damaged. If any of the above devices are connected, remove them. (When using the FR-BIF(-H) capacitor type filter with a single-phase power supply, connect it to the input side of the inverter after isolating the T phase securely.)
- 8) Before starting wiring or other work after the inverter is operated, wait for at least 10 minutes after the power supply has been switched off, and check that there are no residual voltage using a tester or the like. The capacitor is charged with high voltage for some time after power off and it is dangerous.

1.2.4 Selection of peripheral devices

Check the inverter type of the inverter you purchased. Appropriate peripheral devices must be selected according to the capacity.

Refer to the following list and prepare appropriate peripheral devices:

1) Three-phase 200V power input

Motor Output (kW)	Applied Inverter Type	Moulded Case Circuit Breaker (MCCB *1, 4) or Earth Leakage Circuit Breaker (ELB) (Refer to page 12) (*2, 4)	(MC)		DC Reactor FR-HEL-□□K FR-BEL-□□K (Refer to page 17)
0.1	FR-S520E-0.1K(-C)	30AF/5A	S-N10	0.4 (*3)	0.4 (*3)
0.2	FR-S520E-0.2K(-C)	30AF/5A	S-N10	0.4 (*3)	0.4 (*3)
0.4	FR-S520E-0.4K(-C)	30AF/5A	S-N10	0.4	0.4
0.75	FR-S520E-0.75K(-C)	30AF/10A	S-N10	0.75	0.75
1.5	FR-S520E-1.5K(-C)	30AF/15A	S-N10	1.5	1.5
2.2	FR-S520E-2.2K(-C)	30AF/20A	S-N10	2.2	2.2
3.7	FR-S520E-3.7K(-C)	30AF/30A	S-N20, S-N21	3.7	3.7

2) Three-phase 400V power input

Motor Output (kW)	Applied Inverter Type	Moulded Case Circuit Breaker (MCCB *1, 4) or Earth Leakage Circuit Breaker (ELB) (Refer to page 12) (*2, 4)	(MC)		DC Reactor FR-HEL-□□K FR-BEL-□□K (Refer to page 17)
0.4	FR-S540E-0.4K	30AF/5A	S-N10	H0.4	H0.4
0.75	FR-S540E-0.75K	30AF/5A	S-N10	H0.75	H0.75
1.5	FR-S540E-1.5K	30AF/10A	S-N10	H1.5	H1.5
2.2	FR-S540E-2.2K	30AF/15A	S-N10	H2.2	H2.2
3.7	FR-S540E-3.7K	30AF/20A	S-N20, S-N21	H3.7	H3.7

3) Single-phase 200V power input

Motor Output (kW)	Applied Inverter Type	Moulded Case Circuit Breaker (MCCB *1, 4) or Earth Leakage Circuit Breaker (ELB) (Refer to page 12) (*2, 4)	(NIC)	AC Reactor (*3) FR-HAL-□□K FR-BAL-□□K (Referto page 17)	FR-BEL-□□K
0.1	FR-S520SE-0.1K	30AF/5A	S-N10	0.4	0.4
0.2	FR-S520SE-0.2K	30AF/10A	S-N10	0.4	0.4
0.4	FR-S520SE-0.4K	30AF/10A	S-N20, S-N21	0.75	0.75
0.75	FR-S520SE-0.75K	30AF/15A	S-N20, S-N21	1.5	1.5
1.5	FR-S520SE-1.5K	30AF/20A	S-N20, S-N21	2.2	2.2

4) Single-phase 100V power input

Motor Output (kW)	Applied Inverter Type	Moulded Case Circuit Breaker (MCCB *1, 4) or Earth Leakage Circuit Breaker (ELB) (Refer to page 12) (*2, 4)	Magnetic Contactor (MC) (Refer to page 16)	FR-HAL-UUK	DC Reactor (*5) FR-HEL-□□K FR-BEL-□□K (Refer to page 17)
0.1	FR-S510WE-0.1K	30AF/10A	S-N10	0.75	_
0.2	FR-S510WE-0.2K	30AF/15A	S-N10	1.5	_
0.4	FR-S510WE-0.4K	30AF/20A	S-N20, S-N21	2.2	_
0.75	FR-S510WE-0.75K	30AF/30A	S-N20, S-N21	3.7	_

*1. • Select the MCCB according to the power supply capacity. ---- MCCB INV M
• Install one MCCB per inverter.

- *2. For installations in the United States or Canada, the circuit breaker must be inverse time or instantaneous trip type.
- *3. The power factor may be slightly lower.
- *4. When the breaker on the inverter primary side trips, check for the wiring fault (short circuit), damage to internal parts of the inverter, etc. Identify the cause of the trip, then remove the cause and power on the breaker.
- *5. The single-phase 100V power input model is not compatible with the DC reactor.

1.2.5 Leakage current and installation of earth (ground) leakage circuit breaker

Due to static capacitances existing in the inverter I/O wiring and motor, leakage currents flow through them. Since their values depend on the static capacitances, carrier frequency, etc., take the following countermeasures.

(1) To-earth (ground) leakage currents

Leakage currents may flow not only into the inverter's own line but also into the other line through the earth (ground) cable, etc.


These leakage currents may operate earth (ground) leakage circuit breakers and earth (ground) leakage relays unnecessarily.

Countermeasures

- If the carrier frequency setting is high, decrease the carrier frequency (Pr. 72) of the inverter.
 - Note that motor noise increases. Selection of Soft-PWM control (Pr. 70) will make it unoffending. (Factory setting)
- By using earth leakage circuit breakers designed for harmonic and surge suppression in the inverter's own line and other line, operation can be performed with the carrier frequency kept high (with low noise).

(2) Line-to-line leakage currents

Harmonics of leakage currents flowing in static capacities between the inverter output cables may operate the external thermal relay unnecessarily.



Countermeasures

- Use the electronic thermal relay function of the inverter.
- Decrease the carrier frequency. Note that motor noise increases. Selection of Soft-PWM (Pr. 70) makes it unoffending.

To ensure that the motor is protected against line-to-line leakage currents, it is recommended to use a temperature sensor to directly detect motor temperature.

■ Installation and selection of moulded case circuit breaker Install a moulded case circuit breaker (MCCB) on the power receiving side to protect the wiring of the inverter primary side. Select the MCCB according to the power supply side power factor (which depends on the power supply voltage, output frequency and load). Especially for a completely electromagnetic MCCB, one of a slightly large capacity must be selected since its operation characteristic varies with harmonic currents. (Check it in the data of the corresponding breaker.) As an earth (ground) leakage breaker, use the Mitsubishi earth (ground) leakage breaker designed for harmonics and surge suppression. (Refer to page 10 for the

CAUTION

recommended models.)

- •Select the MCCB according to the inverter power supply capacity.
- •Install one MCCB per inverter.

(3) Selecting the rated sensitivity current for the earth leakage circuit breaker


When using the earth leakage circuit breaker with the inverter circuit, select its rated sensitivity current as follows, independently of the PWM carrier frequency:

 Breaker for harmonic and surge Rated sensitivity current: I∆n ≥ 10 × (Iq1+Iqn+Iq2+Iqm)


Standard breaker
 Rated sensitivity current:
 | |∆n ≥ 10 × {||g1+|gn+|3 × (|g2+|gm)|}
 | |g1, |g2 : Leakage currents of cable path during commercial power supply operation

Ign* : Leakage current of noise filter on inverter input side
Igm : Leakage current of motor during commercial power supply operation

 Note the leakage current value of the noise filter installed on the inverter input side. Example of leakage current per 1km in cable path during commercial power supply operation when the CV cable is routed in metal conduit (200V 60Hz)




Leakage current example of three-phase induction motor during commercial power supply operation (200V 60Hz)



Motor capacity (kW)

<Example>



	Breaker for Harmonic and Surge	Standard Breaker		
Leakage current (lg1) (mA)	20 ×5n	= 0.10		
Leakage current (Ign) (mA)	0 (without noise filter)			
Leakage current (lg2) (mA)	20 ×			
Motor leakage current (Igm) (mA)	0.16			
Total leakage current (mA)	1.66 4.78			
Rated sensitivity current (mA) (≥ Ig × 10)	30	100		

CAUTION

- •The earth (ground) leakage circuit breaker should be installed to the primary (power supply) side of the inverter.
- •In the \bot connection neutral point earthed (grounded) system, the sensitivity current becomes worse for earth (ground) faults on the inverter secondary side. Earthing (Grounding) must conform to the requirements of national and local safety regulations and electrical codes. (NEC section 250, IEC 536 class 1 and other applicable standards)
- •When the breaker is installed on the secondary side of the inverter, it may be unnecessarily operated by harmonics if the effective value is less than the rating. In this case, do not install the breaker since the eddy current and hysteresis loss increase and the temperature rises.
- •General products indicate the following models: BV-C1, BC-V, NVB, NV-L, NV-G2N, NV-G3NA, NV-2F, earth (ground) leakage relay (except NV-ZHA), NV with AA neutral wire open-phase protection
- The other models are designed for harmonic and surge suppression: NV-C/NV-S/MN series, NV30-FA, NV50-FA, BV-C2, earth (ground) leakage alarm breaker (NF-Z), NV-ZHA, NV-H

1.2.6 Power-off and magnetic contactor (MC)

(1) Inverter input side magnetic contactor (MC)

On the inverter's input side, it is recommended to provide an MC for the following purposes. (Refer to page 10 for selection)

- 1) To release the inverter from the power supply when the inverter protective function is activated or the drive becomes faulty (e.g. emergency stop operation)
 - When cycle operation or heavy-duty operation is performed with an optional brake resistor connected, overheat and burnout of the electrical-discharge resistor can be prevented if a regenerative brake transistor is damaged due to insufficient heat capacity of the electrical-discharge resistor and excess regenerative brake duty.
- 2) To prevent any accident due to an automatic restart at restoration of power after an inverter stop made by a power failure
- 3) To rest the inverter for an extended period of time The control power supply for inverter is always running and consumes a little power. When stopping the inverter for an extended period of time, powering off the inverter will save power slightly.
- 4) To separate the inverter from the power supply to ensure safe maintenance and inspection work


The inverter's input side MC is used for the above purpose, select class JEM1038-AC3 for the inverter input side current when making an emergency stop during normal operation.

REMARKS

The MC may be switched on/off to start/stop the inverter. However, since repeated inrush currents at power on will shorten the life of the converter circuit (switching life is about 100,000 times), frequent starts and stops must be avoided. Turn on/off the inverter start controlling terminals (STF, STR) to run/stop the inverter.

As shown on the right, always use the start signal (ON or OFF across terminals STF or STR-SD) to make a start or stop. (Refer to page 29)

*1. When the power supply is 400V class, install a step-down transformer.



Inverter Start/Stop Circuit Example


(2) Handling of output side magnetic contactor


In principle, do not provide a magnetic contactor between the inverter and motor and switch it from off to on during operation. If it is switched on during inverter operation, a large inrush current may flow, stopping the inverter due to overcurrent shut-off. When an MC is provided for switching to the commercial power supply, for example, switch it on/off after the inverter and motor have stopped.

1.2.7 Regarding the installation of the reactor


When the inverter is installed near a large-capacity power transformer (500kVA or more with the wiring length of 10m or less) or the power capacitor is to be switched, an excessive peak current will flow in the power supply input circuit, damaging the converter circuit. In such a case, always install the reactor (FR-HEL(-H) /FR-BEL(-H) or FR-HAL(-H)/FR-BAL(-H)).

Three-phase power input





Single phase power input



REMARKS

*When connecting the FR-HEL(-H)/FR-BEL(-H), remove the jumper across terminals P-P1. The wiring length between the FR-HEL(-H)/FR-BEL(-H) and the inverter should be 5m maximum and as short as possible.

Use the cables which are equal in size to those of the main circuit. (Refer to page 8) The single-phase 100V power input model does not allow the DC reactor to be fitted.


1.2.8 Regarding noise and the installation of a noise filter

Some noise enters the inverter causing it to malfunction and others are generated by the inverter causing the malfunction of peripheral devices. Though the inverter is designed to be insusceptible to noise, it handles low-level signals, so it requires the following general countermeasures to be taken.

(1) General countermeasures

- Do not run the power cables (I/O cables) and signal cables of the inverter in parallel with each other and do not bundle them.
- Use twisted shield cables for the detector connecting and control signal cables and connect the sheathes of the shield cables to terminal SD.
- Earth (Ground) the inverter, motor, etc. at one point.
- Capacitances exist between the inverter's I/O wiring, other cables, earth (ground) and motor, through which leakage currents flow to cause the earth leakage circuit breaker, earth (ground) leakage relay and external thermal relay to operate unnecessarily. To prevent this, take appropriate measures, e.g. set the carrier frequency in Pr. 72 to a low value, use an earth (ground) leakage circuit breaker designed for suppression of harmonics and surges, and use the electronic thermal relay function built in the inverter.
- The input and output of the inverter main circuit include high-degree harmonics, which may disturb communication devices (AM radios) and sensors used near the inverter. In this case, install a FR-BIF(-H) optional capacitor type filter (for use on the input side only) or FR-BSF01 common mode filter to minimize interference.

<Noise reduction examples>



1.2.9 Earthing (Grounding) precautions

- Leakage currents flow in the inverter. To prevent an electric shock, the inverter and motor must be earthed (grounded). Earthing (Grounding) must conform to the requirements of national and local safety regulations and electrical codes. (NEC section 250, IEC 536 class 1 and other applicable standards)
- Use the dedicated earth (ground) terminal to earth (ground) the inverter. (Do not use
 the screw in the casing, chassis, etc.)
 Use a tinned* crimping terminal to connect the earth (ground) cable. When
 tightening the screw, be careful not to damage the threads.
 *Plating should not include zinc.
- Use the thickest possible earth (ground) cable. Use the cable whose size is equal to or greater than that indicated in the following table, and minimize the cable length. The earthing (grounding) point should be as near as possible to the inverter.

Motor Capacity	Earth (Ground) Cable Size (Unit: mm ²)					
motor Supacity	200V class, 100V class	400V class				
2.2kW or less	2 (2.5)	2 (2.5)				
3.7kW	3.5 (4)	2 (4)				

For use as a product compliant with the Low Voltage Directive, use PVC cable whose size is indicated within parentheses.

• Earth (Ground) the motor on the inverter side using one wire of the 4-core cable.

1.2.10 Power supply harmonics


The inverter may generate power supply harmonics from its converter circuit to affect the power generator, power capacitor etc. Power supply harmonics are different from noise and leakage currents in source, frequency band and transmission path. Take the following countermeasure suppression techniques.

● The following table indicates differences between harmonics and noise:

ltem	Harmonics	Noise
Frequency	Normally 40th to 50th degrees or less (up to 3kHz or less)	High frequency (several 10kHz to 1GHz order)
Environment	To-electric channel, power impedance	To-space, distance, wiring path
Quantitative understanding	i neoretical calculation possible	Random occurrence, quantitative grasping difficult
	Nearly proportional to load capacity	Change with current variation ratio (larger as switching speed increases)
Affected equipment immunity		Different depending on maker's equipment specifications
Suppression example	Provide reactor.	Increase distance.

Suppression technique

Harmonic currents produced on the power supply side by the inverter change with such conditions as whether there are wiring impedances and a DC reactor (FR-HEL(-H)/FR-BEL(-H)) or FR-HAL(-H)/FR-BAL(-H)) and the magnitudes of output frequency and output current on the load side.



For the output frequency and output current, we understand that they should be calculated in the conditions under the rated load at the maximum operating frequency.

CAUTION

The power factor improving capacitor and surge suppressor on the inverter output side may be overheated or damaged by the high frequency components of the inverter output. Also, since an excessive current flows in the inverter to activate overcurrent protection, do not provide a capacitor and surge suppressor on the inverter output side when the motor is driven by the inverter. To improve the power factor, insert a reactor on the inverter's primary side or DC circuit. For full information, refer to page 17.

1.2.11 Harmonic suppression guideline

Harmonic currents flow from the inverter to a power receiving point via a power transformer. The harmonic suppression guideline was established to protect other consumers from these outgoing harmonic current.

The three-phase 200V input specifications 3.7kW or less are previously covered by "Harmonic suppression guideline for household appliances and general-purpose products" and other models are covered by "Harmonic suppression guideline for consumers who receive high voltage or special high voltage". However, the general-purpose inverter has been excluded from the target products covered by "Harmonic suppression guideline for household appliances and general-purpose products" in January 2004. Later, this guideline was repealed on September 6, 2004. All capacities of all models are now target products of "Harmonic suppression guideline for consumers who receive high voltage or special high voltage" (hereinafter referred to as "Guideline for specific consumers").

"Guideline for specific consumers"

This guideline sets forth the maximum values of harmonic currents outgoing from a high-voltage or especially high-voltage consumer who will install, add or renew harmonic generating equipment. If any of the maximum values is exceeded, this guideline requires that consumer to take certain suppression measures.

Table 1 Maximum Values of Outgoing Harmonic Currents per 1kW Contract Power

Received Power Voltage	5th	7th	11th	13th	17th	19th	23rd	Over 23rd
6.6 kV	3.5	2.5	1.6	1.3	1.0	0.9	0.76	0.70
22 kV	1.8	1.3	0.82	0.69	0.53	0.47	0.39	0.36
33 kV	1.2	0.86	0.55	0.46	0.35	0.32	0.26	0.24

(1) Application of the guideline for specific consumers




Table 2 Conversion Factors for FR-S500 Series

	Conversion Factor (Ki)	
	Without reactor	K31 = 3.4
Three-phase bridge	With reactor (AC side)	K32 = 1.8
(Capacitor-smoothed)	With reactor (DC side)	K33 = 1.8
	With reactors (AC, DC sides)	K34 = 1.4
Single-phase bridge	Without reactor	K41 = 2.3
(capacitor smoothed)	With reactor (AC side)	K42 = 0.35 *

^{*} K42=0.35 is a value when the reactor value is 20%. Since a 20% reactor is large and considered to be not practical, K42=1.67 is written as conversion factor for a 5% reactor in the technical data JEM-TR201 of the Japan Electric Machine Industry Association and this value is recommended for calculation for the actual practice.

Table 3 Equivalent Capacity Limits

Received Power Voltage	Reference Capacity
6.6kV	50 kVA
22/33 kV	300 kVA
66kV or more	2000 kVA

Table 4 Harmonic Contents (Values of the fundamental current is 100%)

F	5th	7th	11th	13th	17th	19th	23rd	25th	
	Not used	65	41	8.5	7.7	4.3	3.1	2.6	1.8
Three-phase	Used (AC side)	38	14.5	7.4	3.4	3.2	1.9	1.7	1.3
bridge (capacitor	Used (DC side) or with filter pack	30	13	8.4	5.0	4.7	3.2	3.0	2.2
smoothed)	Used (AC, DC sides)	28	9.1	7.2	4.1	3.2	2.4	1.6	1.4
Single-phase	Without reactor	50	24	5.1	4.0	1.5	1.4	_	
bridge (capacitor smoothed)	With reactor (AC side) *	6.0	3.9	1.6	1.2	0.6	0.1		_

- * The harmonic contents for "single-phase bridge/with reactor" in the table 4 are values when the reactor value is 20%. Since a 20% reactor is large and considered to be not practical, harmonic contents when a 5% reactor is used is written in the technical data JEM-TR201 of the Japan Electric Machine Industry Association and this value is recommended for calculation for the actual practice.
- 1) Calculation of equivalent capacity (P0) of harmonic generating equipment
 The "equivalent capacity" is the capacity of a 6-pulse converter converted from the
 capacity of consumer's harmonic generating equipment and is calculated with the
 following equation. If the sum of equivalent capacities is higher than the limit in
 Table 3, harmonics must be calculated with the following procedure:

$P0=\Sigma$ (Ki × Pi) [kVA]

- Ki: Conversion factor (refer to Table 2)
- Pi: Input rated capacity of harmonic generating equipment* [kVA]
 - i: Number indicating the conversion circuit type
- * Input rated capacity: Determined by the capacity of the applied motor and found in Table 5. It should be noted that the rated capacity used here is used to calculate a generated harmonic amount and is different from the power supply capacity required for actual inverter drive.
- 2) Calculation of outgoing harmonic current

 Outgoing harmonic current = fundamental wave current (value converterd from received power voltage) × operation ratio × harmonic content
 - Operation ratio: Operation ratio = actual load factor × operation time ratio during 30 minutes
 - Harmonic content: Found in Table 4.

Table 5 Rated Capacities and Outgoing Harmonic Currents for Inverter Drive

Applied Motor	Ra ^s Curre	ted nt [A]	Tungamentai	Input rated capacity	Outgoing Harmonic Current Converte 6.6kV (mA) (without reactor, 100% operation)							
(kW)	200V	400V	wave input current (mA)	(kVA)	5th	7th	11th	13th	17th	19th	23rd	25th
0.4	1.61	0.81	49	0.57	31.85	20.09	4.165	3.773	2.107	1.519	1.274	0.882
0.75	2.74	1.37	83	0.97	53.95	34.03	7.055	6.391	3.569	2.573	2.158	1.494
1.5	5.50	2.75	167	1.95	108.6	68.47	14.20	12.86	7.181	5.177	4.342	3.006
2.2	7.93	3.96	240	2.81	156.0	98.40	20.40	18.48	10.32	7.440	6.240	4.320
3.7	13.0	6.50	394	4.61	257.1	161.5	33.49	30.34	16.94	12.21	10.24	7.092

3) Harmonic suppression technique requirement

If the outgoing harmonic current is higher than; maximum value per 1kW (contract power) × contract power, a harmonic suppression technique is required.

4) Harmonic suppression techniques

No.	Item	Description					
1	Reactor installation (ACL, DCL)	Install a reactor (ACL) in the AC side of the inverter or a reactor (DCL) in its DC side or both to suppress outgoing harmonic currents.					
	Installation of power factor improving capacitor	When used with a series reactor, the power factor improving capacitor has an effect of absorbing harmonic currents.					
3	Transformer multi- phase operation	Use two transformers with a phase angle difference of 30° as in \bot - Δ , Δ - Δ combination to provide an effect corresponding to 12 pulses, reducing low-degree harmonic currents.					
4	Passive (AC filter)	A capacitor and a reactor are used together to reduce impedances at specific frequencies, producing a great effect of absorbing harmonic currents.					
5	Active filter	This filter detects the current of a circuit generating a harmonic current and generates a harmonic current equivalent to a difference between that current and a fundamental wave current to suppress a harmonic current at a detection point, providing a great effect of absorbing harmonic currents.					

1.2.12 Inverter-driven 400V class motor

In the PWM type inverter, a surge voltage attributable to wiring constants is generated at the motor terminals. Especially for a 400V class motor, the surge voltage may deteriorate the insulation. When the 400V class motor is driven by the inverter, consider the following measures:

Measures

It is recommended to take either of the following measures:

(1) Rectifying the motor insulation

For the 400V class motor, use an insulation-enhanced motor. Specifically

- 1) Specify the "400V class inverter-driven, insulation-enhanced motor".
- 2) For the dedicated motor such as the constant-torque motor and low-vibration motor, use the "inverter-driven, dedicated motor".

CAUTION

When the wiring length between the motor and inverter is 40m or more, take the above countermeasure and also set the long wiring mode in Pr. 70 "Soft-PWM setting". (Refer to page 113 for Pr. 70.)


(2) Suppressing the surge voltage on the inverter side

On the secondary side of the inverter, connect the optional surge voltage suppression filter (FR-ASF-H).

1.3 How to use the control circuit terminals

1.3.1 Terminal block layout

In the control circuit of the inverter, the terminals are arranged as shown below:



1.3.2 Wiring instructions

- 1) Terminals SD, SE and 5 are common to the I/O signals isolated from each other. Do not earth (ground) them.
 - Avoid connecting the terminal SD and 5 and the terminal SE and 5.
- Use shielded or twisted cables for connection to the control circuit terminals and run them away from the main and power circuits (including the 200V relay sequence circuit).
- 3) Use two or more parallel micro-signal contacts or twin contacts to prevent contact faults when using contact inputs since the control circuit input signals are microcurrents.

*Information on bar terminals Introduced products (as of September, 2006): Phoenix Contact Co.,Ltd.

Terminal Screw Size	Bar Terminal Model (With Insulation Sleeve)	Bar Terminal Model (Without Insulation Sleeve)	Wire Size (mm²)		
M3 (A, B, C terminals)	AI 0.5-6WH	A 0.5-6	0.3 to 0.5		
IVIS (A, B, C terminals)	AI 0.75-6GY	A 0.75-6	0.5 to 0.75		
M2 (Other than the above)	AI 0.5-6WH	A 0.5-6	0.3 to 0.5		

PBar terminal crimping terminal: CRIMPFOX ZA3 (Phoenix Contact Co., Ltd.)

CAUTION


When using the bar terminal (without insulation sleeve), use care so that the twisted wires do not come out.

1.3.3 Changing the control logic

The input signals are set to sink logic.

To change the control logic, the jumper connector under the setting dial must be moved to the other position.

 Change the jumper connector position using tweezers, a pair of long-nose pliers etc.
 Change the jumper connector position before switching power on.



___ CAUTION

•Make sure that the front cover is installed securely.


•The front cover is fitted with the capacity plate and the inverter unit with the rating plate. Since these plates have the same serial numbers, always replace the removed cover onto the original inverter.

•The sink-source logic change-over jumper connector must be fitted in only one of those positions. If it is fitted in both positions at the same time, the inverter may be damaged.


1) Sink logic type


• In this logic, a signal switches on when a current flows from the corresponding signal input terminal.

Terminal SD is common to the contact input signals. Terminal SE is common to the open collector output signals.



 Use terminal PC as a common terminal, and perform wiring as shown on the right.
 (Do not connect terminal SD of the inverter with terminal 0V of the external power supply. When using terminals PC-SD as a 24VDC power supply, do not install a power supply in parallel in the outside of the inverter. Doing so may cause a malfunction due to undesirable current.)







2) Source logic type


• In this logic, a signal switches on when a current flows into the corresponding signal input terminal.

Terminal PC is common to the contact input signals. For the open collector output signals, terminal SE is a positive external power supply terminal.





 Use terminal SD as a common terminal, and perform wiring as shown on the right.
 (Do not connect terminal PC of the inverter with terminal +24V of the external power supply. When using terminals PC-SD as a 24VDC power supply, do not install an external power supply in parallel with the inverter. Doing so may cause a malfunction in the inverter due to undesirable currents.)



1.4 Input terminals


1.4.1 Run (start) and stop (STF, STR, STOP)

To start and stop the motor, first switch on the input power supply of the inverter to turn on the magnetic contactor at the operation-ready when there is a magnetic contactor on the input side, then start the motor with the forward or reverse rotation start signal.

(1) Two-wire type connection (STF, STR)

A two-wire type connection is shown on the right.

- The forward/reverse rotation signal is used as both the start and stop signals. Switch on either of the forward and reverse rotation signals to start the motor in the corresponding direction. Switch on both or switch off the start signal during operation to decelerate the inverter to a stop.
- 2) The frequency setting signal may either be given by entering 0 to 5VDC (or 0 to 10VDC) across frequency setting input terminals 2-5 or by setting the required values in Pr. 4 to Pr. 6 "multispeed setting" (high, middle, low speeds). (For multi-speed operation, refer to page 33.)




- 3) After the start signal has been input, the inverter starts operating when the frequency setting signal reaches or exceeds the "starting frequency" set in Pr. 13 (factory-set to 0.5Hz).
 - If the motor load torque is large or the "torque boost" set in Pr. 0 is small, operation may not be started due to insufficient torque until the inverter output frequency reaches about 3 to 6Hz.
 - If the "minimum frequency" set in Pr. 2 (factory setting = 0Hz) is 6Hz, for example, merely entering the start signal causes the running frequency to reach the minimum frequency of 6Hz according to the "acceleration time" set in Pr. 7.
- 4) To stop the motor, operate the DC injection brake for the period of "DC injection brake operation time" set in Pr. 11 (factory setting = 0.5s) at not more than the DC injection brake operation frequency or at not more than 0.5Hz.
 - To disable the DC injection brake function, set 0 in either of Pr. 11 "DC injection brake operation time" or Pr. 12 "DC injection brake voltage".
 - In this case, the motor is coasted to a stop at not more than the frequency set in Pr. 10 "DC injection brake operation frequency" (0 to 120Hz variable) or at not more than 0.5Hz (when the DC injection brake is not operated).
- 5) If the reverse rotation signal is input during forward rotation or the forward rotation signal is input during reverse rotation, the inverter is decelerated and then switched to the opposite output without going through the stop mode.


DC Injection Brake and Coasting to Stop Functionality

Operation Mode	Oper Pr. 79 = "0	ion or Combined ration)", "2", "3"	PU Operation or Combined Operation Pr. 79 = "0", "1", "4"		
DC Injection Brake	Terminals STF (STR)-SD disconnected (*1)	Set frequency changed to 0Hz	Stop key	Set frequency changed to 0Hz	
DC injection brake enabled	DC injection brake operated at not more than "DC injection brake operation frequency" set in Pr. 10		injection brake	DC injection brake operated at 0.5Hz or less.	
DC injection brake disabled		at 0.5Hz or less.		Coasted to a stop at 0.5Hz or less.	

^{*1:} Also stopped by the $\frac{\text{STOP}}{\text{RESET}}$. Refer to page 115.



Start/Stop Timing Chart (for two-wire type)



Forward-Reverse Rotation Switch-Over Timing Chart


REMARKS

- *1. The "starting frequency" in Pr. 13 (factory-set to 0.5Hz) may be set between 0 and 60Hz.
- *2. If the next start signal is given during DC injection brake operation, the DC injection brake is disabled and restart is made.
- *3. The "DC injection brake operation time" in Pr. 11 (factory-set to 0.5s) may be set between 0 and 10s.
- *4. The frequency at which the motor is coasted to a stop is not more than the "DC injection brake operation frequency" set in Pr. 10 (factory setting = 3Hz; may be set between 0 and 120Hz) or not more than 0.5Hz.
- *5. The "starting frequency" in Pr. 13, "DC injection brake operation time" in Pr. 11 and "DC injection brake operation frequency" in Pr. 10 are the factory-set values.

(2) Three-wire type connection (STF, STR, STOP)

A three-wire type connection is shown on the right. Assign the start self-holding signal (STOP) to any of the input terminals. To make a reverse rotation start, set Pr. 63 to "- - -" (factory setting).

- Turning the STOP signal on makes start self-holding function valid. In this case, the forward/reverse rotation signal functions only as a start signal. (Note) Assign the stop signal to any of Pr. 60 to Pr. 62 (input terminal function selection).
- Even if the start signal STF (STR) is turned on once then off, the start signal is kept on and starts the inverter. When changing the direction of rotation, turn the start signal STR (STF) on once and then off.
- 3) To stop the inverter, turning off the STOP signal once decelerates it to a stop. For the frequency setting signal and the operation of DC injection brake at a stop time, refer to paragraphs 2) to 4) in (1) Two-wire type connection. The right diagram shows 3-wire type connection.




- 4) When the JOG signal is on, the STOP signal is invalid and the JOG signal has precedence.
- 5) When the output stop signal MRS is turned on, the inverter output is shutoff. However, self-holding function is not deactivated and the start signal is held.

1.4.2 Connection of frequency setting potentiometer and output frequency meter (10, 2, 5, 4, AU)

The analog frequency setting input signals that may be entered are voltage and current signals.

For the relationships between the frequency setting input voltages (currents) and output frequencies, refer to the following diagram. The frequency setting input signals are proportional to the output frequencies. Note that when the input signal is less than the starting frequency, the output frequency of the inverter is 0Hz.

If the input signal of 5VDC (or 10V, 20mA) or higher is entered, the output frequency does not exceed the maximum output frequency.



Relationships between Frequency Setting Inputs and Output Frequencies

REMARKS

For the way to calibrate the output frequency meter, refer to page 138.

(1) Voltage input (10, 2, 5)

Enter the frequency setting input signal of 0 to 5VDC (or 0 to 10VDC) across the frequency setting input terminals 2-5. The maximum output frequency is reached when 5V (10V) is input across terminals 2-5.

The power supply used may either be the inverter's built-in power supply or an external power supply. For the built-in power supply, terminals 10-5 provide 5VDC output.

● For operation at 0 to 5VDC, set "0" in Pr. 73 to the 0 to 5VDC input. Use terminal 10 for the built-in power supply.


● For operation at 0 to 10VDC, set "1" in Pr. 73 to the 0 to 10VDC input.

(2) Current input (4, 5, AU)

To automatically perform operation under constant pressure or temperature control using a fan, pump etc., enter the controller output signal of 4 to 20mADC across terminals 4-5.

Terminals AU-SD must be shorted to use the 4 to 20mADC signal for operation. (Assign the signal AU using any of Pr. 60 to Pr. 63.)

When the multi-speed signal is input, the current input is ignored.



Manual-Automatic Switching


1.4.3 External frequency selection (REX, RH, RM, RL)


Up to 15 speeds (*) may be selected for an external command forward rotation start or up to 7 speeds for an external command reverse rotation start according to the combination of connecting the multi-speed select terminals REX, RH, RM and RL-SD, and multi-speed operation can be performed as shown below by shorting the start signal terminal STF (STR)-SD.

Speeds (frequencies) may be specified as desired from the operation panel or parameter unit as listed below.

CAUTION

 * Change the setting of Pr. 63 "STR terminal function selection" to "8", and assign and use as the 15-speed select signal (REX).
 Has precedence over the main speed setting signal (0 to 5V, 0 to 10V, 4 to 20mADC).






Multi-Speed Setting

	To	ermin	al Inpi	ut		Set Frequency			
Speed	REX-	RH-	RM-	RL-	Parameter	Range	Remarks		
Speed 1	SD*	SD	SD	SD*		. 3			
(high	OFF	ON	OFF	OFF	Pr. 4	0 to 120Hz			
speed)	Oii	ON	011	011	F1. 4	0 10 120112			
Speed 2									
(middle	OFF	OFF	ON	OFF	Pr. 5	0 to 120Hz			
speed)									
Speed 3									
(low	OFF	OFF	OFF	ON	Pr. 6	0 to 120Hz			
speed)	~==								
Speed 4		OFF	ON	ON	Pr. 24		Pr. 6 setting when Pr. 24=""		
Speed 5	OFF	ON	OFF	ON	Pr. 25		Pr. 6 setting when Pr. 25=""		
Speed 6	OFF	ON	ON	OFF	Pr. 26		Pr. 5 setting when Pr. 26=""		
Speed 7	OFF	ON	ON	ON	Pr. 27		Pr. 6 setting when Pr. 27=""		
Speed 8	ON	OFF	OFF	OFF	Pr. 80		0Hz when Pr. 80=""		
Speed 9	ON	OFF	OFF	ON	Pr. 81	0 to 120Hz,	Pr. 6 setting when Pr. 81=""		
Speed 10	ON	OFF	ON	OFF	Pr. 82	0 10 120112,	Pr. 5 setting when Pr. 82=""		
Speed 11	ON	OFF	ON	ON	Pr. 83		Pr. 6 setting when Pr. 83=""		
Speed 12	ON	ON	OFF	OFF	Pr. 84		Pr. 4 setting when Pr. 84=""		
Speed 13		ON	OFF	ON	Pr. 85		Pr. 6 setting when Pr. 85=""		
Speed 14	ON	ON	ON	OFF	Pr. 86		Pr. 5 setting when Pr. 86=""		
Speed 15	ON	ON	ON	ON	Pr. 87		Pr. 6 setting when Pr. 87=""		
External	OFF	OFF	OFF	OFF	Frequency setting	0 to max. setting			
setting	011	011	011	011	potentiometer				

^{*}When using the REX signal, an external command cannot be used to make a reverse rotation start.



Multi-Speed Operation Connection Example

REMARKS


- *1. When the frequency setting potentiometer is connected, the input signal of the frequency setting potentiometer is ignored if the multi-speed select signal is switched on. (This also applies to the 4 to 20mA input signal.)
- *2. For a reverse rotation start, set Pr. 63 to "- -" (factory setting) to make the STR signal of terminal STR valid.

1.4.4 Indicator connection and adjustment (FM)

The output frequency, etc. of the inverter can be indicated by a DC ammeter of 1mA full-scale deflection and maximum 300Ω internal resistance or a commercially available digital indicator which is connected across terminals FM-SD.

The indicator can be calibrated from the operation panel or parameter unit. Note that the reading varies according to the wiring distance if the indicator is placed away from the inverter. In this case, connect a calibration resistor in series with the indicator as shown below and adjust until the reading matches the operation panel or parameter unit indicator (indicator monitoring mode).

Install the indicator within 200m (50m for the digital indicator) of the inverter and connect them by at least 0.3mm² twisted or shielded cables.



REMARKS

* Not needed when calibration is made using the calibration parameter C1 "FM terminal calibration". This resistor is used when calibration must be made near the frequency meter for such a reason as a remote frequency meter. Note that the needle of the frequency meter may not deflect to full-scale when the calibration resistor is connected. In this case, use both the resistor and calibration parameter "C1".

CAUTION

•Refer to page 138 for the procedure of indicator adjustment.

Output waveform of terminal FM

The output signal of terminal FM has a pulse waveform as shown in the table below and the number of its pulses is proportional to the inverter output frequency.

The output voltage (average voltage) is also proportional to the output frequency.

Terminal FM Output Voltage

	Specifications	Inverter
Output waveform	Calibration parameter C1 (Pr. 900)	→ 24V
	Max. 2400 pulses/s	
Number of	Set a full-scale value which	★ J sd _ l
output	achieves 1440 pulses/s.	, , , , , , , , , , , , , , , , , , ,
pulses	Pr. 55: frequency monitoring	
(pulses/	reference	[M
second)	Pr. 56: current monitoring	Example of Inverter and Frequency
	reference	Meter
Output	0 to 8VDC max. (*1)	
voltage	(Approx. 5V at 1440 pulses/s)	

^{*1.} 0.5V or less when a DC ammeter of 300Ω or less internal resistance is connected to measure the output voltage.

Adjustment

Analog meter

To adjust the reading of an analog indicator (ammeter), turn the calibration resistor to change the current.

When using the operation panel or parameter unit for adjustment, change the pulse width of the output waveform (calibration parameter "C1") (adjust the current through the adjustment of the output voltage) to adjust the reading. (For details, refer to page 138.)

REMARKS

It is not recommended to use a voltage type indicator because it is easily affected by a voltage drop, induction noise, etc. and may not provide correct reading if the wiring distance is long.

Digital indicator

Since the digital indicator counts and displays the number of pulses, adjust it from the operation panel or parameter unit.

The inverter output, at which the reference pulses of 1440 pulses/s are output, can be set in Pr. 55 when frequency monitoring is used as reference, or in Pr. 56 when current monitoring is used as reference.

- [Example] 1. To set the output across FM-SD to 1440 pulses/s at the inverter output frequency of 120Hz, set "120" (Hz) in Pr. 55. (Factory setting: 60Hz)
 - To set the output across FM-SD to 1440 pulses/s at the inverter output current of 15A, set "15" (A) in Pr. 56. (Factory setting: rated inverter current)

1.4.5 Control circuit common terminals (SD, 5, SE)

Terminals SD, 5, and SE are all common terminals (0V) for I/O signals and are isolated from each other.


Terminal SD is a common terminal for the contact input terminals (STF, STR, RH, RM, RL) and frequency output signal (FM).

Terminal 5 is a common terminal for the frequency setting analog input signals. It should be protected from external noise using a shielded or twisted cable.

Terminal SE is a common terminal for the open collector output terminal (RUN).

1.4.6 Signal inputs by contactless switches

If a transistor is used instead of a contacted switch as shown on the right, the input signals of the inverter can control terminals STF, STR, RH, RM, RL.



External signal input using transistor

REMARKS

- 1. When using an external transistor connected to an external power supply, use terminal PC to prevent a malfunctions due to undesirable currents. (Refer to page 27.)
- 2.Note that an SSR (solid-state relay) has a relatively large leakage current at OFF time and it may be accidentally input to the inverter.

1.5 How to use the input signals (assigned terminals RL, RM, RH, STR)

These terminals can be changed in function by setting Pr. 60 to Pr. 63.

Pr. 60 "RL terminal function selection"	
Pr. 61 "RM terminal function selection"	Page 108
Pr. 62 "RH terminal function selection"	rage 100
Pr. 63 "STR terminal function selection"	

1.5.1 Multi-speed setting (RL, RM, RH, REX signals):

Pr. 60 to Pr. 63 setting "0, 1, 2, 8"

Remote setting (RL, RM, RH signals):


Pr. 60 to Pr. 63 setting "0, 1, 2"

- By entering frequency commands into the RL, RM, RH and REX signals and turning on/off the corresponding signals, you can perform multi-speed operation (15 speeds). (For details, refer to page 33.)
- If the operation panel is away from the enclosure, you can perform continuous variable-speed operation with signal contacts, without using analog signals. (For details, refer to page 104.)

1.5.2 Second function selection (RT signal): Pr. 60 to Pr. 63 setting "3"

1.5.3 Current input selection "AU signal": Pr. 60 to Pr. 63 setting "4"

When a fan, pump etc. is used to perform operation of constant- pressure/ temperature control, automatic operation can be performed by entering the 4-20mADC output signal of a regulator into across terminals 4-5.



When the 4-20mADC signal is used to perform operation, always short the AU signal.


REMARKS

The current input is ignored if the multi-speed signal is input.

1.5.4 Start self-holding selection (STOP signal): Pr. 60 to Pr. 63 setting "5"

This connection example is used when you want to self-hold the start signal (forward rotation, reverse rotation).

* Connected to the STOP signal to avoid forward or reverse rotation if forward or reverse rotation and stop are turned on simultaneously.



(Wiring example for sink logic)

1.5.5 Output shut-off (MRS signal): Pr. 60 to Pr. 63 setting "6"


Short the output stop terminal MRS-SD during inverter output to cause the inverter to immediately stop the output. Open terminals MRS-SD to resume operation in about 10ms. Terminal MRS may be used as described below:

(1) To stop the motor by mechanical brake (e.g. electromagnetic brake)

Terminals MRS-SD must be shorted when mechanical brake is operated and be opened before the motor that has stopped restarts.

(2) To provide interlock to disable operation by the inverter

After MRS-SD have been shorted, the inverter cannot be operated if the start signal is given to the inverter.




(3) To coast the motor to stop

The motor is decelerated according to the preset deceleration time and is stopped by operating the DC injection brake at 3Hz or less. By using terminal MRS, the motor is coasted to a stop.

1.5.6 External thermal relay input: Pr. 60 to Pr. 63 setting "7"

When the external thermal relay or built-in thermal relay of the motor (thermal relay protector,etc.) is actuated to protect the motor from overheating, the inverter output can shutoff and the corresponding alarm signal can be outputted to hold at the stop status. Even if the thermal relay contact resets, the motor cannot be restarted unless the reset terminals RES-SD are shorted for more than 0.1s and then opened or a power-on reset is made. The function may therefore be used as an external emergency stop signal input.




1.5.7 Jog operation (JOG signal): Pr. 60 to Pr. 63 setting "9"

(1) Jog operation using external signals

Jog operation can be started/stopped by shorting the jog mode select terminals JOG-SD and shorting/opening the start signal terminals STF or STR-SD. The jog frequency and jog acceleration/deceleration time are set in Pr. 15 (factory setting 5Hz, variable between 0 and 120Hz) and Pr. 16 (factory setting 0.5s, variable between 0 and 999s), respectively, and their settings can be changed from the operation panel or parameter unit.

The JOG signal has precedence over the multi-speed signal. (External)



1.5.8 Reset signal: Pr. 60 to Pr. 63 setting "10"


Used to reset the alarm stop state established when the inverter's protective function is activated. The reset signal immediately sets the control circuit to the initial (cold) status, e.g. initializes the electronic thermal relay function protection circuit. It shuts off the inverter output at the same time. During reset, the inverter output is kept shut off. To give this reset input, short terminals RES-SD for more than 0.1s. When the shorting time is long, the operation panel or parameter unit displays the initial screen, which is not a fault.

After opening terminals RES-SD (about 1s), operation is enabled.

The reset terminal is used to reset the inverter alarm stop state. If the reset terminal is shorted, then opened while the inverter is running, the motor may be restarted during coasting (refer to the timing chart below) and the output may be shut off due to overcurrent or overvoltage.

Setting either "1" or "15" in reset selection Pr. 75 allows the accidental input of the reset signal during operation to be ignored.

(For details, refer to page 115.)



CAUTION

Frequent resetting will make electronic thermal relay function invalid.

1.5.9 PID control valid terminal: Pr. 60 to Pr. 63 setting "14"

To exercise PID control, turn on the X14 signal. When this signal is off, ordinary inverter operation is performed. For more information, refer to page 123.

- ◆ Related parameters ◆ -

Pr. 88 "PID action selection", Pr. 89 "PID proportional band", Pr. 90 "PID integral time", Pr. 91 "PID upper limit", Pr. 92 "PID lower limit", Pr. 93 "PID action set point for PU operation", Pr. 94 "PID differential time" (Refer to page 123.)

1.5.10 PU operation/external operation switchover: Pr. 60 to Pr. 63 setting "16"

You can change the operation mode.

With "8" set in Pr. 79 "operation mode selection", turning on the X16 signal shifts the operation mode to the external operation mode and turning off the X16 signal shifts it to the PU operation mode. For details, refer to page 119.

→ Related parameters → -

Pr. 79 "operation mode selection" (Refer to page 119.)

1.6 Connection to the stand-alone option


The inverter accepts a variety of stand-alone option units as required. Incorrect connection will cause inverter damage or accident. Connect and operate the option unit carefully in accordance with the corresponding option unit manual.

1.6.1 Connection of the dedicated external brake resistor (option) (FR-S520E-0.4K to 3.7K only)

REMARKS

A dedicated external brake resistor can be connected to the FR-S520E-0.4K to 3.7K.

Connect a brake resistor across terminals P/+ and PR. Connect a dedicated brake resistor only. (For the locations of terminals P/+ and PR, refer to the terminal block layout (page 6).)




CAUTION

If the transistors in the inverter should become faulty, the resistor can be unusually hot, causing a fire. Therefore, install a magnetic contactor (MC) on the inverter's power supply side to configure a circuit so that a current is shut off in case of fault.

(For connection of the electro magnetic contactor, refer to page 16.)

1.6.2 Connection of the brake unit (BU type)

Connect the BU type brake unit correctly as shown below. Incorrect connection will damage the inverter. Remove jumpers across terminals HB-PC and TB-HC and connect a jumper across terminals PC-TB of the brake unit.




CAUTION

- The wiring distance between the inverter, brake unit and discharge resistor should be within 2m. If twisted wires are used, the distance should be within 5m.
- 2. If the transistors in the brake unit should become faulty, the resistor can be unusually hot, causing a fire. Therefore, install a magnetic contactor on the inverter's power supply side to configure a circuit so that a current is shut off in case of fault.
- 3. The N terminal is not provided for the FR-S520E-0.1K to 0.75K.
- 4. When the power supply is 400V class, install a step-down transformer.
- Do not remove a jumper across terminal P/+ and P1 except when connecting a DC reactor.

1.6.3 Connection of the high power factor converter (FR-HC)

When connecting the high power factor converter (FR-HC) to suppress power supply harmonics, perform wiring securely as shown below. Incorrect connection will damage the high power factor converter and inverter.




CAUTION

- 1. Use sink logic (factory setting) when the FR-HC is connected. The FR-HC cannot be connected when source logic is selected.
- 2. The power input terminals R, S, T must be open. Incorrect connection will damage the inverter.
- 3. The voltage phases of terminals R, S, T and terminals R4, S4, T4 must be matched before connection.
- 4. Use Pr. 60 to Pr. 63 (input terminal function selection) to assign the terminals used for the RES and MRS signals.
- 5. Do not insert MCCB between terminals P-N (P P, N N). Opposite polarity of terminals N, P will damage the inverter.
- 6. The N terminal is not provided for the FR-S520E-0.1K to 0.75K.
- Do not remove a jumper across terminal P/+ and P1 except when connecting a DC reactor.

1.6.4 Connection of the power regeneration common converter (FR-CV)

When connecting the FR-CV type power regeneration common converter, connect the inverter terminals (P, N) and FR-CV type power regeneration common converter terminals as shown below so that their signals match with each other.




CAUTION

- Use sink logic (factory setting) when the FR-CV is connected. The FR-CV cannot be connected when source logic is selected.
- The power input terminals R, S, T must be open. Incorrect connection will damage the inverter.
- 3. The voltage phases of terminals R/L11, S/L21, T/MC1 and terminals R2/L1, S2/L2, T2/L3 must be matched before connection.
- 4. Use Pr. 60 to Pr. 63 (input terminal function selection) to assign the terminals used for the RES and MRS signals.
- 5. Do not insert MCCB between terminals P-N (P/L+ P, N/L- N). Opposite polarity of terminals N, P will damage the inverter.
- Make sure to connect the terminal R/L11, S/L21, T/MC1 to the power supply. Running the inverter without connecting the terminals will damage the power regeneration common converter.
- 7. The N terminal is not provided for the FR-S520E-0.1K to 0.75K.
- Do not remove a jumper across terminal P/+ and P1 except when connecting a DC reactor.

1.7 Handling of the RS-485 connector

<RS-485 connector pin layout> View A of the inverter (receptacle side)



CAUTION

- 1. Do not plug the connector to a computer LAN port, fax modem socket, telephone modular connector etc. The product could be damaged due to differences in electrical specifications.
- 2. Pins 2 and 8 (P5S) are provided for the parameter unit power supply. Do not use them for any other purpose or when making parallel connection by RS-485 communication.
- 3. Refer to page 144 for the communication parameters.

1.7.1 Connection of the parameter unit (FR-PU04)

When connecting the parameter unit to the RS-485 connector, use the optional parameter unit connection cable (FR-CB2□□).

CAUTION =

When the parameter unit is used, the operation other than the stop key $(\stackrel{\text{STOP}}{\text{RESET}})$ of the operation panel is disabled.

Refer to page 164 for the parameters related to parameter unit setting.

1.7.2 Wiring of RS-485 communication

Use the RS-485 connector to perform communication operation from a personal computer etc.


When the RS-485 connector is connected with a personal, FA or other computer by a communication cable, a user program can run and monitor the inverter or read and write to the parameters. For parameter setting, refer to page 142.

- Conforming standard: EIA-485 (RS-485)
- Transmission format: Multidrop link
- •Communication speed: Max. 19200bps
- Overall extension: 500m

Refer to page 142 for the setting related to RS-485 communication operation.

<System configuration examples>

(1) Connection of a computer to the inverter (1:1 connection)



Computer-inverter connection cable

Refer to the following for the cable (RS-232C \Leftrightarrow RS-485 converter) for connection of the computer having the RS-232C interface with the inverter.

Example of product available on the market (as of September, 2006)

Model	Maker
FA-T-RS40□*	Mitsubishi Electric Engineering Co., Ltd.


^{*}The converter cable cannot connect two or more inverters (the computer and inverter are connected on a 1:1 basis). Since the product is packed with the RS-232C cable and RS-485 cable (10BASE-T + RJ-45 connector), the cable and connector need not be prepared separately.

REMARKS

Refer to the following when fabricating the cable on the user side. Example of product available on the market (as of September, 2006)

	Product	Model	Maker		
1)	10BASE-T cable	SGLPEV-T 0.5mm × 4P * Do not use pins No. 2, 8 (P5S).	Mitsubishi Cable Industries, Ltd.		
2)	RJ-45 connector	5-554720-3	Tyco Electronics Corporation		

(2) Combination of computer and multiple inverters (1:n connection)



REMARKS


Refer to the following when fabricating the cable on the user side. Example of product available on the market (as of September, 2006)

	Product	Model	Maker
1)	10BASE-T cable	SGLPEV-T 0.5mm × 4P*	Mitsubishi Cable Industries, Ltd.
2)	RJ-45 connector	5-554720-3	Tyco Electronics Corporation


^{*} Do not use pins No. 2, 8 (P5S) of the 10BASE-T cable.

<Wiring methods>

1) Wiring of one RS-485 computer and one inverter



2) Wiring of one RS-485 computer and "n" inverters (several inverters)




REMARKS

- *1. Make connection in accordance with the instruction manual of the computer to be used with. Fully check the terminal numbers of the computer since they change with the model.
- *2. The inverters may be affected by reflection depending on the transmission speed or transmission distance. If this reflection hinders communication, provide a terminating resistor. When the RS-485 connector is used for connection, a terminating resistor cannot be fitted, so use a distributor. Connect the terminating resistor to only the inverter remotest from the computer. (Terminating resistor: 100Ω)

1.8 Design information

- 1) Provide electrical and mechanical interlocks for MC1 and MC2 which are used for bypass operation.
 - When the wiring is incorrect and if there is a bypass operation circuit as shown below, the inverter will be damaged by leakage current from the power supply due to arcs generated at the time of switch-over or chattering caused by a sequence error.
- 2) If the machine must not be restarted when power is restored after a power failure, provide a magnetic contactor in the inverter's primary side and also make up a sequence which will not switch on the start signal.
 - If the start signal (start switch) remains on after a power failure, the inverter will automatically restart as soon as the power is restored.
- Use two or more parallel micro-signal contacts or twin contacts to prevent a contact fault when using contact inputs since the control circuit input signals are microcurrents.
- 4) Do not apply a large voltage to the contact input terminals (e.g. STF) to the control circuit.
- 5) Always apply a voltage to the alarm output terminals (A, B, C) via a relay coil, lamp etc.
- 6) Make sure that the specifications and rating match the system requirements.



1.9 Failsafe of the system which uses the inverter

When a fault occurs, the inverter trips to output an alarm. However, an alarm output signal may not be output at an inverter alarm occurrence when the detection circuit or output circuit fails, etc. Although Mitsubishi assures best quality products, provide an interlock which uses inverter status output signals to prevent accidents such as damage to machine when the inverter fails for some reason and at the same time consider the system configuration where failsafe from outside the inverter, without using the inverter, is enabled even if the inverter fails.


(1) Interlock method which uses the inverter status output signals By combining the inverter status output signals to provide an interlock as shown below, an inverter alarm can be detected.

No	Interlock Method	Interlock Method Check Method		Refer to Page	
1)	•		Alarm output signal (ABC signal)	110	
2)	Inverter running status	Operation ready signal (RY signal)		110	
3)	Inverter running status	a I signal and rilling I .		29, 110	
4)	Inverter running status Logic check of the start signal and output current		Start signal (STF signal, STR signal) Output current detection signal (Y12 signal)	29, 97, 110	

Check by the inverter alarm output signal


When the inverter protective function is activated to stop the inverter output, the alarm output signal (ABC at NC contact) signal) is output (ABC signal is assigned to terminal ABC in the initial setting).

Check that the inverter functions properly.



2) Checking the inverter operating status power by the inverter operation ready completion signal Operation ready signal (RY signal) is output when the inverter power is on and the inverter becomes operative.

Check if the RY signal is output after powering on the inverter.



 Checking the inverter operating status by the start signal input to the inverter and inverter running signal.

The inverter running signal (RUN signal) is output when the inverter is running (RUN signal is assigned to terminal RUN in the initial setting).

Check if RUN signal is output when inputting the start signal to the inverter (forward signal is STF signal and reverse signal is STR signal). For logic check, note that RUN signal is output for the period from the inverter decelerates until output to the motor is stopped, configure a sequence considering the inverter deceleration time

4) Checking the motor operating status by the start signal input to the inverter and inverter output current detection signal.

The output current detection signal (Y12 signal) is output when the inverter operates and currents flows in the motor. Check if Y12 signal is output when inputting the start signal to the inverter (forward signal is STF signal and reverse signal is STR signal). Note that the current level at which Y12 signal is output is set to 150% of the inverter rated current in the initial setting, it is necessary to adjust the level to around 20% using no load current of the motor as reference with Pr. 48 "output current detection level".

For logic check, as same as the inverter running signal (RUN signal), the inverter outputs for the period from the inverter decelerates until output to the motor is stopped, configure a sequence considering the inverter deceleration time.

Output signal	Pr. 64 and Pr. 65 Setting
ABC	99
RY	11
RUN	0
Y12	12

 When using various signals, assign functions to Pr. 64 and Pr. 65 (output terminal function selection) referring to the table on the left.

CAUTION

•Changing the terminal assignment using Pr. 64 and Pr. 65 (output terminal function selection) may affect the other functions. Make setting after confirming the function of each terminal.

(2) Backup method outside the inverter

Even if the interlock is provided by the inverter status signal, enough failsafe is not ensured depending on the failure status of the inverter itself. For example, even if the interlock is provided using the inverter alarm output signal, start signal and RUN signal output, there is a case where an alarm output signal is not output and RUN signal is kept output even if an inverter alarm occurs.


Provide a speed detector to detect the motor speed and current detector to detect the motor current and consider the backup system such as checking up as below according to the level of importance of the system.

1) Start signal and actual operation check

Check the motor running and motor current while the start signal is input to the inverter by comparing the start signal to the inverter and detected speed of the speed detector or detected current of the current detector. Note that the motor current runs as the motor is running for the period until the motor stops since the inverter starts decelerating even if the start signal turns off. For the logic check, configure a sequence considering the inverter deceleration time. In addition, it is recommended to check the three-phase current when using the current detector.

2) Command speed and actual operation check

Check if there is no gap between the actual speed and commanded speed by comparing the inverter speed command and detected speed of the speed detector.



2. FUNCTIONS

This chapter explains the "functions" for use of this product. For simple variable-speed operation of the inverter, the factory settings of the parameters may be used as they are. Set the necessary parameters to meet the load and operational specifications. Refer to the instruction manual (basic) for the operation procedures. Always read the instructions before using the functions.

2.1	Function (Parameter) list	56
2.2	List of parameters classified by purpose of use	69
2.3	Explanation of functions (parameters)	71
2.4	Output terminal function	95
2.5	Current detection function	97
2.6	Display function	99
2.7	Restart operation function	101
2.8	Additional function	104
2.9	Terminal function selection	108
2.10	Operation selection function	111
2.11	Auxiliary function	131
2.12	Maintenance function	133
2.13	Brake parameters (FR-S520E-0.4K to 3.7K only)	137
2.14	Calibration parameters	138
2.15	Clear parameters	141
2.16	Communication parameters	142
2.17	Parameter unit (FR-PU04) setting	164

Chapter 1

CAUTION

As the contact input terminals RL, RM, RH, STR, open collector output terminal RUN and contact output terminals A, B, C can be changed in functions by parameter setting, their signal names used for the corresponding functions are used in this chapter (with the exception of connection diagram). Note that they are not terminal names.

Chapter 2

REMARKS

Parameter copy

Use of the parameter unit (FR-PU04) allows the parameter values to be copied to another FR-S500 series inverter. After batch-reading the parameters of the copy source inverter, you can connect the parameter unit to the copy destination inverter and batch-write the parameters.

For the operation procedure, refer to the instruction manual of the parameter unit (FR-PU04).

Chapter 3

Chapter 4

2.1 Function (Parameter) list

- CAUTION -

indicates that the setting can be changed during operation if Pr. 77 "parameter write disable selection" has been set to "0" (factory setting). (Note that the Pr. 53, Pr. 70 and Pr. 72 values can be changed only during PU operation.)

Parameter	Indica- tion						Name	Setting Range	Minimum Setting Increments	Factory Setting	Refer To:	Cus- tomer Setting
0	P 0		Torque boost	0 to 15%	0.1%	6%/5%/ 4% (*1)	71					
1	P	;	Maximum frequency	0 to 120Hz	0.1Hz	60Hz	72					
2	ρ.	2	Minimum frequency	0 to 120Hz	0.1Hz	0Hz	72					
3	ρ	3	Base frequency	0 to 120Hz	0.1Hz	60Hz	73					
4	РЧ		Multi-speed setting (high speed)	0 to 120Hz	0.1Hz	60Hz	75					
5	٩	5	Multi-speed setting (middle speed)	0 to 120Hz	0.1Hz	30Hz	75					
6	Р 6		Multi-speed setting (low speed)	0 to 120Hz	0.1Hz	10Hz	75					
7	ρ.	7	Acceleration time	0 to 999s	0.1s	5s	76					
8	P	8	Deceleration time	0 to 999s	0.1s	5s	76					
9	Р 9		Electronic thermal O/L relay	0 to 50A	0.1A	Rated inverter current	78					
30	P30		Extended function display selection	0, 1	1	0	89					
79	P7	9	Operation mode selection	0 to 4, 7, 8	1	0	119					

^{*1.} The factory setting varies with the inverter capacity: 5% for FR-S540E-1.5K and 2.2K, 4% for FR-S540E-3.7K.

The extended function parameters are made valid by setting "1" in Pr. 30 "extended function display selection". (For more detailed information on the way to set Pr. 30, refer to the instruction manual (basic).)

	Para- meter	Indica- tion		Name		Increments	Factory Setting	To:	Cus- tomer Setting		
		_	_		Parameters 0 to 9 are basic function parameters.						
	10	ρ _		DC injection brake operation frequency	0 to 120Hz	0.1Hz	3Hz	80			
	11	,	11	DC injection brake operation time	0 to 10s	0.1s	0.5s	80			
	12	P	IC	brake voltage	0 to 15%	0.1%	6%	80			
	13	ļρ	13	Starting frequency	0 to 60Hz	0.1Hz	0.5Hz	81			
8	14		17		For constant-torque loads, For reduced-torque loads, For vertical lift loads, For vertical lift loads	1	0	82			
ion	15	ΙĒ	15	Jog frequency	0 to 120Hz	0.1Hz	5Hz	83			
Standard operation functions	16		18	Jog acceleration/ deceleration time	0 to 999s	0.1s	0.5s	83			
ndard oper	17	P	ויו	RUN key rotation direction selection	0: Forward rotation, 1: Reverse rotation	1	0	83			
Star	19	Įρ	/9	voilage	0 to 800V, 888,	1V		73			
	20	ρ_{ϵ}		Acceleration/ deceleration reference frequency	1 to 120Hz	0.1Hz	60Hz	76			
	21	ρ_{ϵ}	2!	selection	0 to 31, 100	1	0	84			
	22	_Ρ ,	22	Stall prevention operation level	0 to 200%	1%	150%	86			
	23	ρ _ι	23	Stall prevention operation level compensation factor at double speed	0 to 200%,	1%		86			

Func- tion	Para- meter	Indica- tion	Name	Setting Range	Minimum Setting Increments	Factory Setting	Refer To:	Cus- tomer Setting		
	24	P24	Multi-speed setting (speed 4)	0 to 120Hz,	0.1Hz		75			
	25	P25	Multi-speed setting (speed 5)	0 to 120Hz,	0.1Hz		75			
	26	P26	Multi-speed setting (speed 6)	0 to 120Hz,	0.1Hz		75			
	27	P27	Multi-speed setting (speed 7)	0 to 120Hz,	0.1Hz		75			
	28	P28	Stall prevention operation reduction starting frequency	0 to 120Hz	0.1Hz	60Hz	86			
Standard operation functions	29	P29	Acceleration/ deceleration pattern	C: Linear acceleration/ deceleration, S-pattern acceleration/ deceleration A, S-pattern acceleration/ deceleration B	1	0	88			
era	Parameter 30 is basic function parameter.									
rd op	31	P3 !	Frequency jump 1A	0 to 120Hz,	0.1Hz		89			
anda	32	730	Frequency jump 1B	0 to 120Hz,	0.1Hz		89			
₹	33	P33	Frequency jump 2A	0 to 120Hz,	0.1Hz		89			
	34	P34	Frequency jump 2B	0 to 120Hz,	0.1Hz		89			
	35	P35	Frequency jump 3A	0 to 120Hz,	0.1Hz		89			
	36	P38	Frequency jump 3B	0 to 120Hz,	0.1Hz		89			
	37	P37	Speed display	0, 0.1 to 999	0.1	0	90			
	38	P38	Frequency setting voltage gain frequency	1 to 120Hz	0.1Hz	60Hz	91			
	39	P39	Frequency setting current gain frequency	1 to 120Hz	0.1Hz	60Hz	91			
	40	P40	Start-time earth (ground) fault detection selection	0: Not detected 1: Detected	1	0	95			

Func- tion	Para- meter	Indica- tion	Name	Setting Range	Minimum Setting Increments	Factory Setting	Refer To:	Cus- tomer Setting
Output terminal functions	41	PYI	Up-to- frequency sensitivity	0 to 100%	1%	10%	95	
	42	P45	Output frequency detection	0 to 120Hz	0.1Hz	6Hz	96	
	43	P43	Output frequency detection for reverse rotation	0 to 120Hz,	0.1Hz		96	
Suc	44	PYY	Second acceleration/ deceleration time	0 to 999s	0.1s	5s	76	
Second functions	45	P45	Second deceleration time	0 to 999s,	0.1s		76	
econ	46	P46	Second torque boost	0 to 15%,	0.1%		71	
S	47	PYT	Second V/F (base frequency)	0 to 120Hz,	0.1Hz		73	
	48	P48	Output current detection level	0 to 200%	1%	150%	97	
Current detection	49	P49	Output current detection signal delay time	0 to 10s	0.1s	0s	97	
	50	P50	Zero current detection level	0 to 200%	1%	5%	98	
	51	PS 1	Zero current detection period	0.05 to 1s	0.01s	0.5s	98	

Func- tion	Para- meter	Indica- tion	Name	Setting Range	Minimum Setting Increments	Factory Setting	Refer To:	Cus- tomer Setting
Display functions	52	P52	Operation panel display data selection	O: Output frequency, Output current, 100:Set frequency during stop/output frequency during operation	1	0	99	
	53	PS3	Frequency setting operation selection	Setting dial frequency setting mode Setting dial potentiometer mode	1	0	100	
	54	PSY	FM terminal function selection	Output frequency monitor 1: Output current monitor	1	0	99	
	55	P55	Frequency monitoring reference	0 to 120Hz	0.1Hz	60Hz	101	
	56	P58	Current monitoring reference	0 to 50A	0.1A	Rated inverter current	101	
c restart ions	57	P57	Restart coasting time	0 to 5s,	0.1s		101	
Automatic restart functions	58	P58	Restart cushion time	0 to 60s	0.1s	1s	101	
Additional function	59	P59	Remote setting function selection	Without remote setting function With remote setting function With frequency setting storage function With remote setting function Without frequency setting storage function Without frequency setting function Without frequency setting storage function	1	0	104	

Func- tion	Para- meter	Indica- tion	Name	Setting Range	Minimum Setting Increments	Factory Setting	Refer To:	Cus- tomer Setting
Terminal function selection	60	P60	RL terminal function selection	0: RL, 1: RM, 2: RH, 3: RT, 4: AU, 5: STOP,	1	0	108	
	61	P6 I	RM terminal function selection	6: MRS, 7: OH, 8: REX, 9: JOG, 10: RES, 14: X14, 16: X16,: STR (The STR signal can be assigned to the STR terminal only.) 0:RUN, 1:SU, 3:OL, 4:FU, 11:RY, 12:Y12, 13:Y13, 14:FDN, 15:FUP, 16:RL, 93:Y93, 95:Y95 98:LF, 99:ABC (The Y93 signal can be assigned to the RUN terminal only.)	1	1	108	
	62	P62	RH terminal function selection		1	2	108	
	63	P63	STR terminal function selection		1		108	
	64	P64	RUN terminal function selection		1	0	110	
	65	P85	A, B, C terminal function selection		1	99	110	
Operation selection functions	66	P88	Retry selection	0: OC1 to 3, OV1 to 3, THM, THT, BE, GF, OHT, OLT, PE, OPT 1: OC1 to 3, 2: OV1 to 3, 3: OC1 to 3, OV1 to 3	1	0	111	
	67	P67	Number of retries at alarm occurrence	0: No retry 1 to 10: Without alarm output during retry operation 101 to 110: With alarm output during retry operation	1	0	111	
	68	P68	Retry waiting time	0.1 to 360s	0.1s	1s	111	
	69	P89	Retry count display erase	0: Cumulative count erase	1	0	111	

	Para- meter	Indica- tion	Name	Setting Range	Minimum Setting Increments	Factory Setting	Refer To:	Cus- tomer Setting
Operation selection functions	70	P70	Soft-PWM setting	Soft-PWM mode O Absence Absence I Presence Absence O Absence Presence Presence Presence Presence	1	1	113	
	71	<i>የባ</i> ፣	Applied motor	0, 100: Thermal characteristic for Mitsubishi standard motor 1, 101: Thermal characteristic for Mitsubishi constant-torque motor (Thermal characteristic for Mitsubishi constant-torque motor is selected with the RT signal ON when 100 and 101 are set.)	1	0	78	
	72	P72	PWM frequency selection	0 to 15	1	1	113	
	73	P73	0-5V/0-10V selection	0: For 0 to 5VDC input 1: For 0 to 10VDC input	1	0	114	
	74	ЬЛА	Input filter time constant	0: 2-step moving average processing 1 to 8: Exponential average value of 2n at the setting of n	1	1	115	

	Para- meter	Indica- tion	Name	Setting Range	Minimum Setting Increments	Factory Setting	Refer To:	Cus- tomer Setting
ıctions	75	P75	Reset selection/PU stop selection	O: Reset normally enabled/PU stop key disabled I: Enabled at alarm occurrence only/PU stop key disabled I4: Reset normally enabled/normally decelerated to stop I5: Enabled at alarm occurrence only/normally decelerated to stop I5: Enabled at ostop I5: Enabled ostop I	1	14	115	
lection fur	76	P76	Cooling fan operation selection	O: Operation started at power on Cooling fan ON/ OFF control	1	1	117	
Operation selection functions	77	PTT	Parameter write disable selection	Write is enabled only during a stop Write disabled (except some parameters) Write during operation enabled	1	0	118	
	78	P78	Reverse rotation prevention selection	Both forward rotation and reverse rotation enabled, Reverse rotation disabled, Forward rotation disabled	1	0	119	
			Param	eter 79 is basic function	parameter.		ı	
unction	80	P80	Multi-speed setting (speed 8)	0 to 120Hz,	0.1Hz		75	
Multi-speed operation function	81	P8 I	Multi-speed setting (speed 9)	0 to 120Hz,	0.1Hz		75	
do pəəd	82	P82	Multi-speed setting (speed 10)	0 to 120Hz,	0.1Hz		75	
Multi-s	83	P83	Multi-speed setting (speed 11)	0 to 120Hz,	0.1Hz		75	

Func- tion	Para- meter	Indica- tion	Name	Setting Range	Minimum Setting Increments	Factory Setting	Refer To:	Cus- tomer Setting
unction	84	P84	Multi-speed setting (speed 12)	0 to 120Hz,	0.1Hz		75	
Multi-speed operation function	85	P85	Multi-speed setting (speed 13)	0 to 120Hz,	0.1Hz		75	
do pəəd	86	P86	Multi-speed setting (speed 14)	0 to 120Hz,	0.1Hz		75	
Multi-s	87	P87	Multi-speed setting (speed 15)	0 to 120Hz,	0.1Hz		75	
	88	P88	PID action selection	20: PID reverse action, 21: PID forward action	1	20	123	
	89	P89	PID proportional band	0.1 to 999%,	0.1%	100%	123	
0	90	P90	PID integral time	0.1 to 999s,	0.1s	1s	123	
PID control	91	P9 I	PID upper limit	0 to 100%,	0.1%		123	
PID	92	P92	PID lower limit	0 to 100%,	0.1%		123	
	93	P93	PID action set point for PU operation	0 to 100%	0.01%	0%	123	
	94	<i>P</i> 94	PID differential time	0.01 to 10s,	0.01s		123	
Ē	95	P95	Rated motor slip	0 to 50%,	0.01%		131	
pensatio	96	P96	Slip compensation time constant	0.01 to 10s	0.01s	0.5s	131	
Slip compensation	97	Pgn	Constant power range slip compensation selection	0,	1		131	
torque boost	98	P98	Automatic torque boost selection (Motor capacity)	0.1 to 3.7kW,	0.01kW		132	
Automatic torque bc	99	P99	Motor primary resistance	0 to 50Ω,	0.01Ω		133	

Additional parameters

Func- tion	Parame- ters	Indi- cation	Name	Setting Range	Minimum Setting Incre- ments	Factory Setting	Refer To:	Cus- tomer Setting
	H1 (503)	н ;	Maintenance timer	0 to 999	1 (1000h)	0	133	
	H2 (504)	н 2	Maintenance timer alarm output set time	0 to 999,	1 (1000h)	36 (36000h)	133	
tion	H3 (555)	Н 3	Current average time	0.1 to 1s	0.1s	1s	134	
func	H4 (556)	H 4	Data output mask time	0 to 20s	0.1s	0s	134	
Additional function	H5 (557)	Н 5	Current average value monitor signal output reference current	0.1 to 999A	0.1A	1A	134	
▼	H6 (162)	н 6	Automatic restart after instantaneous power failure selection		1	1	101	
	H7 (559)	ΗΊ	Second electronic thermal O/L relay	0 to 50A,	0.1A		78	

● Brake parameters Set when using an optional brake resistor with the FR-S520E-0.4K to 3.7K.

Func- tion	Parame- ters		di- ion	Name	Setting Range	Minimum Setting Incre- ments	Factory Setting	Refer To:	Cus- tomer Setting
ce ion	b1 (560)	Ŀ	;	Regenerative function selection	0, 1	1	0	137	
Brake function	b2 (561)	ь	2	Special regenerative brake duty	0 to 30%	0.1%	0%	137	

Communication Parameters

	Innumeat					Minimum			Cuo
Func tion	Parame- ter	Indi tio		Name	Setting Range	Setting Incre- ments	Factory Setting	Refer To:	Cus- tomer Setting
	n1 (331)	n	1	Communication station number	0 to 31: Specify the station number of the inverter.	1	0	144	
	n2 (332)	C	2	Communication speed	48: 4800bps, 96: 9600bps, 192: 19200bps	1	192	144	
	n3 (333)	c	3	Stop bit length	0, 1: (Data length 8), 10, 11: (Data length 7)	1	1	144	
	n4 (334)	n	4	Parity check presence/ absence	0: Absent, 1: With odd parity check, 2: With even parity check	1	2	144	
	n5 (335)	n	5	Number of communication retries	0 to 10,	1	1	144	
eters	n6 (336)	c	8	Communication check time interval	0 to 999s,	0.1s		144	
arame	n7 (337)	c	7	Waiting time setting	0 to 150ms,	1		144	
Communication Parameters	n8 (338)	n	8	Operation command source	0: Command source is computer, 1: Command source is external terminal	1	0	160	
0	n9 (339)	п	9	Speed command source	0: Command sourse is computer, 1: Command source is external terminal	1	0	160	
	n10 (340)	~ ·	10	Link startup mode selection	As set in Pr. 79. Started in computer link operation mode.	1	0	161	
	n11 (341)	n		CR/LF selection	0: Without CR/LF, 1: With CR, without LF 2: With CR/LF	1	1	144	
	n12 (342)	n	12	EEPROM write selection	0: Write to RAM and EEPROM 1: Write to RAM only	1	0	163	

PU parameters

When the parameter unit (FR-PU04) is used, operation from the operation panel is not accepted. (The stop key $(\frac{STOP}{RESEI})$) is valid)

Func tion			Name	Setting Range	Minimum Setting Incre- ments	Factory Setting	Refer To:	Cus- tomer Setting
	n13 (145)	n 13	PU display language selection	0: Japanese, 1: English, 2: German, 3: French, 4: Spanish, 5: Italian, 6: Swedish, 7: Finnish	1	0	164	
	n14 (990)	n 14	PU buzzer control	0: Without sound, 1: With sound	1	1	164	
	n15 (991)	n 15	PU contrast adjustment	0 (Light) 63 (Dark)	1	58	165	
PU parameters	n16 (992)	n 16	PU main display screen data selection	0: Selectable between output frequency and output current 100: (during stop): Set frequency, output current (during operation): Output frequency, output current	1	0	165	
	n17 (993)	n 19	Disconnected PU detection/PU setting lock	0: Without disconnected PU error, 1: Error at disconnected PU, 10: Without disconnected PU error (PU operation disable)	1	0	166	

Calibration parameters

Func- tion	Parame- ters	Indi- cation	Name	Setting Range	Minimum Setting Incre- ments	Factory Setting	Refer To:	Cus- tomer Setting		
	C1 (900)	[1	FM terminal calibration				138			
હ	C2 (902)	E 2	Frequency setting voltage bias frequency	0 to 60Hz	0.1Hz	0Hz	91			
mete	C3 (902)	€ 3	Frequency setting voltage bias	0 to 300%	0.1%	0% (*)	91			
para	C4 (903)	E 4	Frequency setting voltage gain	0 to 300%	0.1%	96% (*)	91			
Calibration parameters	C5 (904)	€ 5	Frequency setting current bias frequency	0 to 60Hz	0.1Hz	0Hz	91			
Cal	C6 (904)	€ 8	Frequency setting current bias	0 to 300%	0.1%	20% (*)	91			
	C7 (905)	[7	Frequency setting current gain	0 to 300%	0.1%	100% (*)	91			
	C8 (269)	€ 8	Parameter for ma	Parameter for manufacturer setting. Do not set.						
ameters	CLr	ELF	Parameter clear	0: Not executed 1: Parameter clear 10: All clear	1	0	141			
Clear parameters	ECL	EEL	Alarm history clear	0: Not cleared, 1: Alarm history clear	1	0	141			

^{*} Factory settings may differ because of calibration parameters.

REMARKS

- 1. The parameter number in parentheses is the one for use with the parameter unit (FR-PU04).
- 2. Set "9999" when setting a value "- -" using the parameter unit (FR-PU04).
- 3. The decimal places of a value 100 or more (3 digits or more) cannot be displayed.

2.2 List of parameters classified by purpose of use

Set the parameters according to the operating conditions. The following list indicates purpose of use and corresponding parameters.

	Dumage of Hee	Parameter Numbers		
	Purpose of Use	Parameter numbers which must be set		
	Use of extended function parameters	Pr. 30		
	Operation mode selection	Pr. 53, Pr. 79 (Communication parameters n10, n17)		
	Acceleration/deceleration time/pattern adjustment	Pr. 7, Pr. 8, Pr. 16, Pr. 20, Pr. 29, Pr. 44, Pr. 45		
	Selection of output characteristics optimum for load characteristics	Pr. 3, Pr. 14, Pr. 19, Pr. 44, Pr. 45		
	Output frequency restriction (limit)	Pr. 1, Pr. 2		
tion	Operation over 60Hz	Pr. 1, Pr. 38, Pr. 39, calibration parameter C4, C7		
Related to operation	Adjustment of frequency setting signals and outputs	Pr. 38, Pr. 39, Pr. 73, calibration parameter C2 to C7		
유	Motor output torque adjustment	Pr. 0, Pr. 98		
ted	Brake operation adjustment	Pr. 10, Pr. 11, Pr. 12, brake parameter b1, b2		
Rela	Multi-speed operation	Pr. 1, Pr. 2, Pr. 4, Pr. 5, Pr. 6, Pr. 24, Pr. 25, Pr. 26, Pr. 27, Pr. 80, Pr. 81, Pr. 82, Pr. 83, Pr. 84, Pr. 85, Pr. 86, Pr. 87		
	Jog operation	Pr. 15, Pr. 16		
	Frequency jump operation	Pr. 31, Pr. 32, Pr. 33, Pr. 34, Pr. 35, Pr. 36		
	Automatic restart after instantaneous power failure operation	Pr. 57, Pr. 58, additional parameter H6		
	Slip compensation setting	Pr. 95 to Pr. 97		
	Setting of output characteristics matching the motor	Pr. 3, Pr. 19, Pr. 71		
u	Electromagnetic brake operation timing	Pr. 42, Pr. 64, Pr. 65		
olicatic	Sub-motor operation	Pr. 0, Pr. 3, Pr. 7, Pr. 8, Pr. 44, Pr. 45, Pr. 46, Pr. 47, additional parameter H7		
d to appl	Operation in communication with personal computer	Communication parameters n1 to n12		
Related to application operation	Operation under PID control	Pr. 60 to Pr. 65, Pr. 73, Pr. 79, Pr. 88 to Pr. 94		
ď	Noise reduction	Pr. 70, Pr. 72		


			 		
		Purpose of Use	Parameter Numbers		
		1 41 0000 01 000	Parameter numbers which must be set		
	-	Fraguancy motor calibration	Pr. 54, Pr. 55, Pr. 56,		
d to	ring	Frequency meter cambration	calibration parameter C1		
ite	ito	Display of monitor on operation panel or	Dr. 50. communication narameter v16		
Related	noı	Frequency meter calibration Display of monitor on operation panel or parameter unit (FR-PU04) Display of speed, etc.	Pr. 52, communication parameter n16		
œ	П	Display of speed, etc.	Pr. 37, Pr. 52		
oct	ion	Function write prevention	Pr. 77		
orre	int	•			
inco	reve	Function write prevention Reverse rotation prevention	(Pr. 17), Pr. 78		
			Pr. 48 to Pr. 51, Pr. 64, Pr. 65		
ted					
ela	era	Current detection Motor stall prevention	Pr. 21, Pr. 22, Pr. 23, Pr. 28		
R	op				
		Input terminal function assignment	Pr. 60 to Pr. 63		
		Output terminal function assignment	Pr. 64, Pr. 65		
		Increased cooling fan life	Pr. 76		
é	0	Motor protection from overheat	Pr. 9, Pr. 71		
Othere	5	Automatic restart operation at alarm stop	Pr. 66 to Pr. 69		
Č	5	Setting of earth (ground) fault overcurrent	Pr. 40		
		protection	P1. 40		
		Inverter reset selection	Pr. 75		
		Maintenance timer output	Additional parameters H1 to H5		

2.3 Explanation of functions (parameters)

2.3.1 Torque boost (Pr. 0 2 , Pr. 46 2)

Increase the setting value when the distance between the inverter and motor is long or when the motor torque in the low speed range is insufficient (when stall prevention is activated), etc.

 Motor torque in the low-frequency range can be adjusted to the load to increase the starting motor torque.



Parameter	Name	Factory Setting	Setting Range	Remarks
0	Torque boost	6%/5%/4%	0 to 15%	The factory setting varies according to the inverter capacity. (Refer to the following table for details.)
46	Second torque boost			: Function invalid. Setting is enabled when Pr. 30 = "1".

<Setting>

Assuming that the base frequency voltage is 100%, set the 0Hz voltage in %.
 Use the RT signal to switch between two different torque boosts. (Turn on the RT signal to make Pr. 46 valid(*).)

REMARKS

- * The RT signal acts as the second function selection signal and makes the other second functions valid.
- When using an inverter-dedicated motor (constant-torque motor), make setting as indicated below.

(If the factory set Pr. 71 value is changed to the setting for use with a constant-torque motor, the Pr. 0 setting changes to the corresponding value in the following table.)

Inverter Type	Inverter Capacity	Factory Setting	Constant-torque Motor Setting	
	0.1K to 0.75K		6% (no change)	
FR-S520SE FR-S510WE	1.5K to 3.7K	6%	4%	
	0.4K, 0.75K	6%	6% (no change)	
FR-S540E	1.5K	5%	4%	
1 1X-3340L	2.2K	3 /0	3%	
	3.7K	4%	3 /0	

— CAUTION

- Selecting automatic torque boost control makes this parameter setting invalid.
- A too large setting may cause the motor to overheat or result in an overcurrent trip. The guideline is about 10% at the greatest.


◆Related parameters ◆

- RT signal (second function "Pr. 46") setting⇒ Pr. 60 to Pr. 63 "input terminal function selection" (refer to page 108)
- Constant-torque motor setting ⇒ Pr. 71 "applied motor" (refer to page 78)
- Automatic torque boost control selection

 Pr. 98 "automatic torque boost selection (motor capacity)" (refer to page 132)

2.3.2 Maximum and minimum frequency (Pr. 1 2 Pr. 2 2 2 2)

You can clamp the upper and lower limits of the output frequency.



Parameter	Name	Factory Setting	Setting Range
1	Maximum frequency	60Hz	0 to 120Hz
2	Minimum frequency	0Hz	0 to 120Hz

<Setting>

- •Use Pr. 1 to set the upper limit of the output frequency. If the frequency of the frequency command entered is higher than the setting, the output frequency is clamped at the maximum frequency.
- •Use Pr. 2 to set the lower limit of the output frequency.

REMARKS

When using the potentiometer (frequency setting potentiometer) connected across terminals 2-5 to perform operation above 60Hz, change the Pr. 1 and Pr. 38 (Pr. 39 when using the potentiometer across terminals 4-5) values.

!CAUTION

If the Pr. 2 setting is higher than the Pr. 13 "starting frequency" value, note that the motor will run at the frequency set in Pr. 2 according to the acceleration time setting by merely switching the start signal on, without entry of the command frequency.


◆ Related parameters ◆

- Starting frequency setting Pr. 13 "starting frequency" (refer to page 81)
- Maximum frequency setting using external potentiometer
 - ⇒ Pr. 30 "extended function display selection" (refer to page 89),
 - Pr. 38 "frequency setting voltage gain frequency",
 - Pr. 39 "frequency setting current gain frequency" (refer to page 91)

2.3.3 Base frequency, base frequency voltage

(Pr.3 23, Pr.19 28, Pr.47 249)

Used to adjust the inverter outputs (voltage, frequency) to the motor rating.



Parameter	Name	Factory Setting	Setting Range	Remarks
3	Base frequency	60Hz	0 to 120Hz	
19	Base frequency voltage		0 to 800V, 888,	888: 95% of power supply voltage (*1): Same as power supply voltage (*2) Setting is enabled when Pr. 30 = "1".
47	Second V/F (base frequency)		0 to 120Hz,	: Function invalid Setting is enabled when Pr. 30 = "1".

- *1. 1.9 times greater than the power supply voltage for the FR-S510WE-0.1K to 0.75K.
- *2. Twice greater than the power supply voltage for the FR-S510WE-0.1K to 0.75K.

<Setting>

•In Pr. 3 and Pr. 47, set the base frequency (motor's rated frequency). Use the RT signal to switch between these two different base frequencies.

(Turn on the RT signal to make Pr. 47 valid.) (*)

When running the standard motor, generally set the "base frequency" to the rated frequency of the motor.

If only "50Hz" is given on the motor rating plate as the frequency, always set the "base frequency" to "50Hz". If it remains at "60Hz", the voltage may become too low and torque shortage occurs, resulting in an overload trip. Special care must be taken when "1" is set in Pr. 14 "load pattern selection".

If "50Hz/60Hz" is given on the motor rating plate as the frequency, always set the "base frequency" to "60Hz". When running the motor using bypass operation, set the base frequency to the same value as the power supply frequency.

Set the base voltage (e.g. rated voltage of motor) in Pr. 19.

CAUTION —

- 1. Set 60Hz in Pr. 3 "base frequency" when using a Mitsubishi constant-torque motor.
- 2. When automatic torque boost is selected, Pr. 47 is invalid. When automatic torque boost is selected, setting "- -" or "888" in Pr. 19 uses the rated output voltage.

REMARKS

* The RT signal serves as the second function selection signal and makes the other second functions valid.

- ♦ Related parameters ♦ -

- When rated motor frequency is "50Hz" ⇒ Pr. 14 "load pattern selection" (refer to page 82)
- RT signal (second function "Pr. 47") setting ⇒ Pr. 60 to Pr. 63 (input terminal function selection) (refer to page 108)
- Motor setting ⇒ Pr. 71 "applied motor" (refer to page 78)
- Automatic torque boost selection

 Pr. 98 "automatic torque boost selection (motor capacity)"
 (refer to page 132)

Speed 15


ON

► Time

2.3.4 Multi-speed operation (Pr. 4 2 4 . Pr. 5 2 5 . Pr. 6 2 5 . Pr. 24 2 to Pr. 27 2 Pr. Pr. 80 2 to Pr. 87 2 1

Used to switch between the predetermined running speeds.

- ●Any speed can be selected by merely switching on/off the corresponding contact signals (RH, RM, RL, REX signals).
- By using these functions with Pr. 1 "maximum frequency" and Pr. 2 "minimum. frequency", up to 17 speeds can be set.
- ■This function is valid in the external operation mode or in the combined operation mode which is available when Pr. 79 = "3" or "4".



Parameter	Name	Factory Setting	Setting Range	Remarks
4	Multi-speed setting (high speed)	60Hz	0 to 120Hz	
5	Multi-speed setting (middle speed)	30Hz	0 to 120Hz	
6	Multi-speed setting (low speed)	10Hz	0 to 120Hz	
24 to 27	Multi-speed setting (speeds 4 to 7)		0 to 120Hz,	"" = no setting. Setting enabled when Pr. 30 = "1".
80 to 87	Multi-speed setting (speeds 8 to 15)		0 to 120Hz, 	"" = no setting. Setting enabled when Pr. 30 = "1".

<Setting>

• Set the running frequencies in the corresponding parameters.

Each speed (frequency) can be set as desired between 0 and 120Hz during inverter operation.

When the parameter of any multi-speed setting is read, turn the \bigcirc to change the settina.

In this case, press the (SET) (WRITE) to store the frequency. (This is also enabled in the external mode.)

The setting is reflected by pressing the (SET (WRITE)

 Assign the terminals used for signals RH. RM. RL and REX using Pr. 60 to Pr. 63. (Changing the terminal assignment using Pr. 60 to Pr. 63 (input terminal function selection) may affect the other functions. Check the functions of the corresponding terminals before making setting.)

CAUTION -

- 1. The multi-speed settings override the main speeds (across terminals 2-5, 4-5, setting dial). When the multi-speed settings and setting dial are used in the combined operation mode (Pr. 79 = 3), the multi-speed settings have precedence.
- 2. The multi-speeds can also be set in the PU or external operation mode.
- 3. For 3-speed setting, if two or three speeds are simultaneously selected, priority is given to the set frequency of the lower signal.
- 4. Pr. 24 to Pr. 27 and Pr. 80 to Pr. 87 settings have no priority between them.
- 5. The parameter values can be changed during operation.
- 6. When using this function with the jog signal, the jog signal has precedence.

REMARKS

The frequency-set external terminals have the following priority: Jog > multi-speed operation > AU (terminal 4) > terminal 2

♦ Related parameters ♦

- Maximum, minimum frequency setting


 Pr. 1 "maximum frequency", Pr. 2 "minimum frequency"
 (refer to page 72)
- Assignment of signals RH, RM, RL, REX to terminals ⇒ Pr. 60 to Pr. 63 (input terminal function selection) (refer to page 108)
- ullet External operation mode setting \Rightarrow Pr. 79 "operation mode selection" (refer to page 119)
- Computer link mode ⇒ Pr. 79 "operation mode selection" (refer to page 119), communication parameter n10 "link startup mode selection" (refer to page 161)
- Speed command source ⇒ Communication parameter n9 "speed command source" (refer to page 160)

2.3.5 Acceleration/deceleration time (Pr. 7 P. 8, Pr. 8 P. 8, Pr. 20 P. 97, Pr. 44 P. 97, Pr. 45 P. 97

deceleration time.
Set a larger value for a slower speed increase/decrease or a smaller value for a faster speed

increase/decrease.

Used to set motor acceleration/



Parameter	Name	Factory Setting	Setting Range	Remarks
7	Acceleration time	5s	0 to 999s	
8	Deceleration time	5s	0 to 999s	
20	Acceleration/ deceleration reference frequency	60Hz		Setting is enabled when Pr. 30 = "1".
44	Second acceleration/ deceleration time	5s		Setting is enabled when Pr. 30 = "1".
45	Second deceleration time		0 to 999s,	: Setting is enabled when deceleration time. Pr. 30 = "1".

<Setting>

- •Use Pr. 7 and Pr. 44 to set the acceleration time required to reach the frequency set in Pr. 20 from 0Hz.
- •Use Pr. 8 and Pr. 45 to set the deceleration time required to reach 0Hz from the frequency set in Pr. 20.
- Pr. 44 and Pr. 45 are valid when the RT signal is on. (When the RT signal is on, the other second functions (Pr. 44, Pr. 45, Pr. 46, Pr. 47, additional parameter H7) are also selected.)
- •Set "- -" in Pr. 45 to make the deceleration time equal to the acceleration time (Pr. 44).

CAUTION =

- 1. In S-shaped acceleration/deceleration pattern A (refer to page 88), the set time is the period required to reach the base frequency set in Pr. 3.
 - Acceleration/deceleration time formula when the set frequency is the base frequency or higher

$$t = \frac{4}{9} \times \frac{T}{(Pr.3)^2} \times f^2 + \frac{5}{9} T$$

T: Acceleration/deceleration time setting (s)

f : Set frequency (Hz)

•Guideline for acceleration/deceleration time at the base frequency of 60Hz (0Hz to set frequency)

Frequency setting (Hz) Acceleration/ deceleration time (s)	60	120
5	5	12
15	15	35

2. If the Pr. 20 setting is changed, the settings of calibration functions Pr. 38 and Pr. 39 (frequency setting signal gains) remain unchanged.

To adjust the gains, adjust calibration functions Pr. 38 and Pr. 39.

- 3. When the setting of Pr. 7, Pr. 8, Pr. 44 or Pr. 45 is "0", the acceleration/ deceleration time is 0.04s.
- 4. If the acceleration/deceleration time is set to the shortest value, the actual motor acceleration/deceleration time cannot be made shorter than the shortest acceleration/deceleration time which is determined by the mechanical system's J (moment of inertia) and motor torque.

→ Related parameters ◆ -

- Base frequency setting ⇒ Pr. 3 "base frequency" (refer to page 73)
- Acceleration/deceleration pattern, S-pattern acceleration/deceleration A
 Pr. 29 "acceleration/deceleration pattern" (refer to page 88)
- Calibration function ⇒ Pr. 38 "frequency setting voltage gain frequency"
 Pr. 39 "frequency setting current gain frequency" (refer to page 91)
- RT signal setting ⇒ Pr. 60 to Pr. 63 (input terminal function selection) (refer to page 108)
- Jog acceleration/deceleration time ⇒ Pr. 16 "jog acceleration/deceleration time" (refer to page 83)

2.3.6 Selection and protection of a motor (Pr. 9 2 , Pr. 71 2 , H7 2 , H7

Set the motor used and protect the motor from overheat.

This feature provides the optimum protective characteristics, including reduced motor cooling capability, at low speed.

POINT

•When using the Mitsubishi constant-torque motor

Set "1" in Pr. 71 for V/F control or automatic torque boost control.

The electronic thermal relay function is set to the thermal characteristic of the constant-torque motor.

•When you selected the Mitsubishi constant-torque motor, the values of the following parameters are automatically changed. (only when the setting values of those parameters are at factory setting)

Pr. 0 "torque boost", Pr. 12 "DC injection brake voltage"

Para meter	Name	Factory Setting	Setting Range	Remarks	
9	Electronic thermal O/L relay	Rated inverter current(*)	0 to 50A		
71	Applied motor	0	0, 1, 100, 101		Setting is enabled
H7 (559)	Second electronic thermal O/L relay		0 to 50A,	: Without second electronic thermal relay function	when Pr. 30 = "1"

- * 0.75K or less is set to 85% of the rated inverter current.
- The parameter number in parentheses is the one for use with the parameter unit (FR-PU04).

<Setting>

Refer to the following list and set Pr. 71 according to the motor used.
 Setting "100 or 101" changes thermal characteristic of the electronic thermal relay function to thermal characteristics of a Mitsubishi constant-torque motor when the RT signal is ON.

Pr. 71 Setting	Thermal Characteristic of the Electronic Thermal Relay Function
0, 100	Thermal characteristics of a standard motor
1, 101	Thermal characteristics of a Mitsubishi constant-torque motor
1, 101	(This provides a 100% continuous torque characteristic in the low-speed range.)

- Set the rated current [A] of the motor in Pr. 9. (Normally set the rated current at 50Hz.)
- Setting "0" in Pr. 9 disables electronic thermal relay function (motor protective function). (The protective function of the inverter is activated.)
- •When setting second electronic thermal relay function, set the motor rated current value in the additional parameter H7. The second electronic thermal relay function is valid when the RT signal is on. (When the RT signal is on, other second functions (Pr.44 to Pr.47) are also selected.)

CAUTION =

- •When two or more motors are connected to the inverter, they cannot be protected by the electronic thermal relay function. Install an external thermal relay to each motor.
- •When a difference between the inverter and motor capacities is large and the setting becomes less than half amount of the rated inverter current, the protective characteristics of the electronic thermal relay function will be deteriorated. In this case, use an external thermal relay.
- A special motor cannot be protected by the electronic thermal relay function.
 Use an external thermal relay.

REMARKS

•When running two motors with one inverter, you can set the electronic thermal relay function of each inverter.

Pr. 71	First Motor Electronic Thermal Relay Function			Second Motor Electronic Thermal Relay Function		
applied motor	Pr. 9 setting	RT = OFF	RT = ON	additional parameter H7 setting	RT = OFF	RT = ON
	0	>	<	, 0 0.1 to 50A	<u> </u>	<
0	0.1 to 50A	O standard	Δ	0 0.1 to 50A	>	Standard
	0	>	<	, 0 0.1 to 50A	\triangle	standard
1	0.1 to 50A		constant-		>	Standard
		torque		0.1 to 50A , 0		< standard
	0	×		0.1 to 50A	\triangle	Oconstant- torque
100	0.1 to 50A	0		0	>	<
	0.110 00/1	standard		0.1 to 50A	\triangle	oconstant- torque
				, 0		<
101	0	×		0.1 to 50A	\triangle	Oconstant- torque
101	0.44 50:	O		0		<
	0.1 to 50A constant- torque	Δ	0.1 to 50A	Δ	Oconstant- torque	

standardThermal characteristic for standard motor

constant-torqueThermal characteristic for constant-torque motor

- Output current value is used to perform integration processing.

!CAUTION


A Set this parameter correctly according to the motor used. Incorrect setting may cause the motor to overheat and burn.

- ♦ Related parameters ♦

- Automatic torque boost ⇒ Pr. 98 "automatic torque boost selection (Motor capacity)" (refer to page 132)
- ullet Pr. 0 "torque boost" \Rightarrow refer to page 71
- Pr. 12 "DC injection brake voltage" ⇒ refer to page 80

2.3.7 DC injection brake (Pr. 10 PH, Pr. 11 PH, Pr. 12 PH)

By setting the DC injection brake voltage (torque) at a stop, operation time, and operation starting frequency, the timing of applying the DC injection brake to stop the braking torque the motor is adjusted.



Parameter	Name	Factory Setting	Setting Range	Remarks
	DC injection brake operation frequency	3Hz		Setting is enabled when Pr. 30 = "1".
	DC injection brake operation time	0.5s	0 to 10s	(When Pr. 11 is set to "0s" or Pr. 12 is set to "0%", DC injection brake is not
12	DC injection brake voltage	6%		operated.)

CAUTION =

•A too large setting of Pr. 12 "DC injection brake voltage" activates protection function of electronic thermal relay function and can cause the inverter life to be shorter.

<Setting>

- •Use Pr. 10 to set the frequency at which the DC injection brake operation is started.
- •Use Pr. 11 to set the period during when the brake is operated.
- •Use Pr. 12 to set the percentage of the power supply voltage.
- Change the Pr. 12 setting to 4% when using the inverter-dedicated (constant-torque motor).

(If the Pr. 12 value remains unchanged from the factory setting and Pr. 71 is changed to the setting for use of the constant-torque motor, the Pr. 12 setting is automatically changed to 4%.)

ACAUTION

 Λ Install a mechanical brake. No holding torque is provided.


◆ Related parameters ◆

Pr. 71 "applied motor" ⇒ refer to page 78

2.3.8 Starting frequency (Pr. 13 PB)

The starting frequency at which the start signal is turned on can be set in the range 0 to 60Hz.

Frequency which is output by the inverter first at a start and gives great influence to the starting torque. About 1 to 3Hz for vertical lift applications, or up to 5Hz to the maximum. For other than vertical lift applications, factory setting of about 0.5Hz (approx. rated motor slip) is recommended.



Parameter	Name	Factory Setting		Remarks
13	Starting frequency	0.5Hz	0 to 60Hz	Setting is enabled when Pr. 30 = "1".

CAUTION

The inverter will not start if the frequency setting signal is less than the value set in Pr. 13 "starting frequency".


For example, when 5Hz is set in Pr. 13, the motor will not start running until the frequency setting signal reaches 5Hz.

!CAUTION

- Note that when Pr. 13 is set to any value equal to or less than Pr. 2 "minimum frequency", simply turning on the start signal will run the motor at the preset frequency even if the command frequency is not input.
 - ◆ Related parameters ◆
- Minimum frequency setting ⇒ Pr. 2 "minimum frequency" (refer to page 72)

2.3.9 Load pattern selection (Pr. 14 PM)

You can select the optimum output characteristic (V/F characteristic) for the application and load characteristics.



Parameter	Name	Factory Setting	Setting Range	Remarks	
1 1/1	Load pattern selection	1	0, 1, 2, 3	1: For reduced-torque loads 2: For vertical lift loads	Setting is enabled when Pr. 30 = "1".

CAUTION

- 1. When automatic torque boost control is selected, this parameter setting is ignored.
- 2. Pr. 46 "second torque boost" is made valid when the RT signal turns on.

 The RT signal acts as the second function selection signal and makes the other second functions valid.

◆Related parameters ◆ -

- ◆Automatic torque boost ⇒ Pr. 98 "automatic torque boost selection (motor capacity)" (refer to page 132)
- Boost setting ⇒ Pr. 0 "torque boost", Pr. 46 "second torque boost" (refer to page 71)
- Assignment of RT signal to terminal when second torque boost is used
 ⇒ Pr. 60 to Pr. 63 (input terminal function selection) (refer to page 108)


2.3.10 Jog operation (Pr.15 PB, Pr.16 PB)

To start/stop jog operation in the external operation mode, choose the jog operation function in input terminal function selection, turn on the jog signal, and turn on/off the start signal (STF, STR).

You can choose the jog operation mode from the parameter unit (FR-PU04) and perform jog operation

using the $\boxed{\mbox{\tiny FWD}}$ or $\boxed{\mbox{\tiny REV}}.$

(Can be read as the basic parameters when the FR-PU04 is connected.)



• Set the frequency and acceleration/deceleration time for jog operation.

Parameter	Name	Factory Setting	Setting Range	Remarks
15	Jog frequency	5Hz	0 to 120Hz	Setting is enabled when
i in	Jog acceleration/ deceleration time	0.5s		Pr. 30 = "1".

CAUTION

- •In S-shaped acceleration/deceleration pattern A, the acceleration/deceleration time is the period of time required to reach Pr. 3 "base frequency", not Pr. 20 "acceleration/deceleration reference frequency".
- •The acceleration time and deceleration time cannot be set separately for jog operation.
- •The Pr. 15 "Jog frequency" value should be equal to or higher than the Pr. 13 "starting frequency" setting.
- •Assign the jog signal using any of Pr. 60 to Pr. 63 (input terminal function selection).
- •Select PU operation mode to perform PU JOG operation. (Refer to page 119.)

♦ Related parameters ♦

- ◆Assignment of jog signal to terminal ⇒ Pr. 60 to Pr. 63 (input terminal function selection) (refer to page 108)
- Acceleration/deceleration pattern S-shaped acceleration/deceleration A
 ⇒ Pr. 29 "acceleration/deceleration pattern" (refer to page 88)

2.3.11 RUN key rotation direction selection (Pr.17 P.11)

Used to choose the direction of rotation by operating the (RUN) key of the operation panel.

Parameter	Name	Factory Setting	Setting Range	Remarks	
1 /	RUN key rotation direction selection	0	() 1		Setting is enabled when Pr. 30 = "1".

P 19 → Refer to P 3 (page 73)

P20 → Refer to *P 1*, *P 8* (page 76)

2.3.12 Stall prevention function and current limit function (Pr. 21 PPH)

You can make setting to prevent stall caused by overcurrent and/or to prevent the inverter from resulting in an overcurrent trip (to disable fast-response current limit that limits the current) when an excessive current flows due to sudden load fluctuation or ON-OFF on the output side of a running inverter.

· Stall prevention

and OLT are not output.

Name

Parameter

- If the current exceeds the stall prevention operation level (Pr.22), the output frequency of the inverter is automatically varied to reduce the current.
- Fast-response current limit
 If the current exceeds the limit value, the output of the inverter is shut off to
 prevent an overcurrent.

Setting

Range

Remarks

Factory

Setting

21 Stall prevention function selection		0	0 to 31	, 100	Settin	g is e	enable	ed w	hen Pr. 30 =			
Pr. 21 Setting	Fast- Response Current Limit (): Activated	Operation Selection C: Activated Selection C: Activated		OL Signal Output O: Operation continued O:	Pr. 21 Setting	Fast- Response Current		Stall Prevention Operation Selection : Activated :Not activated		n I	OL Signal Output (): Operation continued ():	
	Not activated	Acceleration	Constant speed	Deceleration	Operation not continued (*1)		●:No activa	ot	Acceleration	Constant speed	Deceleration	Operation not continued (*1)
0	0	Q	Q	Q	0	16	(<u> </u>	Q	Q	<u>Q</u>	
1		Ŏ	Ŏ	Ó	<u> </u>	17		<u> </u>	Ō	Ŏ	<u>O</u>	•
2	Q	Ì	Q	\bigcirc	0	18	(<u>) </u>	•	\bigcirc	\bigcirc	•
3	•		\bigcirc	\bigcirc	<u> </u>	19				\bigcirc	<u>Q</u>	•
4 5	0	\bigcirc	•	\bigcirc	\bigcirc	20 21		2	\mathbb{R}^{0}		$\underline{\circ}$	_
6		V	2	\otimes	-0 $-$ 0 $-$ 1	22	9		$\overline{\mathbb{Q}}$		$\frac{\circ}{\circ}$	_
7	<u> </u>	2	2	\otimes	\sim	23		2	-		$\frac{\circ}{\circ}$	_
8				\subseteq	$\overline{\bigcirc}$	23	_	_			$\overline{\underline{\bigcirc}}$	_
9	<u> </u>	$\stackrel{\square}{\bowtie}$	$\stackrel{\smile}{\sim}$	<u> </u>	-	25			$\stackrel{\square}{\sim}$	$\stackrel{\bigcirc}{\sim}$	<u> </u>	_
10		\subseteq	\sim		$ \otimes$ $-$	26	-	_	\square	\sim	<u> </u>	_
11		-	\mathbb{R}^{2}	_	\sim	27			-	\sim	-	_
12			\square		$\overline{}$	28	<u> </u>	_			<u> </u>	
13		$\vdash \bowtie$			$\overline{}$	29			\mathbb{R}		X	
14		\vdash			\longrightarrow	30						
15		-		_	<u> </u>	31		_			-	— (*2)
*1 When "Operation not continued for OL signal output" is selected, the "OLT" alarm code (stopped by stall prevention) is			0 Driving	()	0	0	0	— (Z)			
(Alaı *2 Sinc	displayed and operation stopped. (Alarm stop display "[]] [["]) *2 Since both fast response current limit and stall prevention are not activated, OL signal				t limit and	100 Regene Lative	•	•	•	•	•	— (*2)

CAUTION

- •If the load is heavy or the acceleration/deceleration time is short, the stall prevention may be activated and the motor not stopped in the preset acceleration/deceleration time. Therefore, set optimum values to the Pr. 21 and stall prevention operation level.
- •When the fast-response current limit has been set in Pr. 21 (factory setting), torque will not be provided at the Pr. 22 setting of 170% or higher. At this time, make setting so that the fast-response current limit is not activated.
- •In vertical lift applications, make setting so that the fast-response current limit is not activated. Torque may not be produced, causing a drop due to gravity.

ACAUTION

⚠ Always perform test operation.

Stall prevention operation performed during acceleration may increase the acceleration time.

Stall prevention operation performed during constant speed may cause sudden speed changes.


Stall prevention operation performed during deceleration may increase the deceleration time, increasing the deceleration distance.

2.3.13 Stall prevention (Pr. 22 222, Pr. 23 222, Pr. 28 222)

Set the output current level (% value to the rated inverter output current) at which the output frequency will be adjusted to prevent the inverter from stopping due to overcurrent etc.

• During high-speed operation above the rated motor frequency, acceleration may not be made because the motor current does not increase. To improve the operating characteristics of the motor in this case, the stall prevention level can be reduced in the high frequency range. This function is effective for performing operation up to the high speed range on a centrifugal separator etc. Normally, set 60Hz in Pr. 28 "stall prevention operation reduction starting frequency" and 100% in Pr. 23.

Parameter	Name	Factory Setting	Setting Range	Rem	arks
22	Stall prevention operation level	150%	0 to 200%		Setting is
23	Stall prevention operation level compensation factor at double speed		0 to 200%,	: Pr. 22 equally	enabled when Pr. 30 = "1".
28	Stall prevention operation reduction starting frequency	60Hz	0 to 120Hz		11.00 - 1.



<Setting>

- •Generally, set 150% (factory setting) in Pr. 22 "stall prevention operation level". Setting "0" in Pr. 22 disables stall prevention operation.
- •To reduce the stall prevention operation level in the high frequency range, set the reduction starting frequency in Pr. 28 "stall prevention operation reduction starting frequency" and the reduction ratio compensation factor in Pr. 23. Formula for stall prevention operation level

Stall prevention operation level (%) = A + B ×[
$$\frac{Pr. 22-A}{Pr. 22-B}$$
]×[$\frac{Pr. 23-100}{100}$] where, A = $\frac{Pr. 28 \text{ (Hz)} \times Pr. 22 \text{ (%)}}{\text{output frequency (Hz)}}$, B = $\frac{Pr. 28 \text{ (Hz)} \times Pr. 22 \text{ (%)}}{120\text{Hz}}$

•By setting "- - -" (factory setting) in Pr. 23, the stall prevention operation level is constant at the Pr. 22 setting up to 120Hz.

REMARKS

When the fast-response current limit is set in Pr. 21 "stall prevention function selection" (factory setting), do not set any value above 170% in Pr. 22. The torque will not be developed by doing so.

If the Pr. 22 value is set to higher than 170%, make setting in Pr. 21 to disable the fast-response current limit.

In vertical lift applications, make setting so the fast-response current limit is not activated. Torque may not be produced, causing a drop due to gravity.

A CAUTION

Do not set a small value as the stall prevention operation current. Otherwise, torque generated will reduce.

Test operation must be performed.

Stall prevention operation during acceleration may increase the acceleration time.


Stall prevention operation during constant speed may change the speed suddenly.


Stall prevention operation during deceleration may increase the deceleration time, increasing the deceleration distance.

P24 to P27 → Refer to P 4 to P 5 (page 75)

2.3.14 Acceleration/deceleration pattern (Pr. 29 228)

Set the acceleration/deceleration pattern.





Set value 2

Parameter	Name	Factory Setting	Setting Range	Remarks
1 79	Acceleration/ deceleration pattern	0	0, 1, 2	Setting is enabled when Pr. 30 = "1".

<Setting>

D . 00	T	
Pr. 29 Setting	Function	Description
0	Linear acceleration/ deceleration	Acceleration is made to the set frequency linearly. (Factory setting)
1	S-pattern acceleration/ deceleration A (*)	For machine tool spindle applications, etc. Used when acceleration/deceleration must be made in a short time to a high-speed range of not lower than the base frequency. Acceleration/deceleration is made in a pattern where fb (base frequency) acts as the inflection point of an S shape, and you can set the acceleration/deceleration time which matches the motor torque reduction in the constant-output operation range of not lower than the base frequency.
2	S-pattern acceleration/ deceleration B	For prevention of load shifting in conveyor and other applications. Since acceleration/deceleration is always made in an S shape from f2 (current frequency) to f1 (target frequency), this function eases shock produced at acceleration/deceleration and is effective for load collapse prevention, etc.

CAUTION

* As the acceleration/deceleration time, set the time taken to reach the Pr. 3 "base frequency" value, not the Pr. 20 "acceleration/deceleration reference frequency" value.

Related parameters + -

- Base frequency (acceleration/deceleration time setting) setting

 Pr. 3 "base frequency" (refer to page 73)
- Pr. 20 "acceleration / deceleration reference frequency" ⇒ refer to page 76
- For setting of "1" (S-pattern acceleration/deceleration A)
 - ⇒ Pr. 44 "second acceleration/deceleration time", Pr. 45 "second deceleration time" (refer to page 76)

2.3.15 Extended function display selection (Pr. 30 PM)


Used to display the extended function parameters.

- Refer to page 56 for the extended function parameter list.
- Refer to the instruction manual (basic) for the parameter setting method.

Parameter	Name	Factory Setting	Setting Range	Remarks
1 30	Extended function display selection	0	() 1	0: Without display, 1: With display

2.3.16 Frequency jump (Pr. 31 to Pr. 36)


When it is desired to avoid resonance attributable to the natural frequency of a mechanical system, these parameters allow resonant frequencies to be jumped. Up to three areas may be set, with the jump frequencies set to either the top or bottom point of each area. The value set to 1A, 2A or 3A is a jump point and operation is performed at this frequency.



Parameter		Factory Setting	Setting Range	Remarks
31	Frequency jump 1A		0 to 120Hz,	
32	Frequency jump 1B		0 to 120Hz,	
33	Frequency jump 2A		0 to 120Hz,	•: Function invalid •Setting is enabled when Pr.
34	Frequency jump 2B		0 to 120Hz,	30 = "1"
35	Frequency jump 3A		0 to 120Hz,	
36	Frequency jump 3B		0 to 120Hz,	<u> </u>

<Setting>

- To fix the frequency at 30Hz between Pr. 33 and Pr. 34 (30Hz and 35Hz), set 30Hz in Pr. 33 and 35Hz in Pr. 34.
- •To jump to 35Hz between 30 and 35Hz, set 35Hz in Pr. 33 and 30Hz in Pr. 34.



Pr.33:35Hz ... Pr.34:30Hz ...

CAUTION

During acceleration/deceleration, the running frequency within the set area is valid.

REMARKS

Write disable error " F_{r} " occurs if the frequency jump setting ranges overlap.

2.3.17 Speed display (Pr. 37 23)

You can change the output frequency indication or set frequency of the operation panel and parameter unit (FR-PU04) to the motor speed or machine speed.

Parar	neter	Name	Factory Setting	Setting Range	Remarks	
3	7	Speed display	0	0, 0.1 to 999	•	Setting is enabled when Pr. 30 = "1".

<Setting>

• To display the machine speed, set in Pr. 37 the machine speed for 60Hz operation.

CAUTION

- •The motor speed is converted from the output frequency and does not match the actual speed.
- •When you want to change the monitor (PU main display) of the operation panel, refer to Pr. 52 "operation panel display data selection" and communication parameter n16 "PU main display screen data selection".
- •Since the operation panel indication is 3 digits, make a setting so that the monitor value does not exceed "999". If the Pr. 1 value is higher than 60Hz and Pr. 1 value × Pr. 37 value > 60Hz × 999

 $\mathcal{E} \cap \mathcal{E}$ (write error) occurs when Pr. 1 or Pr. 37 is written.

REMARKS

When the speed is set in Pr. 37 (Pr. 37 \neq 0), the speed is monitored and displayed in the monitor/frequency setting mode.

At this time, setting can be made in the minimum setting (display) increments of 0.01r/min. Due to the limitations on the resolution of the set frequency, the indication in the second decimal place may differ from the setting.

♠CAUTION

Make sure that the running speed setting is correct.


Otherwise, the motor might run at extremely high speed, damaging the machine.


Related parameters ◆

- To choose running speed monitor display ⇒ Pr. 52 "operation panel display data selection" (refer to page 99)
- FR-PU04 display switching ⇒ Communication parameter n16 "PU main display screen data selection" (refer to page 165)

2.3.18 Biases and gains of the frequency setting voltage (current) (Pr. 38 BB, Pr. 39 BB, C2 BB to C7 BB)

You can set the magnitude (slope) of the output frequency as desired in relation to the external frequency setting signal (0 to 5V, 0 to 10V or 4 to 20mADC). The "bias" and "gain" functions are used to adjust the relationship between the input signal entered from outside the inverter to set the output frequency, e.g. 0 to 5V, 0 to 10V or 4 to 20mADC, and the output frequency.





Frequency setting current signal

Parameter	Name	Factory Setting	Setting Range	Remarks
38	Frequency setting voltage gain frequency	60Hz	1 to 120Hz	
39	Frequency setting current gain frequency	60Hz	1 to 120Hz	
TGZ (90Z) "Z	Frequency setting voltage bias frequency	0Hz	0 to 60Hz	Setting is enabled
C3 (902) *2	Frequency setting voltage bias	0% *1	0 to 300%	when Pr. 30 = "1".
C4 (903) *2	Frequency setting voltage gain	96% *1	0 to 300%	
C5 (904) *2	Frequency setting current bias frequency	0Hz	0 to 60Hz	
C6 (904) *2	Frequency setting current bias	20% *1	0 to 300%	
C7 (905) *2	Frequency setting current gain	100% *1	0 to 300%	

^{*1.}Factory settings may differ because of calibration parameters.

POINT

- Bias setting for 0-5VDC (0-10VDC) input Use calibration parameters C2, C3 for setting.
- Gain setting for 0-5VDC (0-10VDC) input

 Use Pr. 38, calibration parameter C4 for setting.
- •Bias setting for 4-20mADC input
- Use calibration parameters C5, C6 for setting.
- •Gain setting for 4-20mADC input
- **▶** Use Pr. 39, calibration parameter C7 for setting.

(For 4 to 20mADC input, set "4" in any of Pr. 60 to Pr. 63 (input terminal function selection) and assign AU (current input selection) to any of terminals RH, RM, RL and STR, and turn on the AU signal.)

^{*2.} The parameter number in parentheses is the one for use with the parameter unit (FR-PU04).

<Setting>

(1) How to change the highest frequency

(2) Adjusting the deviation of the highest frequency from the Pr. 38 (Pr. 39) setting. (2)-1) Make adjustment with a voltage applied directly across terminals 2-5 (with a

current flowing across terminals 4-5)

(2)-2) Make adjustment at any point without a voltage applied across terminals 2-5 (without a current flowing across terminals 4-5)

Changing example When you want to use the 0 to 5VDC input frequency setting potentiometer to change the 5V frequency from 60Hz(factory setting) to 50Hz

POINT


mode indication.

- •Pr. 38 is an extended function parameter. Pr. 30 must be set to "1".
- •Change Pr. 38 "frequency setting voltage gain frequency" to 50Hz.

(1) How to change the highest frequency

Operation -

- 1. Confirm the RUN indication and operation
 - The inverter must be at a stop.
 - •The inverter must be in the PU operation mode. (Press the $(\frac{PU}{FY})$.)
- 2. Press the (MODE) to choose the parameter setting mode.
- 3. Turn the (2) until the parameter number 38 "frequency setting voltage gain frequency" appears.
 - Pr. 30 must be set to "1". (For the Pr. 30 setting method, refer to the instruction manual (basic).)
- 4. Pressing the (SET) shows the currently set value. (60Hz)
- 5. Turn the (2) to change the set value to "50.0". (50Hz)
- 6. Press the (SET) to set the value.



Display





Flicker ... Parameter setting complete!!

- By turning the (5), you can read another parameter.
- Press the (SET) to show the setting again.
- Press the (SET) twice to show the next parameter.

? The monitor/frequency setting indication cannot be changed to just 50Hz ... Why?

The calibration parameter C4 "frequency setting voltage gain" value must be set. (Refer to next page (2).)

REMARKS

To change the value to more than 60Hz, Pr. 1 "maximum frequency" must be set to more than 60Hz.

Changing example Changing the calibration parameter C4 "frequency setting voltage gain" value

POINT

The calibration parameter C4 is an extended function parameter. Pr. 30 must be set to "1".

(2) Adjusting a deviation of the highest frequency from the Pr. 38 (Pr. 39) setting. (2)-1 Making adjustment with a voltage applied directly across terminals 2-5 (with a current flowing across terminals 4-5)


Operation ———
 Confirm the RUN indication and operation mode indication.

- •The inverter must be at a stop.
- The inverter must be in the PU operation mode. (Press the $\frac{PU}{EXI}$)
- Press the (op) to choose the parameter setting mode.
- 3. Turn the \bigcirc to show " \mathcal{L} . .".
 - Pr. 30 must be set to "1".
 (For the Pr. 30 setting method, refer to the instruction manual (basic).)
- 4. Press the (SET) to show " \mathcal{L} -".

When adjusting Pr. 38

- Turn the ountil the calibration parameter C4 "frequency setting voltage gain" appears.
- Press the (SET) to show the analog voltage value (%).
- Apply a 5V voltage.
 (Turn the external potentiometer connected to across terminals 2-5 to the maximum (any position).)









*The value is nearly 100 (%) in the

until completion of

maximum position of the potentiometer.

After performing operation in step 7, do not touch the calibration.

8. Press the (SET) to set the value.

CAUTION

SET ⇒ IOO * [Y

Flicker ... Parameter setting complete!!

*The value is nearly 100 (%) in the maximum position of the potentiometer.

- By turning the O, you can read another parameter.
- Press the (SET) to return to the (SET) indication (step 4).
- Press the (SET) twice to show the next parameter ([[] -...).
- ? The frequency meter (indicator) connected to across terminals FM-SD does not indicate just 50Hz ... Why?
 - The calibration parameter C1 "FM terminal calibration" value must be set. (For the setting method, refer to the instruction manual (basic).)
- ? When write is performed, an error (إلى ج) is displayed.
 The gain and bias frequency settings are too close.

(2)-2 Making adjustment at any point with a voltage not applied across terminals 2-5 (without a current flowing across terminals 4-5)

Operation ·

- Confirm the RUN indication and operation mode indication.
 - •The inverter must be at a stop.
 - The inverter must be in the PU operation mode. (Press the $\frac{PU}{EXT}$)
- 2. Press the (100) to choose the parameter setting mode.
- 3. Turn the O to show "[. . . ".
 - Pr. 30 must be set to "1".(For the Pr. 30 setting method, refer to the instruction manual (basic).)
- 4. Press the (SET) to show "(F) -".


When adjusting Pr. 38

- 5. Turn the O until the calibration parameter C4 "frequency setting voltage gain" appears.
- 6. Press the (SET) to show the analog voltage value (%).

 (The maximum value can be displayed by merely turning the Oclockwise or counterclockwise in this status by one pulse's worth of turns (there is tactile feedback because of the notch type).)
- 7. Turn the to the maximum value (100%) or any point.
- 8. Press the (SET) to set the value.



Display













*The value is 100 (%) in the maximum position of the potentiometer.



Flicker ... Parameter setting complete!! *The value is 100 (%) in the maximum position of the potentiometer.

- Turn the () to read another parameter.
- Press the (SET) to return to the [-indication (step 4).
- Press the (SET) twice to show the next parameter ([] _ ___).

REMARKS

For the way to change the output frequency setting of the frequency setting potentiometer, refer to the instruction manual (basic).

2.3.19 Start-time earth (ground) fault detection selection (Pr. 40 248)

You can choose whether to make earth (ground) fault detection at start valid or invalid. Earth (Ground) fault detection is executed only right after the start signal is input to the inverter.

Protective function will not activate if an earth (ground) fault occurs during operation.

Parameter	Name	Factory Setting	Setting Range	Remarks	
40	Start-time earth (ground) fault detection selection	0	0, 1	1: Forth (Cround) foult	Setting is enabled when Pr. 30 = "1".

CAUTION

- 1. If an earth (ground) fault is detected with "1" set in Pr. 40, alarm output "[; F" is detected and the output is shut off.
- 2. If the motor capacity is less than 0.1kW, earth (ground) fault protection may not be provided.


REMARKS

When an earth (ground) fault is detected with "1" set in Pr. 40, an approximate 20ms delay occurs at every start.

2.4 Output terminal function

2.4.1 Up-to-frequency sensitivity (Pr. 41 PM)

The ON range of the up-tofrequency signal (SU) output when the output frequency reaches the running frequency can be adjusted between 0 and ±100% of the running frequency. This parameter can be used to ensure that the running frequency has been reached to provide the operation start signal etc. for related equipment.



Parameter	Name	Factory Setting	Setting Range	Remarks
	Up-to-frequency sensitivity	10%	0 to 100%	Setting is enabled when Pr. 30 = "1".

Use Pr. 64 or Pr. 65 (output terminal function selection) to assign the terminal used for SU signal output.

— CAUTION


Using Pr. 64 or Pr. 65 to change the terminal assignment may affect the other functions. Please make setting after confirming the function of each terminal. (Refer to page 110.)

◆Related parameters ◆

Assignment of SU signal to terminal ⇒ Pr. 64 "RUN terminal function selection", Pr. 65 "A, B, C terminal function selection" (refer to page 110)

2.4.2 Output frequency detection (Pr. 42 213, Pr. 43 213)

The output frequency detection signal (FU) is output when the output frequency reaches or exceeds the setting. This function can be used for electromagnetic brake operation, open signal, etc. You can also set the frequency detection used exclusively for reverse rotation.



This function is effective for switching the timing of electromagnetic brake operation between forward rotation (rise) and reverse rotation (fall) during vertical lift operation, etc.

Parameter	Name	Factory Setting	Setting Range	Remai	·ks
42	Output frequency detection	6Hz	0 to 120Hz		Setting is
43	Output frequency detection for reverse rotation		0 to 120Hz,	· Cama ac	enabled when Pr. 30 = "1".

<Setting>

Refer to the above chart and set the corresponding parameters.

- •When Pr. 43 "output frequency detection for reverse rotation" ≠ "- -", the Pr.42 setting applies to forward rotation and the Pr.43 setting applies to reverse rotation.
- •Use Pr. 64 or Pr. 65 (output terminal function selection) to assign the terminal used for FU signal output.

CAUTION

Using Pr. 64 or Pr. 65 to change the terminal assignment may affect the other functions. Make setting after confirming the function of each terminal.

◆Related parameters ◆

Assignment of FU signal to terminal ⇒ Pr. 64 "RUN terminal function selection", Pr. 65 "A, B, C terminal function selection" (refer to page 110)

РЧЧ, РЧ5 **→** Refer to Р Л, Р 8 (раде 76).


 P48
 ➡
 Refer to
 P 8
 (page 71).

 PY?
 ▶ Refer to
 P 3 (page 73).

2.5 Current detection function

2.5.1 Output current detection functions (Pr. 48 EER. Pr. 49 EER)

If the output remains higher than the Pr. 48 setting during inverter operation for longer than the time set in Pr. 49, the output current detection signal (Y12) is output from the inverter's open collector output or contact output terminal.



Parameter	Name	Factory Setting	Setting Range	Remarks
48	Output current detection level	150%	0 to 200%	Setting is enabled when
49	Output current detection signal delay time	0s	0 to 10s	Pr. 30 = "1"

<Setting>

Parameter Number	Description
48	Set the output current detection level. 100% is the rated inverter current.
49	Set the output current detection period. Set the time from when the output current has risen above the Pr. 48 setting until the output current detection signal (Y12) is output.

Use Pr. 64 or Pr. 65 (output terminal function selection) to assign the terminal used for Y12 signal output.

CAUTION =

- Once turned ON, when the output current has risen above the preset detection level, the output current detection signal is held for at least 100ms (approximately).
- •Using Pr. 64 or Pr. 65 (output terminal function selection) to change terminal assignment may affect the other functions. Make setting after confirming the function of each terminal.

◆Related parameters ◆

Assignment of Y12 signal to terminal

Pr. 64 "RUN terminal function selection", Pr. 65 "A, B, C terminal function selection" (refer to page 110)

2.5.2 Zero current detection (Pr. 50 258, Pr. 51 258)

When the inverter's output current falls to "0[A]", torque will not be generated. This may cause a gravity drop when the inverter is used in vertical lift application.

OFF ON Start signal Pr.50 "zero current Output **♦** Pr.50 detection 100ms current 0 [A] OFF level" OFF Zero current detection signal Pr.51 Pr.51 output (Y13) detection period detection period

To prevent this, the output current "zero" signal can be output from the inverter to close the mechanical brake when the output current has fallen to "0[A]".

Parameter	Name	Factory Setting	Setting Range	Remarks
50	Zero current detection level			Setting is enabled when
51	Zero current detection period	0.5s	0.05 to 1s	Pr. 30 = "1"

POINT

If the output is lower than the Pr. 50 setting for longer than the time set in Pr. 51 during inverter operation, the zero current detection (Y13) signal is output from the inverter's open collector output terminal or contact output terminal.

<Setting>

Parameter	Description		
	Set the zero current detection level. Set the level of zero current detection in terms of the percentage of the rated inverter current from the output current value of 0 [A].		
51	Set the zero current detection period. Set a period of time from when the output current falls to or below the Pr. 50 setting to when the zero current detection signal (Y13) is output.		

Use Pr. 64 or Pr. 65 (output terminal function selection) to assign the terminal used for Y13 signal output.

CAUTION

- •If the current falls below the preset detection level but the timing condition is not satisfied, the zero current detection signal is held on for about 100ms.
- •Changing the terminal functions using Pr. 64 and Pr. 65 may affect the other functions. Please make setting after confirming the function of each terminal.
- •When running (connecting) multiple motors with one inverter in due order, the zero current detection signal (Y13) may be output. Set 13% or more for the 0.1K and 8% or more for the 0.2K.

(when the total capacity of motors is less than the zero current detection level and the motor capacity per inverter is less than the zero current detection level)

◆Related parameters ◆

Assignment of Y13 signal to terminal

Pr. 64 "RUN terminal function selection", Pr. 65 "A, B, C terminal function selection" (refer to page 110)

2.6 Display function

2.6.1 Monitor display (Pr. 52 252, Pr. 54 252)

You can choose the display of the operation panel "monitor/frequency setting screen".

Parameter	Name	Factory Setting	Setting Range	Remarks
52	Operation panel display data selection	0	0, 1, 100	Setting is enabled when Pr. 30 = "1"
1 54	FM terminal function selection	0	0, 1	

POINT

- •You can also use the (SET) to change the display. (Refer to the instruction manual (basic) for the operation procedure.)
- •The pulse train output terminal FM is available for signal output. (Make selection using the Pr. 54 "FM terminal function selection" value.)

<Setting>

		Paramete	er Setting		
Types of Monitor	Unit	Pr. 52	Pr. 54	Full-Scale Value of FM	
Types of Monitor	Omic	Operation panel LED	FM terminal	Level Meter	
Output frequency	Hz	0/100	0	Pr. 55 "frequency monitoring reference"	
Output current	Α	1	1	Pr. 56 "current monitoring reference"	

When "100" is set in Pr. 52, the monitored values during stop and during operation differ as indicated below.

Pr. 52					
0 100					
During running/stop	During stop	During running			
Output frequency	Set frequency	Output frequency			

REMARKS

- •During an error, its definition appears.
- •During reset, the values displayed are the same as during a stop.
- •For selection of the parameter unit (FR-PU04) monitor display, refer to the communication parameter n16 "PU main display screen data selection". (Page 165)

— CAUTION

The unit displayed on the operation panel is only A and other units are not displayed.

- ♦ Related parameters ♦

- Speed display ⇒ Pr. 37 "speed display" (refer to page 90)
- Adjustment of FM level meter full-scale value ⇒ Calibration parameter C1 "FM terminal calibration" (refer to page 138)
- Monitoring reference ⇒Pr. 55 "frequency monitoring reference", Pr. 56 "current monitoring reference" (refer to page 101)

2.6.2 Setting dial function selection (Pr. 53 PR)

You can use the dial like a potentiometer to perform operation.

Parameter	Name	Factory Setting	Setting Range	Remarks	
53	Frequency setting operation selection	0	0, 1	mode	Setting is enabled when Pr. 30 = "1"

Using the setting dial like a potentiometer to perform operation


POINT

- •Set "1" (extended function parameter valid) in Pr. 30 "extended function display selection".
- •Set "1" (setting dial potentiometer mode) in Pr. 53 "frequency setting operation selection".

Operation example Changing the frequency from 0Hz to 60Hz during operation

Operation — — Display or check

- 1. Mode/monitor check
 - Choose monitor/frequency monitor. (MODE)
 - The inverter must be in the PU operation mode. (Press the $\frac{PU}{EXT}$.)
 - Pr. 30 must be set to "1".
 - OPr. 53 must be set to "1".



3. Turn the Cockwise until "60.0" appears. The flickering frequency is the set frequency. You need not press the set frequency.




REMARKS

- •If flickering "60.0" turns to "0.0", the Pr. 53 "frequency setting operation selection" setting may not be "1".
- •Independently of whether the inverter is running or at a stop, the frequency can be set by merely turning the dial.
- •When the frequency is changed, it will be stored as the set frequency after 10s.

2.6.3 Monitoring reference (Pr. 55 PS, Pr. 56 PS)

Set the frequency or current which is referenced when the output frequency or output current is selected for the terminal FM.



Parameter	Name	Factory Setting	Setting Range	Remarks
55	Frequency monitoring reference	60Hz	0 to 120Hz	Setting is enabled when
56	Current monitoring reference	Rated inverter current	0 to 50A	Pr. 30 = "1"

<Setting>

Refer to the above diagrams and set the frequency monitoring reference value in

Pr. 55 and the current monitoring reference value in Pr. 56.

Pr. 55 is set when Pr. 54 "FM terminal function selection" = "0" and Pr. 56 is set when Pr. 54 = "1".

Set the Pr. 55 and Pr. 56 values so that the output pulse train output of terminal FM is 1440 pulses/s.

_ CAUTION _

The maximum pulse train output of terminal FM is 2400 pulses/s. If Pr. 55 is not adjusted, the output of terminal FM will be filled to capacity. Therefore, adjust Pr. 55.

2.7 Restart operation function

2.7.1 Restart setting (Pr. 57 1958), Pr. 58 1958, H6 1958)

At power restoration after an instantaneous power failure, you can restart the inverter without stopping the motor (with the motor coasting).


Parameter	Name	Factory Setting	Setting Range	Remarks
57	Restart coasting time		0 to 5s,	
58	Restart cushion time	1s	0 to 60s	Setting is enabled when Pr. 30 = "1"
H6 (162)	Automatic restart after instantaneous power failure selection	1	0, 1, 10	

The parameter number in parentheses is the one for use with the parameter unit (FR-PU04).

<Setting>

Refer to the following table and set the parameters:

Parameter		Setting	Descri	ption	
	0	0.1K to 1.5K	Coasting time of 0.5s	Generally, this setting will pose	
		2.2K, 3.7K	Coasting time of 1.0s no problems.		
0.1 to 5s			Waiting time for inverter-triggered restart after power is restored from an instantaneous power failure. (Set this time between 0.1 and 5s according to magnitude of the moment (J) of inertia of the load and torque.)		
			No restart (factory setting)		
58		0 to 60s	Normally the motor may be run with the factory settings. These values are adjustable to the load (moment of inertia, torque).		
		0	With speed search The motor coasting speed is dete failure is detected.	ected after instantaneous power	
H6 (162) 1		1	Without speed search (factory setting) Automatic restart operation after instantaneous power failure is a reduced voltage starting system in which the output voltage is risen gradually at the preset frequency independently of the coasting speed of the motor.		
		10	With speed search at starting The motor coasting speed is dete failure and at starting.	ected after instantaneous power	



^{*}The output shut off timing differs according to the load condition.

REMARKS

•When the start signal is turned off during power failure and power is restored

Without speed search (H6=1): Decelerates to stop after running in the same direction before power failure. Note that the motor will coast if the start signal is turned off during restart operation.

If the start signal turns on upon power restoration, the inverter starts at the starting frequency (Pr. 13). Keep the starting signal on during power failure.

With speed search (H6=0,10): The motor will coast.

- •With speed search (H6=0,10)
- It will start at the starting frequency (Pr.13) when the speed search is less than 10Hz.
- Restart operation is also performed after the inverter reset and retry reset.
- The motor starts at the starting frequency when an instantaneous power failure occurs during restart voltage cushion time.
- When the special motor is used, speed search can not be performed, the motor may start at the starting frequency.
- •When speed search is selected (H6=0), automatic restart operation at a start is first performed after powering on and normal restart is performed thereafter.
- When speed search at starting (H6=10) is selected, restart operation is performed at each starting.
- There is delay time (Pr. 57 setting + speed search time) until frequency is output after the start command is input during restart operation.
- •If two or more motors are connected to one inverter, speed search is not performed properly. Select without speed search (H6=1)
- •The SU and FU signals are not output during a restart. They are output after the restart cushion time has elapsed.

CAUTION =

For the restart after instantaneous power failure operation without speed search (H6=1), the state (output frequency, rotation direction) before an instantaneous power failure cannot be stored in memory if the instantaneous power failure time is 0.2s or longer (changes according to the motor load condition) and the inverter restarts at the starting frequency (Pr.13).

ACAUTION

- Mhen automatic restart after instantaneous power failure has been selected, the motor and machine will start suddenly (after the restart coasting time has elapsed) after occurrence of an instantaneous power failure. Stay away from the motor and machine.
 - When you have selected automatic restart after instantaneous power failure, apply in easily visible places the CAUTION stickers supplied to the instruction manual (basic).
- The motor is coasted to a stop as soon as you turn off the start signal or press the (STOP) during the restart cushion time after instantaneous power failure.


→ Related parameters →

•Retry reset ⇒ Pr.66 to Pr.69 (retry function) (Refer to page 111.)

2.8 Additional function

2.8.1 Remote setting function selection (Pr. 59 PS)

Even if the operation panel is located away from the enclosure, you can use contact signals to perform continuous variable-speed operation, without using analog signals.



* External running frequency (other than multi-speed) or PU running frequency

Parameter	Name	Factory Setting	Setting Range	Remarks
59	Remote setting function selection	0	0, 1, 2	Setting is enabled when Pr. 30 = "1"

REMARKS

- •By merely setting this parameter, you can use the acceleration, deceleration and setting clear functions of the motorized speed setter (FR-FK).
- •When the remote function is used, the output frequency of the inverter can be compensated for as follows:


External operation mode Frequency set by RH/RM operation plus external analog

frequency command

PU operation mode Frequency set by RH/RM operation plus setting dial or PU

digital preset frequency

<Operation panel operation procedure>



* When you have set "1" in Pr. 53 "frequency setting operation selection", you need not press the (SET).

<Setting>

	Operation			
Pr. 59 Setting	Remote setting function	Frequency setting storage function (EEPROM)		
0	No			
1	Yes	Yes		
2	Yes	No		

- •Use Pr. 59 to select whether the remote setting function is used or not and whether the frequency setting storage function* in the remote setting mode is used or not. When "remote setting function yes" is selected, the functions of signals RH, RM and RL are changed to acceleration (RH), deceleration (RM) and clear (RL), respectively. Use Pr. 60 to Pr. 63 (input terminal function selection) to set the signals RH, RM, RL.
 - * Frequency setting storage function
 - This function stores the remotely-set frequency (frequency set by RH/RM operation) into memory.
 - When power is switched off once, then on, operation is resumed with that output frequency value. (Pr. 59="1")

<Frequency setting storage conditions>

- •The frequency at which the start signal (STF or STR) turns off is stored.
- •The remotely-set frequency is stored every one minute after one minute has elapsed since turn off (on) of both the RH (acceleration) and RM (deceleration) signals. (The frequency is written if the present frequency setting compared with the past frequency setting every one minute is different.) (The state of the RL signal dose not affect writing.)


REMARKS

•This function is invalid under jog operation and PID control operation.


Setting frequency is "0"

•Even when the remotely-set frequency is cleared by turning on the RL (clear) signal after turn off (on) of both the RH and RM signals, the inverter operates at the remotely-set frequency stored in the last operation if power is reapplied before one minute has elapsed since turn off (on) of both the RH and RM signals

remotely-set frequency stored in the last operation




•When the remotely-set frequency is cleared by turning on the RL (clear) signal after turn off (on) of both the RH and RM signals, the inverter operates at the speed in the remotely-set frequency cleared state if power is reapplied after one minute has elapsed since turn off (on) of both the RH and RM signals.



CAUTION

•The range of frequency changeable by RH (acceleration) and RM (deceleration) is 0 to maximum frequency (Pr. 1 setting). Note that the maximum value of set frequency is (main speed + maximum frequency).



- •When the acceleration or deceleration signal switches on, the set frequency varies according to the slope set in Pr. 44 "second acceleration/deceleration time" or Pr. 45 "second deceleration time". The output frequency acceleration and deceleration times are as set in Pr. 7 "acceleration time" and Pr. 8 "deceleration time", respectively. Therefore, the longer preset times are used to vary the actual output frequency.
- •If the start signal (STF or STR) is off, turning on the acceleration (RH) or deceleration (RM) signal varies the preset frequency.

CAUTION

When selecting this function, re-set the maximum frequency according to the machine.

◆Related parameters ◆

- RH, RM, RL signal terminal assignment ⇒ Pr. 60 to Pr. 63 (input terminal function selection)
 (Refer to page 108.)
- Maximum frequency setting ⇒ Pr. 1 "maximum frequency" (Refer to page 72.)
- Output frequency acceleration/deceleration time ⇒ Pr. 7 "acceleration time",
 Pr. 8 "deceleration time" (Refer to page 76.)
- Time setting for acceleration/deceleration ⇒ Pr. 44 "second acceleration/deceleration time", Pr. 45 "second deceleration time" (Refer to page 76.)

2.9 Terminal function selection

2.9.1 Input terminal function selection (Pr. 60 251, Pr. 61 251, Pr. 62 251, Pr. 63 251)

Use these parameters to select/change the input terminal functions.

Parameter	Name	Factory Setting	Setting Range	Remarks
60	RL terminal function selection	0		
61	RM terminal function selection	1		Setting is enabled
62	RH terminal function selection	2		when Pr. 30 = "1"
63	STR terminal function selection		0 to 10, 14, 16,	

<Setting>

Refer to the following table and set the parameters:

Setting	Signal Name	Fund	etions	Related Parameters
0	RL	Pr. 59 = "0"	Low-speed run command	Pr. 4 to Pr. 6, Pr. 24 to Pr. 27, Pr. 80 to Pr. 87
0	KL	Pr. 59 = "1", "2" (*1)	Remote setting (setting clear)	Pr. 59
1	RM	Pr. 59 = "0"	Middle-speed run command	Pr. 4 to Pr. 6, Pr. 24 to Pr. 27, Pr. 80 to Pr. 87
ľ	TXIVI	Pr. 59 = "1", "2" (*1)	Remote setting (deceleration)	Pr. 59
2	RH	Pr. 59 = "0"	High-speed run command	Pr. 4 to Pr. 6, Pr. 24 to Pr. 27, Pr. 80 to Pr. 87
2	IXII	Pr. 59 = "1", "2" (*1)	Remote setting (acceleration)	Pr. 59
3	RT	Second function selection		Pr. 44 to Pr. 47, H7
4	AU	Current input selection		
5	STOP	Start self-holding sele	ction	
6	MRS	Output shut-off stop		
7	ОН	External thermal relay The inverter stops wh provided thermal rela protection, motor's en relay etc. is actuated.	en the externally y for overheat nbedded temperature	Refer to page 174.
8	REX	15-speed selection (c speeds RL, RM, RH)		Pr. 4 to Pr. 6, Pr. 24 to Pr. 27, Pr. 80 to Pr. 87
9	JOG	Jog operation selection	on	Pr. 15, Pr. 16
10	RES	Reset		Pr. 75
14	X14	PID control presence		Pr. 88 to Pr. 94
16	X16	PU-external operation	n switch-over	Pr. 79 (setting: 8)
	STR	Reverse rotation start		(can be assigned to STR terminal (Pr. 63) only)

^{*1.}When Pr. 59 = "1 or 2", the functions of the RL, RM and RH signals change as listed above.

REMARKS

- •One function can be assigned to two or more terminals. In this case, the function is activated when one of the multiple terminals used for assignment turns on.
- •The speed command priorities are higher in order of jog, multi-speed setting (RH, RM, RL, REX) and AU.
- •Use common terminals to assign multi-speeds (7 speeds) and remote setting. They cannot be set individually.

(Common terminals are used since these functions are designed for speed setting and need not be set at the same time.)

^{*2.}Actuated when the relay contact "opens".

^{*3.} When using the REX signal, an external command cannot be used to make a reverse rotation start.

2.9.2 Output terminal function selection (Pr. 64 251, Pr. 65 251)

You can change the functions of the open collector output terminal and contact output terminal.

Parameter	Name	Factory Setting	Setting Range	Remarks
64	RUN terminal function selection	0		Setting is enabled
65	A, B, C terminal function selection	99	0, 1, 3, 4, 11 to 16, 95, 98, 99	when Pr. 30 = "1"

<Setting>

Setting	Signal Name	Function	Operation	Parameters Referred to
0	RUN	Inverter running	Output during operation when the inverter output frequency rises to or above the starting frequency.	Pr. 2, Pr. 13
1	SU	Up to frequency	Output when the output frequency is reached.	Pr. 41
3	OL	Overload alarm	Output while stall prevention function is activated.	Pr. 21, Pr. 22, Pr. 23, Pr. 28
4	FU	Output frequency detection	Output when the output frequency rises to or above the setting.	Pr. 42, Pr. 43
11	RY	Inverter operation ready	Output when the inverter is ready to be started by switching the start signal on.	_
12	Y12	Output current detection	Output when the output current rises to or above the setting.	Pr. 48, Pr. 49
13	Y13	Zero current detection	Output when the output current reaches 0.	
14	FDN	PID lower limit		
15	FUP	PID upper limit	Outputs the detection signal	Pr. 88 to Pr. 94
16	RL	PID forward-reverse rotation output	under PID control.	F1. 00 to F1. 94
93	Y93	Current average value monitor signal	The output current average value and maintenance timer value are output during the constant speed operation. (can be set to the RUN terminal (Pr.64) only)	H3 to H5
95	Y95	Maintenance timer alarm	Output when additional parameter H1 is greater than maintenance parameter H2.	H1, H2
98	LF	Minor fault output	Output when a minor fault (fan failure or communication error warning) occurs.	Pr. 76, n5
99	ABC	Alarm output	Output when the inverter's protective function is activated to stop the output (major fault).	_

REMARKS

One function can be assigned to two terminals.

2.10 Operation selection function

2.10.1 Retry function (Pr. 66 258, Pr. 67 258, Pr. 68 258, Pr. 69 258)

When any protective function (major fault) is activated and the inverter stops its output, the inverter itself resets automatically and performs retries. Whether retry is performed or not, alarms for retry, number of retries made and waiting time can be selected.

When you have selected automatic restart after instantaneous power failure (with speed search), restart operation is performed at the retry operation time which is the same of that of a power failure. (Refer to page 101 for automatic restart function.)

Parameter	Name	Factory Setting	Setting Range	Remarks
66	Retry selection	0	0 to 3	
67	Number of retries at alarm occurrence	0	101 10 110	Setting is enabled when Pr. 30 = "1"
68	Retry waiting time	1s	0.1 to 360s	171. 30 - 1
69	Retry count display erase	0	0	

<Setting>

•Use Pr. 66 to select the protective functions (major faults) to be activated for retries.

Pr. 66		Protective Functions (Major Faults) for Retries												
Setting	OCT	OVT	THM	THT	BE	FIN	GF	OHT	OLT	PE	PUE	RET	CPU	OPT
0	•	•	•	•	•		•	•	•	•				•
1	•													
2		•												
3	•	•												

- * Indicates the retry items selected. (OCT denotes any of OC1 to OC3 and OVT any of OV1 to OV3.)
- •Use Pr. 67 to set the number of retries at alarm occurrence.

Pr. 67 Setting	Number of Retries	Alarm Signal (ABC) Output
0	Retry is not made.	
1 to 10	1 to 10 times	Not provided during retry operation *
101 to 110	1 to 10 times	Output every time

- * If the retry count is exceeded, " F, " (retry count over) is displayed.
- •Use Pr. 68 to set the waiting time from when an inverter alarm occurs until a restart in the range 0.1 to 360s.
- Reading the Pr. 69 value provides the cumulative number of successful restart times made by retry. The cumulative number of time is cleared when setting value "0" is written.

— CAUTION =

- •The cumulative number in Pr. 69 is incremented by "1" when retry operation is regarded as successful, i.e. when normal operation is continued without the protective function (major fault) activated during a period four times longer than the time set in Pr. 68.
- •If the protective function (major fault) is activated consecutively within a period four times longer than the above waiting time, the operation panel may show data different from the most recent data or the parameter unit (FR-PU04) may show data different from the first retry data. The data stored as the error reset for retry is only that of the protective function (major fault) which was activated the first time.
- •When an inverter alarm is reset by the retry function at the retry time, the stored data of the electronic thermal relay function, etc. are not cleared. (Different from the power-on reset.)

ACAUTION

⚠ When you have selected the retry function, stay away from the motor and machine unless required. They will start suddenly (after the reset time has elapsed) after occurrence of an alarm.

When you have selected the retry function, apply in easily visible places the CAUTION stickers supplied to the instruction manual (basic).

2.10.2 PWM carrier frequency and long wiring mode (Pr. 70 PM, Pr. 72 PM)

You can change the motor sound.

Parameter	Name	Factory Setting Setting Range		Remarks
70	Soft-PWM setting	1	0, 1, 10, 11	Setting is enabled when
72	PWM frequency selection	1	0 to 15	Pr. 30 = "1"

<Setting>

- By parameter setting, you can set whether to exercise Soft-PWM control that changes the motor tone or select with or without long wiring mode.
- Soft-PWM control is a control method that changes the motor noise from a metallic tone into an unoffending complex tone.
- Surge voltage is suppressed regardless of wiring length in the long wiring mode. (When operating the 400V motor with wiring length of 40m or longer, select the long wiring mode.)

Pr. 70		Descripti	on		
Setting	Soft-PWM	Long wiring mode	Remarks		
0	Invalid	Invalid			
1	Valid (When Pr. 72 setting = any of "0" to "5")	Invalid			
10	Invalid	Valid	When Pr. 72 "PWM frequency selection" = 1 or more, the PWM carrier frequency is constant at		
11	Valid	Valid	1kHz. (When "0" is set, the PWM carrier frequency is constant at 0.7kHz.)		

CAUTION

- 1.When "10 or 11" (long wiring mode) is set in Pr. 70, the output voltage at rated frequency drops 5V maximum.
- 2.For the 400V class, use an insulation-enhanced motor. Refer to page 25 for an inverter-driven 400V class motor.

Pr. 72 Setting	Description				
0 to 15	PWM carrier frequency can be changed. The setting displayed is in [kHz]. Note that 0 indicates 0.7kHz and 15 indicates 14.5kHz.				

REMARKS

- An increased PWM frequency will decrease the motor sound but increase noise and leakage currents. Therefore, perform the reduction techniques. (Refer to page 18.)
- •Metallic sound may be generated from the motor at sudden deceleration but it is not a fault.

P? ! → Refer to P 9 (page 78).

2.10.3 Voltage input selection (Pr. 73 PB)

You can change the input (terminal 2) specifications according to the frequency setting voltage signal. When entering 0 to 10VDC, always make this setting.

Parameter	Name	Factory Setting	Setting Range	Remark	s
/3	0-5V/0-10V selection	0	*	IO' O-5VIDC INDUIT	Setting is enabled when Pr. 30 = "1"

CAUTION

- •The acceleration/deceleration time, which is a slope up/down to the acceleration/deceleration reference frequency, is not affected by the change in Pr. 73 setting.
- •When connecting a frequency setting potentiometer across terminals 10-2-5 for operation, always set "0" in this parameter.

2.10.4 Input filter time constant (Pr. 74 PPS)

You can set the input section's built-in filter constant for an external voltage or current frequency setting signal.

• Effective for eliminating noise in the frequency setting circuit.

Parameter	Name	Factory Setting	Setting Range	Remarks
/4	Input filter time constant	1	0 to 8	Setting is enabled when Pr. 30 = "1"

<Setting>

Increase the filter time constant if steady operation cannot be performed due to noise. A larger setting results in slower response. (The time constant can be set between approximately 1ms to 1s with the setting of 0 to 8. A larger setting results in a larger filter time constant.)

2.10.5 Reset selection/PU stop selection (Pr. 75 PS)

You can make reset input acceptance selection and choose the stop function from the operation panel (PU).

- Reset selection : You can choose the reset function input (RES signal) timing.
- PU stop selection: When an alarm etc. occurs in any operation mode, you can
 make a stop from the operation panel by pressing the (STOP)
 RESET.

Parameter	Name	Factory Setting	Setting Range	Remarks
/5	Reset selection/ PU stop selection	14	0, 1, 14, 15	Setting is enabled when Pr. 30 = "1"

<Setting>

Pr. 75 Setting	Reset Selection	PU Stop Selection		
0	Reset input normally enabled.	The PU stop key is invalid. Note that the STOP is		
1	Enabled only when the protective function is activated.	valid only in the PU operation mode or combined operation mode (Pr. 79 = "4").		
14	Reset input normally enabled.	Pressing the (STOP) decelerates the inverter to a		
15	Enabled only when the protective function is activated.	stop in any of the PU, external and communication operation modes.		


(1) How to make a restart after a stop by the $\frac{\text{STOP}}{\text{RESET}}$ input from the operation panel (Restarting method with $\boxed{P5}$ shown)

1. After completion of deceleration to a stop, switch off the STF or STR signal.

2. Press the PU to show PU (P5 canceled)

3. Press the $\frac{PU}{EXT}$ to return to $\frac{EXT}{EXT}$.

4. Switch on the STF or STR signal.



Stop and restart example for external operation

REMARKS

- •If the reset signal (RES) is provided during operation, the inverter shuts off its output while it is reset, the internal thermal integrated value of the electronic thermal relay function and the number of retries are reset, and the motor coasts.
- •The Pr. 75 value can be set any time. Also, if parameter (all) clear is executed, this setting will not return to the initial value.
- •When the inverter is stopped by the PU stop function, the display alternates between PS and $\Pi\Pi$. An alarm is not output.


(2) How to make a restart when a stop is made by the RESET input from the parameter unit

1. After completion of deceleration to a stop, switch off the STF or STR signal.

2. Press the EXT

(**P5** canceled)

3. Switch on the STF or STR signal.



Stop and restart example for external operation

Besides the above operations, a restart can be made by performing a power-on reset or resetting the inverter with the inverter's reset terminal.

REMARKS

- •If the reset signal (RES) is provided during operation, the inverter shuts off its output while it is reset, the internal thermal integrated value of the electronic thermal relay function and the number of retries are reset, and the motor coasts.
- •To resume operation, reset the inverter after confirming that the parameter unit is connected securely.
- •The Pr. 75 value can be set any time. Also, if parameter (all) clear is executed, this setting will not return to the initial value.
- •When the inverter is stopped by the PU stop function, PS is displayed but an alarm is not output.

⚠CAUTION

 \triangle Do not reset the inverter with the start signal on. Otherwise, the motor will start instantly after resetting, leading to potentially hazardous conditions.

2.10.6 Cooling fan operation selection (Pr. 76

You can control the operation of the cooling fan built in the inverter (whether there is a cooling fan or not depends on the model.).

Parameter	Name	Factory Setting	Setting Range	Remarks
	Cooling fan			0: Operation is performed with Setting is
76	operation	1	0, 1	power on. enabled when
	selection			1: Cooling fan ON/OFF control Pr. 30 = "1"

<Setting>

Setting	Description
0	Operated at power on (independent of whether the inverter is running or at a stop).
1	Cooling fan ON/OFF control valid Always on during inverter operation During stop (reset or error), the inverter status is monitored and the fan is switched on/off according to the temperature. Heatsink temperature is less than 40°C

REMARKS

In either of the following cases, fan operation is regarded as faulty, F_{n} is shown on the operation panel, and the minor fault (LF) signal is output. Use any of Pr. 64, Pr. 65 (output terminal function selection) to allocate the terminal used to output the LF signal.*

•Pr. 76 = "0"

When the fan comes to a stop with power on.

When the inverter is running and the fan stops during fan ON command.

CAUTION

* When the terminal assignment is changed using Pr. 64, Pr. 65, the other functions may be affected. Confirm the functions of the corresponding terminals before making settings.

2.10.7 Parameter write disable selection (Pr. 77 Parameter write disable

You can select between write-enable and disable for parameters. This function is used to prevent parameter values from being rewritten by incorrect operation.

Parameter	Name	Factory Setting	Setting Range	Remarks
77	Parameter write disable selection	0	0, 1, 2	Setting is enabled when Pr. 30 = "1"

<Setting>

Pr. 77 Setting	Function			
0	Write is enabled only during a stop in the PU operation mode. (*)			
1	Write disabled.			
'	Values of Pr. 22, Pr. 30, Pr. 75, Pr. 77 and Pr. 79 can be written.			
2	Write is enabled even during operation. Write is enabled independently of			
2	the operation mode.			

^{*} The shaded parameters in the parameter list always allow setting. Note that the Pr. 70 and Pr. 72 values may be changed during PU operation only.

___ CAUTION =

- •If Pr. 77 = 2, the values of Pr. 17, Pr. 23, Pr. 28, Pr. 60 to Pr. 63, Pr. 64, Pr. 65, Pr. 71, Pr. 79, Pr. 98, Pr. 99, CLr cannot be written during operation. Stop operation when changing their parameter settings.
- •By setting "1" in Pr. 77, the following clear operations can be inhibited:
 - Parameter clear
 - All clear

2.10.8 Reverse rotation prevention selection (Pr. 78 PR)

This function can prevent reverse rotation faults resulting from the incorrect input of the start signal.

POINT

Used for a machine which runs only in one direction, e.g. fan, pump. (The setting of this function is valid for the combined, PU, external and communication operations.)

Parameter	Name	Factory Setting	Setting Range	Remarks
l 78	Reverse rotation prevention selection	0	0, 1, 2	Setting is enabled when Pr. 30 = "1"

<Setting>

Pr. 78 Setting	Function
0	Both forward and reverse rotations allowed
1	Reverse rotation disallowed
2	Forward rotation disallowed

2.10.9 Operation mode selection (Pr. 79 PM)

Used to select the operation mode of the inverter.

The inverter can be run from the operation panel or parameter unit (PU operation), with external signals (external operation), or by combination of PU operation and external operation (external/PU combined operation).

The inverter is placed in the external operation mode at power on (factory setting).

Г	Parameter	Name	Factory Setting	Setting Range
	79	Operation mode selection	0	0 to 4, 7, 8

^{*} Pr. 79 can be changed during a stop in any operation mode.

<Setting>

In the following table, operation using the operation panel or parameter unit is abbreviated to PU operation.

Pr. 79 Setting		Function	LED Indication *	RUN PU EXT PU	EXT	
0	At power on, the inverter is put in the external operation mode. The operation mode can be changed between the PU and external operation modes from the operation panel $(\frac{PU}{EXT})$ or parameter unit $(\frac{PU}{EXT})$. For each mode, refer to the columns of settings 1 and 2.					r to ngs nd
1	Operation mode PU operation mode	Running frequency Setting from operation panel or FR-PU04	Start signal	Off: Stop without start command	On (Off)	Off
2	External operation mode	External signal input (across terminals 2(4)-5, multi-speed selection) jog	External signal input (terminal STF, STR)	Forward rotation: On Reverse rotation: Slow flickering	Off	On
3	External/ PU combined operation mode 1	Setting dial of operation panel, digital setting by parameter unit key operation, or external signal input (multi-speed setting, across terminals 4-5 (valid when AU signal is on))	External signal input (terminal STF, STR)	With start command Without frequency setting	On	On
4	External/ PU combined operation mode 2	External signal input (across terminals 2(4)-5, multi-speed selection, jog)	RUN			
7	MRS signal C	ation mode (PU operation into DN Switching to PU operation (output stop during exte operation) allowed FF Switching to PU operation		Refe settir	ngs	
8	during operation X16 signal Of	de change using external signa on) N Switched to external op mode FSwitched to PU operation	eration		"2".	ΠŪ

REMARKS

- •In other than the PU operation mode, the stop function (PU stop selection) activated by pressing (STOP) of the PU (operation panel/FR-PU04) is valid. (Refer to page 115.)
- •Either "3" or "4" may be set to select the PU/external combined operation, and these settings differ in starting method.
- •Refer to page 142 for the computer link operation mode.
- *When the FR-PU04 is connected, the LED indicators (PU, EXT) are not lit. In the computer link operation mode, the LED indicators (PU, EXT) flicker slowly.

(1) PU operation interlock

The PU operation interlock function is designed to forcibly change the operation mode to external operation mode when the MRS signal switches off. This function prevents the inverter from being inoperative by the external command if the mode is accidentally left unswitched from PU operation mode.

1) Preparation

- •Set "7" (PU operation interlock) in Pr. 79.
- Set the terminal used for MRS signal input with any of Pr. 60 to Pr. 63 (input terminal function selection).

Refer to page 108 for Pr. 60 to Pr. 63 (input terminal function selection).

CAUTION =

Changing the terminal assignment using Pr. 60 to Pr. 63 (input terminal function selection) may affect the other functions.

Check the functions of the corresponding terminals before making settings.

2) Function

MRS Signal	Function/Operation			
	Output stopped during external operation.			
ON	Operation mode can be switched to PU operation mode.			
ON	Parameter values can be rewritten in PU operation mode.			
	PU operation allowed.			
	Forcibly switched to external operation mode.			
OFF	External operation allowed.			
	Switching to PU operation mode inhibited.			

<Function/operation changed by switching on-off the MRS signal>

Operating Condition		MRS	Operation		Parameter	Switching to
Operation mode	Status	Signal	Mode (*2)	Operating Status	Write	PU Operation Mode
	During stop	ON → OFF (*1)		During stop	Allowed → disallowed	Disallowed
PU	During operation	ON → OFF (*1)	PU → External	If external operation frequency setting and start signal are entered, operation is performed in that status.	Allowed → disallowed	Disallowed
	During	$OFF \to ON$		During stop	Disallowed → disallowed	Allowed
External	stop	$ON \rightarrow OFF$	External	During Stop	Disallowed → disallowed	Disallowed
LAGINAI	During	OFF \ ON		During operation → output stop	Disallowed → disallowed	Disallowed
	operation	$ON \rightarrow OFF$		Output stop → operation	Disallowed → disallowed	Disallowed

REMARKS

- •If the MRS signal is on, the operation mode cannot be switched to the PU operation mode when the start signal (STF, STR) is on.
- *1. The operation mode switches to the external operation mode independently of whether the start signal (STF, STR) is on or off.
 - Therefore, the motor is run in the external operation mode when the MRS signal is switched off with either of STF and STR on.
- *2. Switching the MRS signal on and rewriting the Pr. 79 value to other than "7" in the PU operation mode causes the MRS signal to act as the ordinary MRS function (output stop). Also as soon as "7" is set in Pr. 79, the signal acts as the PU interlock signal.

(2) Operation mode switching by external signal

1) Preparation

Set "8" (switching to other than external operation mode) in Pr. 79. Use any of Pr. 60 to Pr. 63 (input terminal function selection) to set the terminal used for X16 signal input.

CAUTION =

Changing the terminal assignment using Pr. 60 to Pr. 63 (input terminal function selection) may affect the other functions.

Check the functions of the corresponding terminals before making settings.

For details refer to page 108.

2) Function

This switching is enabled during an inverter stop only and cannot be achieved during operation.

X16 Signal	Operation Mode
ON	External operation mode (cannot be changed to PU operation mode)
OFF	PU operation mode (cannot be changed to external operation mode)

| P80 | to | P87 | ➡ Refer to | P 4 | to | P 5 | (page 75).

2.10.10 PID control (Pr. 88 288 to Pr. 94 288)

The inverter can be used to exercise process control, e.g. flow rate, air volume or pressure.

■ The voltage input signal (0 to +5V or 0 to +10V) or Pr. 93 setting is used as a set point and the 4 to 20mADC current input signal used as a feedback value to constitute a feedback system for PID control.


POINT

Made valid by turning on the X14 signal. Use Pr. 60 to Pr. 63 (input terminal function selection) to make assignment.

Parameter	Name	Factory Setting	Setting Range	Remarks
88	PID action selection	20	20, 21	
89	PID proportional band	100%	0.1 to 999%,	
90	PID integral time	1s	0.1 to 999s,	
91	PID upper limit		0 to 100%,	Setting is enabled
92	PID lower limit		0 to 100%,	when Pr. 30 = "1"
9.3	PID action set point for PU operation	0%	0 to 100%	
94	PID differential time		0.01 to 10s,	

<Setting>

(1) Basic PID control configuration



Kp: Proportion constant Ti: Integral time S: Operator Td: Differential time

(2) PID action overview


1) PI action

A combination of proportional control action (P) and integral control action (I) for providing a manipulated variable in response to deviation and changes with time.

REMARKS

PI action is the sum of P and I actions.

[Operation example for stepped changes of measured value]



2) PD action

A combination of proportional control action (P) and differential control action (D) for providing a manipulated variable in response to deviation speed to improve the transient characteristic.

REMARKS


PD action is the sum of P and D actions.


PID action
 The PI action and PD action are combined to utilize the advantages of both actions for control.

REMARKS


The PID action is the sum of P, I and D actions.

[Operation example for proportional changes of measured value]







4) Reverse action
Increases the manipulated
variable (output frequency) if
deviation X = (set point measured value) is positive, and
decreases the manipulated
variable if deviation is negative.



[Heating]

5) Forward action
Increases the manipulated
variable (output frequency) if
deviation X = (set point measured value) is negative,
and decreases the manipulated
variable if deviation is positive.






Relationships between deviation and manipulated variable (output frequency)

	Deviation		
	Positive	Negative	
Reverse action	7	Ä	
Forward action	Ä	7	

(3) Wiring example



CAUTION

- *1. The power supply must be selected in accordance with the power specifications of the detector used.
- *2. The output signal terminals used depends on the Pr. 64, Pr. 65 settings.
- *3. The input signal terminal used depends on the setting of Pr. 60 to Pr. 63.
- The contact input signal (AU Signal) need not be turned on.

(4) I/O signals

Sign	nal	Terminal Used	Function	Description	
	X14	Depending on	PID control	Turn on X14 to exercise PID control.	
	A14	Pr. 60 to Pr. 63	selection	Tulli on X14 to exercise FID control.	
Input	2	2	Set point input	Enter the set point for PID control.	
	4	4	Measured value	Enter the 4 to 20mADC measured value	
	4	4	input	signal from the detector.	
	FUP		Upper limit output	Output to indicate that the measured value	
	FUF			signal exceeded the upper limit value.	
	FDN		Lower limit output	Output to indicate that the measured value	
O t t	I DIN	Depending on		signal exceeded the lower limit value.	
Output		Pr. 64, Pr. 65	Forward (reverse)	"Hi" is output to indicate that the output	
	DI	RL	rotation direction	indication of the parameter unit is forward	
	KL			rotation (FWD) or "Low" to indicate that it is	
			output	reverse rotation (REV) or stop (STOP).	

- Enter the set point across inverter terminals 2-5 or in Pr. 93 and enter the measured value signal across inverter terminals 4-5.
- To exercise PID control, turn on the X14 signal. When this signal is off, PID control is not exercised.


Item	Entry	Description				
	ACTOSS	Set 0V as 0% and 5V as 100%.	When "0" is set in Pr. 73 (5V selected for terminal 2).			
Set point	terminals 2-5	Set 0V as 0% and 10V as 100%.	When "1" is set in Pr. 73 (10V selected for terminal 2).			
	Pr. 93	Set the set point (%) in Pr. 93.				
Measured value	Across terminals 4-5	4mA is equivalent to 0% and 20mA to 100%.				

(5) Parameter setting

Parameter Number	Name	Setting	Description		
88	PID action	20	For heating, pressure control, etc. PID reverse ac		
00	selection	21	For cooling, etc.	PID forward action	
89	PID proportional band	0.1 to 999%	If the proportional band is narrow (parameter setting is small), the manipulated variable varies greatly with a sli change of the measured value. Hence, as the proportio band narrows, the response sensitivity (gain) improves the stability deteriorates, e.g. hunting occurs. Gain K = 1/proportional band		
			No proportional control		
90	90 PID integral 0.1 to 999s time		Time required for the integral (I) action to provide the same manipulated variable as that for the proportional (P) action. As the integral time decreases, the set point is reached earlier but hunting occurs more easily.		
			No integral control.		


Parameter Number	Name	Setting	Description
- Trainison			Set the upper limit. If the feedback value exceeds the
04	PID upper	0 to 100%	setting, the FUP signal is output. (Measured value of
91	limit		4mA is equivalent to 0% and 20mA to 100%.)
			No function
			Set the lower limit. (If the measured value falls below
	PID lower	0 to 100%	the setting, the FDN signal is output. In this case, the
92	limit	0 to 100%	measured value of 4mA is equivalent to 0% and 20mA
	IIIIII		to 100%.)
			No function
	PID action set point for PU operation		Valid only when Pr. 79 = "3" (n9 = 0 for computer link
		r 0 to 100%	operation) under the PU command in the PU operation
			or PU/external combined mode. (When the computer
00			has the speed command source in the computer link
93			operation mode (NET))
			For external operation, the voltage across 2-5 is the set
			point.
			(C3 value is equivalent to 0% and C4 value to 100%.)
			Time required for the differential (D) action to provide
	PID	0.04.4.40	the same measured value as that for the proportional
94	differential	0.01 to 10s	(P) action. As the differential time increases, greater
	time		response is made to a deviation change.
			No differential control.

(6) Adjustment procedure



(7) Calibration example

(A detector of 4mA at 0°C and 20mA at 50°C is used to adjust the room temperature to 25°C under PID control. The set point is given to across inverter terminals 2-5 (0-5V).)



*When calibration → Use Pr. 38 and calibration parameters C2 to C4 (terminal 2) is required and Pr. 39 and calibration parameters C5 to C7 (terminal 4) to calibrate the detector output and set point setting input.

Make calibration in the PU mode when the inverter is at a stop.

<Set point input calibration>


- 1. Apply the input voltage of 0% set point setting (e.g. 0V) across terminals 2-5.
- 2. Make calibration using the calibration parameters C2, C3. At this time, enter in C2 the frequency which should be output by the inverter at the deviation of 0% (e.g. 0Hz). (When using the FR-PU04, make calibration with Pr. 902.)
- 3. Apply the voltage of 100% set point (e.g. 5V) to across terminals 2-5.
- 4. Make calibration using Pr. 38 and calibration parameter C4. At this time, enter in Pr. 38 the frequency which should be output by the inverter at the deviation of 100% (e.g. 60Hz). (When using the FR-PU04, make calibration with Pr. 903.)

<Detector output calibration>

- 1. Apply the output current of 0% detector setting (e.g. 4mA) across terminals 4-5.
- Make calibration using the calibration parameter C6. (When using the FR-PU04, make calibration with Pr. 904.)
- 3. Apply the output current of 100% detector setting (e.g. 20mA) across terminals 4-5.
- Make calibration using the calibration parameter C7. (When using the FR-PU04, make calibration with Pr. 905.)


Note: The frequencies set in the calibration parameter C5 and Pr. 39 should be equal to those set in the calibration parameter C2 and Pr. 38, respectively.

The results of the above calibration are as shown below:



REMARKS

- •If the multi-speed (RH, RM, RL signal) or jog operation (JOG signal) is entered, PID control is stopped and multi-speed or jog operation is started.
- •Changing the terminal functions using Pr. 60 to Pr. 65 may affect the other functions. Confirm the functions of the corresponding terminals before making settings.
- •When PID control is selected, the minimum frequency is the frequency set in the calibration parameter C2 and the maximum frequency is the frequency set in Pr. 38.
- (The Pr. 1 "maximum frequency" and Pr. 2 "minimum frequency" settings are also valid.)
- •When the control is switched to PID control during normal operation, the frequency command value calculated by PID operation using 0Hz as standard is used without the frequency during the operation.



Operation when control is switched to PID control during normal operation

◆Related parameters ◆

- X14 signal assignment ⇒ Pr. 60 to Pr. 63 (input terminal function selection) (refer to page 108)
- FUP, FDN and RL signal assignment ⇒ Pr. 64 "RUN terminal function selection", Pr. 65 "A, B, C terminal function selection" (refer to page 110)
- Voltage input selection (0 to ±5V, 0 to ±10V) ⇒ Pr. 73 "0-5V/0-10V selection" (refer to page 114)
- Operation mode selection ⇒ Pr. 79 "operation mode selection" (refer to page 119)
- Making terminal calibration ⇒ Pr. 38, Pr. 39, C2 to C7 (calibration parameters) (refer to page 91)

2.11 Auxiliary function

2.11.1 Slip compensation (Pr. 95 235, Pr. 96 236, Pr. 97 234)

The inverter output current may be used to assume motor slip to keep the motor speed constant.

Parameter	Name	Factory Setting	Setting Range	Remarks
95	Rated motor slip		0 to 50%,	
96	Slip compensation time constant	0.5s		Setting is enabled when Pr. 30 = "1"
97	Constant power range slip compensation selection		0,	Wilei 1 1. 30 – 1

<Setting>

Rated slip = Synchronous speed at base frequency - rated speed ×100[%]

Parameter	Setting	Function			
95 0.01 to 50% Used to set the ra		Used to set the rated motor slip.			
93	0,	Slip compensation is not made.			
96	0.01 to 10s	Used to set the slip compensation response time. (*)			
97	0	Slip compensation is not made in the constant power range (frequency range above the frequency set in Pr. 3).			
		Slip compensation is made in the constant power range.			

^{*}When this value is made smaller, response will be faster.

However, as load inertia is greater, a regenerative overvoltage (OVT) error is more liable to occur.

REMARKS

When making $\overline{\text{slip}}$ compensation at 60Hz, set the maximum frequency (Pr. 1) to slightly higher than 60Hz.

In the factory setting status, it is clamped at 60Hz.

2.11.2 Automatic torque boost selection (Pr. 98 EEE)

You can choose automatic torque boost control.

Automatic torque boost control

Not only gives the motor the optimum excitation but also provides high torque even in a low speed range.

Parameter	Name	Factory Setting	Setting Range	Remarks
98	Automatic torque boost		0.1 to 3.7kW,	Setting is enabled when
90	selection (motor capacity)			Pr. 30 = "1"

<Operating conditions>

- •The number of motor poles should be any of 2, 4 and 6 poles.
- •Single-motor operation (One motor for one inverter)
- •The wiring length from inverter to motor should be within 30m.

<Setting>

Parameter	Setting	Description
		Ordinary V/F control and torque boost (Pr. 0, Pr. 46) are valid.
98	0.1 to 3.7kW	Automatic torque boost control valid
		(Set the applied motor capacity or one rank lower motor capacity.)

- Also when the Pr. 98 setting is other than "- -", Pr. 3 "base frequency" and Pr. 19 "base frequency voltage" are valid.
- When "- -" or "888" is set in Pr. 19, the rated output voltage is selected.

CAUTION

During operation using automatic torque boost, write to Pr. 3 and Pr. 19 is disabled even if "2" is set in Pr. 77.

◆Related parameters ◆ -

- Torque boost ⇒ Pr. 0 "torque boost", Pr. 46 "second torque boost" (refer to page 71)
- Base frequency ⇒ Pr. 3 "base frequency", Pr. 19 "base frequency voltage" (refer to page 73)
- Applied motor setting ⇒ Pr. 71 "applied motor" (refer to page 78)
- Motor primary resistance ⇒ Pr. 99 "motor primary resistance" (refer to page 133)

2.11.3 Motor primary resistance (Pr. 99 PR)

Generally this parameter need not be set. At the factory setting of "- - -", the standard motor constant of the motor capacity set in Pr. 98 (including that of the constant-torque motor) is used.

Parameter	Name	Factory Setting	Setting Range	Remarks
1 99	Motor primary resistance		0 to 50Ω,	Setting is enabled when Pr. 30 = "1"

- ◆Related parameters ◆ -

- Applied motor setting ⇒ Pr. 71 "applied motor" (refer to page 78)
- Automatic torque boost selection ⇒ Pr. 98 "automatic torque boost selection (motor capacity)" (refer to page 132)

2.12 Maintenance function


2.12.1 Maintenance output function (H1 Hall, H2 H2)

The maintenance timer alarm signal (Y95) is output when the cumulative energization time (H1 "maintenance timer") of the inverter reaches the time set in H2 "maintenance alarm output set time". (Used to alert the operator of the main circuit smoothing capacitor life expiration, for example.)

Parameter	Name	Factory Setting	Setting Range	Remarks	
H1 (503)	Maintenance timer	0	0 to 999	Write disabled	Setting is
H2 (504)	Maintenance alarm output set time	36 (36000h)	0 to 999,	: Function as 36000h	enabled when Pr. 30 = "1"

The parameter numbers in parentheses are those for use with the parameter unit (FR-PU04).

<Setting>



- 1) H1 (Pr. 503) "maintenance timer"
 - •The cumulative energization time of the inverter is stored into the EEPROM every hour and indicated in 1000h increments. (Cannot be written.)
 - •The maintenance timer is clamped at 999 (999000h).
- 2) H2 (Pr. 504) "maintenance alarm output set time"
 - •Set the time when the maintenance timer alarm signal (Y95) is output.
 - •The setting unit is 1000h.

REMARKS

The factory setting (36000h) is the guideline for the main circuit smoothing capacitor life (about 10 years in the operating environment of 40°C ambient temperature, 10h/day, and 365 days/year) of the inverter. The lifetime changes depending on the operating environment of the inverter.

- 3) Maintenance timer alarm signal (Y95)
 - •Made valid by setting "95" (maintenance timer alarm output signal) in Pr. 64 or Pr. 65 (output terminal function selection).
 - •If the value set in H2 is equal to or greater than the H1 setting, the maintenance timer alarm output (Y95) turns off.

◆Related parameters ◆

Assignment of Y95 signal to terminal ⇒ Pr. 64 "RUN terminal function selection", Pr. 65 "A, B, C terminal function selection" (Refer to page 110)


2.12.2 Current average value monitor signal

(H3 H = 1, H4 H = 4, H5 H = 5)

The average value of the output current during constant speed operation and the maintenance timer value (maintenance parameter H1) are output as pulses to the current average value monitor signal (Y93).

The pulse width measured by inputting the signal to the I/O module of the PLC or the like can be used as a guideline for increase in output current due to abrasion of peripheral machines and elongation of belt and for aged deterioration of peripheral devices to know the maintenance time.

The current average value monitor signal (Y93) is output as pulse for 20s as 1 cycle and repeatedly output during constant speed operation.




Parameter	Name	Factory Setting	Setting Range	Remarks
H3 (555)	Current average time	1s	0.1 to 1s	Setting is
H4 (556)	Data output mask time	0s	0 to 20s	enabled when
	Current average value monitor signal output reference current	1A	0.1 to 999A	Pr. 30 = "1"

The parameter number in parentheses is the one for use with the parameter unit (FR-PU04).

<Pulse operation>

The output pulse of the Y93 signal is shown below.



<Settina>

output time

Perform setting according to the following steps.

Parameter H5 (A)

- Setting of additional parameter H4 "data output mask time"
 The output current is unstable (transient state) right after the operation is changed from the acceleration/deceleration state to the constant speed operation. Set the time for not obtaining (mask) transient state data in H4.
- 2) Setting of additional parameter H3 "output current average time"


 The average output current is calculated during Hi output of start pulse (1s). Set the time taken to average the current during start pulse output in H3.
- 3) Setting of additional parameter H5 "output reference current"
 Set the reference (100%) for outputting the signal of the current average value.
 Obtain the time to output the signal from the following calculation.

Output current average value

Setting value of output × 5s (Output current average value 100%/5s) reference current (H5)

Note that the output time range is 0.5s to 9s, and it is 0.5s when the output current average value is less than 10% of the setting value of output reference current (H5) and 9s when exceeds 180%. Example) when H5=10A and the average value of output current is 15A


As 15A/10A×5s=7.5, the current average salue monitor signal is output as low pulse shape for 7.5s.



4) Output of maintenance timer value (additional parameter H1) After the output current average value is output as low pulse shape, the maintenance timer value is output as high pulse shape. The output time of the maintenance timer value is obtained from the following calculation.


 $\frac{\text{Maintenance timer value (H1×1000h)}}{40000h} \times 5s \text{ (Maintenance timer value 100\%/5s)}$

Note that the output time range is 2 to 9s, and it is 2s when the maintenance timer value (H1) is less than 16000h and 9s when exceeds 72000h.



REMARKS

- Mask of data output and sampling of output current are not performed during acceleration/ deceleration.
- •Set "93" in Pr. 64 and assign the current average value monitor signal (Y93) to the RUN terminal. It can not be assigned to the ABC contact (Pr. 65)
- •When the speed is changed to acceleration/deceleration from constant speed during start pulse output, the data is judged as invalid, the start pulse is output as high pulse shape for 3.5s, and the end pulse is output as low pulse shape for 16.5s.



The signal is output for at least 1 cycle even when acceleration/deceleration state continues after the start pulse output is completed.

- •When the output current value (inverter output current monitor) is 0A on completion of the 1 cycle signal output, the signal is not output until the speed becomes constant next time.
- •The current average value monitor signal (Y93) is output as low pulse shape for 20s (without data output) under the following condition.
- (1) when the motor is in the acceleration/deceleration state on completion of the 1 cycle signal output
- (2) when the 1 cycle output is completed during restart operation with automatic restart after instantaneous power failure (Pr. 57≠ "---")
- (3) when automatic restart operation was being performed with automatic restart after instantaneous power failure selected (Pr. 57≠ "---") on completion of the data output mask

◆Related parameters ◆

- Assignment of Y93 signal to terminal ⇒ Pr. 64 "RUN terminal function selection" (Refer to page 110.)
- Maintenance timer value ⇒ additional parameter H1 "maintenance timer (Refer to page 133.)
- · Automatic restart after instantaneous power failure operation \Rightarrow Pr. 57 "restart coasting time" (Refer to page 101.)
- H 7 → Refer to P 9 (page 78).

2.13 Brake parameters (FR-S520E-0.4K to 3.7K only)

2.13.1 Regenerative braking operation (b1 511, b2 512)

When making frequent starts/stops in the FR-S520E-0.4K to 3.7K inverter, use the optional brake resistor to increase the regenerative brake duty.

Para meter	Name	Factory Setting	Setting Range	Remarks
b1 (560)	Regenerative function selection	0	0	When using the brake resistor (MRS/MYS type), brake unit (BU type), high power factor converter (FR-HC), power regenerative common converter (FR-CV)
			1	When using the high-duty brake resistor (FR-ABR)
b2 (561)	Special regenerative brake duty	0%	0 to 30%	%ED of the built-in brake transistor operation

- The parameter numbers in parentheses are those for use with the parameter unit (FR-PU04).
- · Setting is enabled when Pr. 30="1".

<Setting>

- (1) When using the brake resistor (MRS/MYS type), brake unit (BU type), high power factor converter (FR-HC), power regenerative common converter (FR-CV) Set the brake parameter b1 to "0". In this case, the brake parameter b2 is disabled.
 - The regenerative braking duty when using the brake resistor is 3%.
- (2) When using the high-duty brake resistor (FR-ABR) Set the brake parameter b1 to "1". Set the brake parameter b2 to "10%".

REMARKS

- •Can be connected to the FR-S520E-0.4K to 3.7K only.
- •The brake unit (BU type), high power factor converter (FR-HC), power regenerative common converter (FR-CV) can not be connected to the FR-S520E-0.1K to 0.75K.

MARNING

The brake parameter b2 value must not exceed the setting of the brake resistor used.

Otherwise, the resistor can overheat.

2.14 Calibration parameters

2.14.1 Meter (frequency meter) calibration (C1

- By using the operation panel or parameter unit, you can calibrate an analog meter connected to terminal FM to full scale deflection.
- Terminal FM provides the pulse output. By setting the calibration parameter C1, you can use the parameter to calibrate the analog meter connected to the inverter without providing a calibration resistor.

Paramete	Name	Factory Setting	Setting Range	Remarks
C1 (900)	FM terminal calibration			Setting is enabled when Pr. 30 = "1"


The parameter number in parentheses is the one for use with the parameter unit (FR-PU04).

Changing example

Deflecting the meter (analog indicator) to full-scale (1mA) at the preset frequency of 60Hz (for frequency setting, refer to the instruction manual (basic).)

POINT

- •The calibration parameters "C1" can be made to be ready by setting "1" (extended function parameter valid) in Pr. 30 "extended function display selection".
- •Set the value of the calibration parameter C1 "FM terminal calibration".



- By turning the O, you can read another parameter.
 - Press the (SET) to return to the _____ indication (step 3).
- Press the (SET) twice to show the next parameter ([]...).

REMARKS

- •Depending on the set value, it may take some time for the needle to move.
- •If "1" is set in Pr. 30 "extended function display selection", the calibration parameter C1 "FM terminal calibration" can also be set in the external operation mode.
- •C1 is factory-set to 1mA full-scale or 1440 pulses/s FM output frequency at 60Hz. The maximum pulse train output of terminal FM is 2400 pulses/s.
- •When a frequency meter is connected to across terminals FM-SD to monitor the running frequency, the FM terminal output is filled to capacity at the factory setting if the maximum output frequency reaches or exceeds 100Hz. In this case, the Pr. 55 setting must be changed to the maximum frequency.
- •When the FR-PU04 is used, make calibration with Pr. 900.

POINT

By setting the Pr. 54 "FM terminal function selection" value, preset Pr. 55 "frequency monitoring reference" or Pr. 56 "current monitoring reference" to the running frequency or current value at which the output signal is 1440 pulses/s.

At 1440 pulses/s, the meter generally deflects to full-scale.

◆Related parameters ◆

Choosing signal to be output to FM terminal \Rightarrow Pr. 54 "FM terminal function selection" (refer to page 99)

Reference values of frequency and current values \Rightarrow Pr. 55 "frequency monitoring reference",
Pr. 56 "current monitoring reference"
(refer to page 101)

[[] to []] Refer to [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [[] [] [] [[] [] [[] [] [[] [] [[] [] [] [[] [[] [[] [[] [[] [[] [[] [[] [[] [[] [[] [[] [[] [[] [[] [[

2.15 Clear parameters

2.15.1 Parameter clear (CLr [1])

Initializes the parameter values to the factory settings. Clear the parameters during a stop in the PU operation mode.

Parameter	Name	Factory Setting	Setting Range	Remarks	
CLr	Parameter clear	0	0 1 10	C7 are not cleared)	Setting is enabled when Pr. 30 = "1"

^{*1.}Parameters are not cleared by setting "1" in Pr. 77 "parameter write disable selection".

Pr. 75, Pr. 38, Pr. 39, Pr. 53, Pr. 60 to Pr. 65, Pr. 99, additional parameters H1, H2, calibration parameters C1 to C7 and communication parameters n13, n15 are not cleared.

*2.Pr. 75, additional parameter H1 and communication parameter n13 are not cleared.

REMARKS

For details of the operation procedure, refer to the instruction manual (basic).

2.15.2 Alarm history clear (ECL [11])

Clear all alarm history.


Parameter	Name	Factory Setting	Setting Range	Rema	rks
ECL	Alarm history clear	0	() 1	0: Not cleared 1: Alarm history clear	Setting is enabled when Pr. 30 = "1"

2.16 Communication parameters

You can perform communication operation from the RS-485 connector of the inverter through RS-485.

(1) Operational functions

1) Operation mode switching [Operation mode switching method]



Symbol	Switching Type		Switching M	ethod		
A	PU operation to external operation	Using the (EXT) of the operation panel or the (EXT) of the parameter unit (FR-PU04)				
B	Inneration	Using the $\overbrace{\text{EXT}}^{\text{PU}}$ of the operation panel or the $\overbrace{\text{PU}}^{\text{PU}}$ of the parameter unit (FR-PU04)				
©	External operation to computer link operation	Using the computer program	Read (H7B)/			
D	Computer link operation to external operation	Using the computer program	` ,	H0001: External operation		
E	PU operation to computer link operation	Switching must not be made (External operation may be selected at (A) and then switched to computer link operation at (C)*)				
F	Computer link operation to PU operation	Switching must not (External operation switched to PU ope	may be selec	eted at ① and then		

^{*} When "1" is set in the communication parameter n10 "link startup mode selection", the inverter is placed in the computer link operation mode at power on or inverter reset. (Note that it is overridden by the Pr. 79 "operation mode selection" setting.)

REMARKS

Unlike the other inverters, the FR-S500 series is not the type of inverter whose operation panel is removed to make communication.

Parameter setting using setup S/W is not enabled in the PU operation mode and external / PU combined operation mode (Pr. 79 = 1, 3, 4). Also, pressing the RUN on the operation panel starts the inverter in the external / PU combined operation mode. (Pr. 79=1, 3)

2) Operation mode-based functions

Operation		Operation Mode				
Location	Item	PU operation	External operation	Computer link operation		
Operation panel or FR-PU04	Run command (start)	Enabled	Enabled (Combined operation mode)	Disabled		
	Running frequency setting	Enabled	Enabled (Combined operation mode)	Disabled		
	Monitoring	Enabled	Enabled	Enabled		
	Parameter write	Enabled (*4)	Disabled (*4)	Disabled (*4)		
	Parameter read	Enabled	Enabled	Enabled		
	Inverter reset	Enabled	Enabled	Enabled		
	Stop command	Enabled	Enabled (*3)	Enabled (*3)		
On-computer	Run command	Disabled	Disabled	Enabled (*1)		
user program by RS-485	Running frequency setting (*)	Disabled	Disabled	Enabled (*1)		
communication	Monitoring	Enabled	Enabled	Enabled		
	Parameter write	Disabled (*4)	Disabled (*4)	Enabled (*4)		
	Parameter read	Enabled	Enabled	Enabled		
	Inverter reset	Disabled	Disabled	Enabled (*2)		
	Stop command	Disabled	Disabled	Enabled		
Control circuit	Inverter reset	Enabled	Enabled	Enabled		
external terminal	Run command	Enabled (Combined operation mode)	Enabled	Enabled (*1)		
	Frequency setting	Enabled (Combined operation mode)	Enabled	Enabled (*1)		

^{*1.} As set in the communication parameters n8 "operation command source" and n9 "speed command source". (refer to page 160)

CAUTION =

When the user program of the computer is used to make the running frequency setting by RS-485 communication, setting can be made in the minimum setting increments of 0.01Hz, but the setting may be written to the inverter in increments of 0.1Hz. (0 is written in the second decimal place.)

POINT

To perform parameter write, give the run command, make inverter reset, etc. using RS-485 communication, the operation mode must be changed to the "computer link operation mode".

Set "0", "2", "7" or "8" in Pr. 79 "operation mode selection" to select the external operation mode, and change the operation mode to the "computer link operation mode" in either of the following methods.

- Set "1" in the communication parameter n10 "link startup mode selection" to start the inverter in the "computer link operation mode" at power on. (Refer to page 161 for the communication parameter n10.)
- Using operation mode write (instruction code HFB), write H0000 to choose the "computer link operation mode". (Refer to page 154 for operation mode write.)

^{*2.} At occurrence of RS-485 communication error, the inverter cannot be reset from the computer.

^{*3.} As set in Pr. 75 "reset selection/PU stop selection".

^{*4.} As set in Pr. 77 "parameter write disable selection".

2.16.1 Communication settings (n1 mm to n7 mm, n11 mm)

Communication-related parameters

Parameter	Name	Factory Setting	Setting Range	Remarks	Reflection Timing
n1(331)	Communication station number	0	0 to 31		After reset
n2(332)	Communication speed	192	48,96,192		After reset
n3(333)	Stop bit length	1	0,1,10,11	•	After reset
n4(334)	Parity check presence/ absence	2	0,1,2	•	After reset
n5(335)	Number of communication retries	1	0 to 10,	Setting is enabled	Immediately
n6(336)	Communication check time interval (*)		0, 0.1 to 999s,	when Pr. 30 = "1"	Immediately
n7(337)	Waiting time setting		0 to 150ms, 		After reset
n11(341)	CR/LF selection	1	0,1,2	•	After reset

- The parameter numbers within parentheses are those for use of the parameter unit (FR-PU04).
- Refer to page 206 for the instruction codes.

POINTS

*When making RS-485 communication, set any value other than 0 in the communication parameter n6 "communication check time interval". RS-485 communication is disabled if the setting is "0s".

Communication specifications

	Item		Computer		
Confor	ming star	ndard	EIA-485 (RS-485)		
Number of inverters connected			1:N (max. 32 inverters)		
Commi	unication	speed	Selected between 19200, 9600 and 4800bps		
Contro	l protocol		Asynchronous		
Commi	unication	method	Half-duplex		
u s	Characte	er system	ASCII (7 bits/8 bits) selectable		
atic	Stop bit	length	Selectable between 1 bit and 2 bits.		
ig ig	Terminat	or	CR/LF (presence/absence selectable)		
Pari		Parity check	Selectable between presence (even/odd) and absence		
Communication specifications	Check system	Sum check	Presence		
Waiting	time set	ting	Selectable between presence and absence		

REMARKS

- •For computer link operation, set 65535 (HFFFF) as the value "- -" and 65520 (HFFF0) as the Pr. 19 value "888".
- •Refer to page 47 for handling the RS-485 connector.
- •For parameter instruction codes, refer to the appended parameter instruction code list (page 206).

<Setting>

To make communication between the personal computer and inverter, initialization of the communication specifications must be made to the inverter. If initial setting is not made or there is a setting fault, data transfer cannot be made.


*After making the initial setting of the parameters, always reset the inverter. After you have changed the communication-related parameters, communication cannot be made until the inverter is reset.

Parameter	Name	Setti	ing	Description
n1	Communication station number	0 to 31		Station number specified for communication from the RS-485 connector. Set the inverter station numbers when two or more inverters are connected to one personal computer.
	0	48	3	4800bps
n2	Communication	96	3	9600bps
	speed	19	2	19200bps
		8 bits	0	Stop bit length 1 bit
n3	Stop bit length/	8 DIIS	1	Stop bit length 2 bits
113	data length	7 bits	10	Stop bit length 1 bit
		7 DILS	11	Stop bit length 2 bits
	Parity check	0		Absent
n4	presence/	1		Odd parity present
	absence	2		Even parity present
n5	Number of communication retries	0 to 10		Set the permissible number of retries at occurrence of a data receive error. If the number of consecutive errors exceeds the permissible value, the inverter will come to an alarm stop (OPT). If a communication error occurs, the inverter will not come to an alarm stop. At this time, the inverter can
		 (65535)		be coasted to a stop by MRS or RES input. During a communication error (H0 to H5), the minor fault signal (LF) is switched on. Allocate the used terminal with any of Pr. 64, Pr. 65 (output terminal function selection).
		0		No communication
n6	Communication check time interval			Set the communication check time [s] interval. If a no-communication state persists for longer than the permissible time, the inverter will come to an alarm stop (OPT).
				Communication check suspension.
n7	Waiting time setting	0 to 150		Set the waiting time between data transmission to the inverter and response.
	36ttilig		-	Set with communication data.
		0		Without CR/LF
n11	CR/LF selection	1		With CR, without LF
		2		With CR/LF

<Computer programming>

(1) Communication protocol

Data communication between the computer and inverter is performed using the following procedure:



REMARKS

- *1. If a data error is detected and a retry must be made, execute retry operation with the user program. The inverter comes to an alarm stop if the number of consecutive retries exceeds the parameter setting.
- *2. On receipt of a data error occurrence, the inverter returns "reply data 3)" to the computer again. The inverter comes to an alarm stop if the number of consecutive data errors reaches or exceeds the parameter setting.

(2) Communication operation presence/absence and data format types Communication operation presence/absence and data format types are as follows:

No.	Oper	ation	Run Command	Running Frequency	Parameter Write	Inverter Reset	Monitor- ing	Parame- ter Read
1)	Communication is sent to the accordance user prograr computer.	inverter in with the	A'	A (A")*1	A (A")*2	Α	В	В
2)	Inverter data time	processing	Present	Present	Present	Absent	Present	Present
3)	Reply data from the inverter.(Da	No error* (Request accepted)	С	С	C	Absent	E, E' (E")*1	E (E")*2
3)	ta 1) is `checked for error)	With error (request rejected)	D	D	D	Absent	F	F
4)	Computer pridelay time	ocessing	Absent	Absent	Absent	Absent	Absent	Absent
	Answer from computer in	No error* (No inverter processing)	Absent	Absent	Absent	Absent	G (Absent)	G (Absent)
5)	response to reply data 3). (Data 3) is checked for error)	With error. (Inverter outputs 3) again.)	Absent	Absent	Absent	Absent	н	H

^{*} In the communication request data from the computer to the inverter, 10ms or more is also required after "no data error (ACK)". (Refer to page 150.)

REMARKS


^{*1.} Setting any of "0.1" to "999" in Pr. 37 "speed display" and "1" in instruction code "HFF" sets the data format to A" or E" (6-digit data). Also, the output frequency turns to a speed display, which is valid in 0.01r/min increments. (The third decimal place is invalid.) If the instruction code "HFF" is other than "1", the display is in 1r/min increments and a 4-digit data format can be used. Reply data is given in format E if the requested monitor data has 4 digits, in format E' if the data has 2 digits, or in format E" if the data has 6 digits.

^{*2.} The data format to read/write Pr. 37 "speed display" is always E"/A" (6-digit data).


(3) Data format

Data communication between the computer and inverter is made in ASCII code (hexadecimal code).

- Data format type's
- 1) Communication request data from computer to inverter




2) Reply data from inverter to computer during data write




3) Reply data from inverter to computer during data read

[No data error detected] [Data error detected]



4) Send data from computer to inverter during data read



REMARKS

- 1. Indicates the control code. (Refer to the table below.)
- *2. Specify the inverter station numbers between H00 and H1F (stations 0 to 31) in hexadecimal.
- *3. When communication parameter n7 "waiting time setting" ≠ - -, create the communication request data without "waiting time" in the data format. (The number of characters is decremented by 1.)
- *4. CR or LF code

When data is transmitted from the computer to the inverter, codes CR (carriage return) and LF (line feed) codes are automatically set at the end of a data group on some computers. In this case, setting must also be made on the inverter according to the computer.

Also, the presence or absence of the CR and LF codes can be selected using n11.

(4) Data definitions

1) Control codes

Signal	ASCII Code	Description
STX	H02	Start of Text (Start of data)
ETX	H03	End of Text (End of data)
ENQ	H05	Enquiry (Communication request)
ACK	H06	Acknowledge (No data error detected)
LF	H0A	Line Feed
CR	H0D	Carriage Return
NAK	H15	Negative Acknowledge (Data error detected)

2) Inverter station number

Specify the station number of the inverter which communicates with the computer.

3) Instruction code


Specify the processing request, e.g. operation or monitoring, given by the computer to the inverter. Hence, the inverter can be run and monitored in various ways by specifying the instruction code as appropriate. (Refer to page 206.)

4) Data

Indicates the data such as frequency and parameters transferred to and from the inverter. The definitions and ranges of set data are determined in accordance with the instruction codes. (Refer to page 206.)

5) Waiting time


Specify the waiting time between the receipt of data at the inverter from the computer and the transmission of reply data. Set the waiting time in accordance with the response time of the computer between 0 and 150ms in 10ms increments (e.g. 1 = 10ms, 2 = 20ms).



REMARKS

When communication parameter n7 "waiting time setting" \neq "- - -", create the communication request data without "waiting time" in the data format. (The number of characters is decremented by 1.)

6) Response time



[Formula for data sending time]



Communication specification


Name	Number of Bits	
Stop bit le	1 bit 2 bits	
Data len	igth	7 bits 8 bits
Parity check	Yes	1 bit
ranty check	No	0 bit

In addition to the bits in the above table, 1 bit is required for the start bit. Minimum total number of bits ... 9 bits Maximum total number of bits ... 12 bits

7) Signal loss detection (Communication parameter n6 "communication check time interval")

- · If a signal loss (communication stop) is detected between the inverter and computer as a result of a signal loss detection, a communication error (OPT) occurs and the inverter output is shut off.
- A signal loss detection is made when the setting is any of "0.1s" to "999s". To
 make a signal loss detection, it is necessary to send data (control code refer to
 page 149) from the computer within the communication check time interval. (The
 send data has nothing to do with the station number)
- · Communication check is performed in computer link operation mode from at the first communication.
- · When the setting is "---", communication check (disconnection detection) is not made.
- · When the setting is "0", RS-485 communication is disabled.

Example: When communication parameter n6= "0.1 to 999"




CAUTION

When the setting is "----" = n6, communication check (signal loss detection) is not made. When signal is lost (communication is disconnected), motor can not be stopped from communication.

8) Sum check code

The sum check code is 2-digit ASCII (hexadecimal) representing the lower 1 byte (8 bits) of the sum (binary) derived from the checked ASCII data



9) Error code

If any error is found in the data received by the inverter, its definition is sent back to the computer together with the NAK code. (Refer to page 158.)

REMARKS

- 1. When the data from the computer has an error, the inverter will not accept that data.
- 2.All data communication, e.g. run command or monitoring, are started when the computer gives a communication request. The inverter does not return any data without the computer's request. For monitoring, therefore, design the program to cause the computer to provide a data read request as required.
- 3.When the parameter setting is read or written, the data of the link parameter expansion setting changes depending on the parameter. For the data, refer to the parameter instruction code list on page 206.

CAUTION

Always set the communication check time interval before starting operation to prevent hazardous conditions.

⚠ Data communication is not started automatically but is made only once when the computer provides a communication request. If communication is disabled during operation due to signal cable breakage etc., the inverter cannot be stopped. When the communication check time interval has elapsed, the inverter will come to an alarm stop (OPT).

The inverter can be coasted to a stop by switching on its RES signal or by

The inverter can be coasted to a stop by switching on its RES signal or by switching power off.

If communication is broken due to signal cable breakage, computer fault etc., the inverter does not detect such a fault. This should be fully noted.

<Setting items and set data>

After completion of parameter settings, set the instruction codes and data then start communication from the computer to allow various types of operation control and monitoring.

No.		Item		Instruction Code			Desc	ription		Number of Data Digits
1	Op mo	Operation		Н7В	H0001 H0002	l: Extern 2: PU op				4 digits
	Ш	ue	Write	нгв	H0001	l: Extern	unication ope al operation			
		Outpu freque [speed	ncy	H6F	increm Pr. 37 H0000 When (HFF)	nents = 0 (fac) to HFF Pr. 37 = = 0		1r/min inci expansior	rements i link parameter	· 4 digits
					When (HFF)	Pr. 37 = = 1	"0.1 to 999",	expansior	/min increments n link parameter	6 digits
		Outpu curren		П/О	incren	nents	•	,	adecimal) in 0.01A	4 digits
2	Monitoring	Alarm definit	ion		Alarm Alar Dat H00 H11 H12 H22 H30 H31 H41	Promodela definition b15 Promodela definition	n display exa	Most rece (HA) Data H60 H70 H80 H90 H80 HB0 HB1 HB2 HC0	ent alarm	4 digits

No.	ltem	Instruction Code	Description	Number of Data Digits
3	Run command	HFA	b7	2 digits
1 4	Inverter status monitor	Н7А	b7 b0 b0: Inverter running (RUN)* b1: Forward rotation b2: Reverse rotation b2: Reverse rotation b3: Up to frequency (SU) b4: Overload (OL) b5: b6: Frequency detection (FU) b7: Alarm occurrence* * Function change can be made using Pr. 64 and Pr. 65 (output terminal function selection).	2 digits

No.	Item	Instruction Code	Description	Number of Data Digits
	Set frequency read (RAM)	H6D	When Pr. 37 = "0" (factory setting) The set frequency (RAM or EEPROM) is read. H0000 to H2EE0: 0.01Hz increments When Pr. 37 = "0.1 to 999", expansion link parameter (HFF) = 0 The set speed is read. H0000 to H03E7: 1r/min increments	4 digits (6 digits)
	Set frequency read (EEPROM)	H6E	•When Pr. 37 = "0.1 to 999", expansion link parameter (HFF) = 1 The set speed is read. (The number of data digits is 6 digits.) H0000 to HF3E58: 0.001r/min increments	
5	Set frequency write (RAM only)	HED	When Pr. 37 = "0" (factory setting) H0000 to H2EE0 (0 to 120.00Hz): Set frequency in 0.01Hz increments When changing the set frequency continuously, write it to the inverter RAM (instruction code: HED). The minimum setting increments are 0.01Hz but setting can be made in only 0.1Hz increments. When Pr. 37 = "0.1 to 999", expansion link parameter HFF = 0 H0000 to H03E7 (0 to 999): Set speed in 1r/min increments	4 digits (6 digits)
	Set frequency write (RAM and EEPROM)	HEE	•When Pr. 37 = "0.1 to 999", expansion link parameter HFF = 1 H0000 to HF3E58 (0 to 999.000): Set speed in 0.001r/min increments Set the number of data digits as 6 digits. The minimum setting increments are 0.001r/min but setting can be made in only 0.01r/min increments.	
	Inverter reset	HFD	H9696: Resets the inverter. As the inverter is reset on start of communication by the computer, the inverter cannot send reply data back to the computer.	4 digits
	Alarm definition batch clear	HF4	H9696: Alarm history batch clear	4 digits

No.	Item	ı	Instruction Code								Number of Data Digits				
								Α	ny of fou	eters returr or different to the data	all clear o _l			med	
						Pr.	Commu- nication Pr.		Other Pr.*	HEC HFF					
	All param	eter			H9696	0	×	0	0						
8	clear	Cici	HFC		H9966	0	0	0	0		4 digits				
	o.ou.				H5A5A	×	×	0	0						
					H55AA	×	0	0	0						
				H re se *	When all parameter clear is executed for H9696 or H9966, communication-related parameter settings also return to the factory settings. When resuming operation, set the parameters again. * Pr. 75 is not cleared.										
u	Paramete read	1100 10 1100 10 100 100 100 100 100 10				d write	4 diaita								
10	Paramete write	r	H80 to HE3		When setting Pr. 100 and later, set link parameter expansion setting.						4 digits				
11	Link parameter	Read	H7F		Set any of H00 to H09 to change the parameter settings. For details of the settings, refer to the parameter						2 digits				
	expansion setting	Write	HFF			code list (-		irameter		2 digits				
10	parameter changing (Code	Read	H6C	H H H	DE to HI 00: Freq 01: Anal	ting the biase E1) parame uency (*1) og og value of	eters `		ode H5E to	o H61 ,	O digita				
12		Write	HEC	*1	I. The ga 38 and 2. When	ain frequen d Pr. 39 (in: a voltage i bias or gai	icies may struction c s given to	also be wi codes A6 a the extern	and A7). nal termina	al to	2 digits				

REMARKS

For the instruction codes HFF, HEC, their set values are held once they are written, but changed to 0 when the inverter is reset or all clear is performed.

<Error Code List>

The corresponding error code in the following list is displayed if an error is detected in any communication request data from the computer:

Error Code	Item	Definition	Inverter Operation			
Н0	Computer NAK error					
H1	Parity error	The parity check result does not match the specified parity	Brought to an			
H2	Sum check error	The sum check code in the computer does not match that of the data received by the inverter.	alarm stop (OPT) if error occurs			
НЗ	Protocol error	Data received by the inverter is in wrong protocol, data receive is not completed within given time, or CR and LF are not as set in the parameter.	continuously more than the allowable number			
H4	Framing error	The stop bit length is not as specified by initialization.	of retries.			
H5	Overrun error	New data has been sent by the computer before the inverter completes receiving the preceding data.				
H6						
H7	Character error	The character received is invalid (other than 0 to 9, A to F, control code).	Does not accept received data but is not brought to alarm stop			
H8		- 				
H9						
HA	Mode error	Parameter write was attempted in other than the computer link operation mode or during inverter operation.	Does not accept			
НВ	Instruction code error	The specified command does not exist.	received data but is not brought to			
НС	Data range error	Invalid data has been specified for parameter write, frequency setting, etc.	alarm stop.			
HD						
HE						
HF						

(5) Operation at alarm occurrence

			Operation Mode			
Fault Location	Statu	ıs	Communication Operation (RS-485 connector)	External Operation		
	Inverter operati		Stop	Stop		
Inverter fault	Communication RS-485 connector		Continued	Continued		
	Inverter operati	on	Stop/continued (*3)	Continued		
(Communication from RS-485 connector)	Communication	RS-485 connector	Stop	Stop		

^{*3:} Can be selected using the corresponding parameter (factory-set to stop).

(6) Communication error

Fault Location	Error Message (Operation panel)	Remarks
Communication error (Communication from RS-485 connector)	OPT	Error code is OPT

(7) Program example

To change the operation mode to computer link operation

Program

Line number 10 OPEN"COM1:9600,E,8,2,HD"AS #1 20 COMST1,1,1:COMST1,2,1 30 ON COM(1)GOSUB*REC 40 COM(1)ON

50 D\$="01FB10000"

60 S=0

70 FOR I=1 TO LEN(D\$)

80 A\$=MID\$(D\$,I,1)

90 A=ASC(A\$) 100 S=S+A

100 S=S+A 110 NEXT I

120 D\$=CHR\$(&H5)+D\$+RIGHT\$(HEX\$(S),2)

130 PRINT#1,D\$

140 GOTO 50

1000 *REC


1010 IF LOC(1)=0 THEN RETURN

1020 PRINT"RECEIVE DATA"

1030 PRINT INPUT\$(LOC(1),#1)

1040 RETURN

General flowchart



Initial setting of I/O file

- ★ Opening the communication file
- ★ ON/OFF setting of circuit control signals (RS, ER)
- ★ Interrupt definition for data receive
- ★ Interrupt enable

Send data setting

Sum code calculation

* Addition of control and sum codes

Data send

Interrupt data receive

★ Interrupt occurrence during data receive

Receive data processing
O Data import

O Screen display

2.16.2 Operation and speed command source (n8 🔠, n9 🔠)

Used to make valid the run and speed commands from the computer or external terminals.

Parameter	Name	Factory Setting	Setting Range	Remarks
	Operation command source	0	0, 1	Setting is enabled when Pr. 30 = "1"
n9 (339)	Speed command source	0	0, 1	Setting is chabled when F1. 30 - 1

The parameter numbers within parentheses are those for use of the parameter unit (FR-PU04).

<Setting>

In the computer operation mode, commands from the external terminals and computer are as listed below.

(Refer to page 108 for Pr. 60 to Pr. 63 (input terminal function selection).)

(T COLC	, 10		(Pr. 338) "operation	0: (mpar t	0:	1:	1:	
Opera		command source" (•	Computer		External	Remarks
selec				0:	1:	0:	1:	Kemarks
36160	Juon			Computer	External	Computer	External	
Fixed		(ST	,	Computer	Computer	External	External	
functi (Term equiv	ninal-		nputer link operation uency	Computer		Computer		
functi			2		External	_	External	
	,		4		External	_	External	
		0	Low-speed run command (RL)	Computer	External	Computer	External	Pr. 59 = "0"
		1	Middle-speed run command (RM)	Computer	External	Computer	External	Pr. 59 = "0"
		2	High-speed run command (RH)	Computer	External	Computer	External	Pr. 59 = "0"
		3	Second function selection (RT)	Computer	Computer	External	External	
	sbu	4	Current input selection (AU)	_	Combined	_	Combined	
nctior	settings	5	Start self-holding selection (STOP)	_	_	External	External	
₽	63	6	Output stop (MRS)	Combined	Combined	External	External	Pr. 79 ≠ "7"
Selection function	to Pr.	7	External thermal relay input (OH)	External	External	External	External	
Sele	Pr. 60	8	15-speed selection (REX)	Computer	External	Computer	External	Pr. 59 = "0"
	Д	9	Jog operation selection (JOG)		_	External	External	
		10	Reset (RES)	External	External	External	External	
		14	PID control valid terminal (X14)	Computer	External	Computer	External	
		16	PU-external operation switch-over (X16)	External	External	External	External	
			Reverse rotation command (STR)	Computer	Computer	External	External	

Operation location	n8 (Pr. 338) "operation command source"	0: Computer	0: Computer	1: External	1: External	Remarks
selection	n9 (Pr. 339) "speed command source"	0: Computer	1: External	0: Computer	1: External	rtemarks
	Remote setting (RH, RM, RL)	Computer	External	Computer	External	
RL, REX selection function	15-speed selection (REX)	_	_	_	_	Pr. 59 = "1", "2"
MRS selection function	PU operation interlock (MRS)	External	External	External	External	Pr. 79 = "7"

[Explanation of table]

External : Operation is valid only from external terminal signal.

Computer : Operation is valid only from computer.

Combined : Operation is valid from either of external terminal and computer.

: Operation is invalid from either of external terminal and computer.

_ CAUTION _

When Pr. 79 "operation mode selection" is set to "7" (PU operation interlock function), only the external terminal is made valid independently of the n8 and n9 settings because the MRS terminal is shared.

2.16.3 Link startup mode selection (n10 📶)

The operation mode at power on and at power restoration after instantaneous power failure can be selected.

Set "1" in n10 to select the computer link operation mode.

After a link start, parameter write is enabled with a program.

Parameter	Name	Factory Setting	Setting Range	Remarks
	Link startup mode selection	0	0, 1	Setting is enabled when Pr. 30 = "1"

The parameter numbers in parentheses are those for use with the parameter unit (FR-PU04).

<Setting>

n10 Setting	Pr. 79 Setting	Operation Mode at Power on or Power Restoration	Remarks		
	0	External operation mode	Can be changed to the computer link operation mode by RS-485 communication.		
	1	PU operation mode	Operation mode cannot be changed.		
	2	External operation mode	Can be changed to the computer link operation mode by RS-485 communication.		
	3	External/PU combined mode	Operation mode cannot be changed.		
0	4	External/PU combined mode			
(Factory setting)	7	External operation mode (PU operation interlock)	MRS signal ONCan be changed to PU operation by RS-485 communication. MRS signal OFFOperation mode cannot be changed.		
	8	•X16 signal ON Started in the external operation mode.	Can be changed to the computer link operation mode by RS-485 communication.		
	0	•X16 signal OFF Started in the PU operation mode.	Operation mode cannot be changed.		
	0	Computer link operation mode	Can be changed to the external operation mode by RS-485 communication.		
	1	PU operation mode	Operation mode cannot be changed.		
	2	Computer link operation mode	Can be changed to the external operation mode by RS-485 communication.		
	3	External/PU combined mode	Operation mode cannot be changed.		
	4	External/PU combined mode	operation most carmet so shanges.		
1	7	PU operation interlock MRS signal ON Started in the computer link operation mode.	Can be changed to external operation by RS-485 communication.		
		MRS signal OFF Started in the external operation mode.	Operation mode cannot be changed.		
	8	•X16 signal ON Started in the computer link operation mode.	Can be changed to external operation by RS-485 communication.		
	Ĭ	•X16 signal OFF Started in the PU operation mode.	Operation mode cannot be changed.		

- n10 can be changed from the operation panel independently of the operation mode.
- Setting of n10 = "1" is made valid when "0" or "2" is set in Pr. 79 "operation mode selection".

2.16.4 EEPROM write selection (n12 12)

You can choose whether the parameters are stored into the EEPROM or not at the parameter setting for computer communication. When performing parameter write frequently, write them to the RAM.

Parameter	Name	Factory Setting	Setting Range	Remarks
n12 (342)	EEPROM write selection	0		0: Written to RAM and EEPROM 1: Written to RAM only Not written to EEPROM* Setting is enabled when Pr. 30 = "1"

The parameter numbers in parentheses are those for use with the parameter unit (FR-PU04).

REMARKS

*When the parameter setting is "not written to EEPROM" (setting=1), the settings return to the original values (values saved in the EEPROM) at power-on reset or terminal reset.

2.17 Parameter unit (FR-PU04) setting

When the optional parameter unit (FR-PU04) is connected to the RS-485 connector of the inverter, you can make the environment setting of the parameter unit.

CAUTION

When the parameter unit (FR-PU04) is used, operation from the operation panel is not accepted. (The stop key $(\frac{\text{STOP}}{\text{DPSSFT}})$ is valid)

2.17.1 PU display language selection (n13 113)

By setting the communication parameter n13 "PU display language selection", you can switch the display language of the parameter unit to another.

Parameter	Name	Factory Setting	Setting Range	Remarks
n13 (145)	PU display language selection	0	0 to 7	Setting is enabled when Pr. 30 = "1"

The parameter numbers in parentheses are those for use with the parameter unit (FR-PU04).

<Setting>

n13 Setting	Display Language
0	Japanese (factory setting)
1	English
2	German
3	French
4	Spanish
5	Italian
6	Swedish
7	Finnish

2.17.2 PU buzzer control (n14 **518**)

By setting the communication parameter n14 "PU buzzer control", you can control "beep" produced when any of the parameter unit (FR-PU04) keys is operated.

Parameter	Name	Factory Setting	Setting Range	Remarks
n14 (990)	PU buzzer control	1	0, 1	0: Without sound 1: With sound (factory setting) Setting is enabled when Pr. 30 = "1"

The parameter numbers in parentheses are those for use with the parameter unit (FR-PU04).

2.17.3 PU contrast adjustment (n15 📶)

By setting the communication parameter n15 "PU contrast adjustment", you can adjust the LCD contrast of the parameter unit (FR-PU04). When using the FR-PU04, adjust the numerical value to any darkness with the A/ and define that brightness with the WRITE of the parameter unit.

Parameter	Namo	Factory Setting	_	Remarks
n15 (991)	PU contrast adjustment	58	0 to 63	Setting is enabled when Pr. 30 = "1"

The parameter numbers in parentheses are those for use with the parameter unit (FR-PU04).

2.17.4 PU main display screen data selection (n16 📶)

You can choose the main display screen of the parameter unit (FR-PU04).

Parameter	Name	Factory Setting	Setting Range	Remarks
n16 (992)	PU main display screen data selection	0	0, 100	Setting is enabled when Pr. 30 = "1"

The parameter numbers in parentheses are those for use with the parameter unit (FR-PU04).

<Setting>

When "100" is set in n16, the monitor value is different depending on whether the inverter is at a stop or running.

	n16			
	0	100		
	During operation/stop	During stop	During operation	
Output frequency	Output frequency	Set frequency	Output frequency	
Output current		Output current		
Alarm display	Alarm display			

REMARKS

- •During an error, the output frequency at error occurrence appears.
- •During MRS signal is on, the values displayed are the same as during a stop.

◆Related parameters ◆

•Speed display ⇒ Pr. 37 "speed display" (refer to page 90)

2.17.5 Disconnected PU detection/PU setting lock selection (n17 📶)

You can choose the connector disconnection detection function of the parameter unit (FR-PU04) and the control source of the PU (operation panel, FR-PU04).

Disconnected PU detection :

This function detects that the parameter unit (FR-PU04) has been disconnected from the inverter for longer than 1s and causes the inverter to provide an alarm output (PUE) and come to an alarm stop. When the PU has been disconnected since before power-on, it is not judged as an alarm.

PU setting lock :

Control source of operation command, frequency command and parameter setting is restricted to the operation panel or parameter unit (FR-PU04).

Parameter	Name	Factory Setting	Setting Range	Remarks
n17 (993)	Disconnected PU detection/ PU setting lock	0	0, 1, 10	Setting is enabled when Pr. 30 = "1"

The parameter numbers in parentheses are those for use with the parameter unit (FR-PU04).

<Setting>

n17 Setting	Disconnected PU Detection	PU Setting Lock*
0	Operation is continued as-is if the PU is disconnected (without disconnected PU detection)	Parameter unit (FR-
1	Inverter output is shut off when the PU is disconnected (with disconnected PU detection)	PU04) is valid
10	Operation is continued as-is if the PU is disconnected (without disconnected PU detection)	Operation panel is valid

^{*} The monitor display and the $\frac{\text{STOP}}{\text{RESET}}$ are valid.

CAUTION

The motor decelerates to a stop when the PU is disconnected during PU jog operation with n17 set to any of "0, 10" (operation is continued if the PU is disconnected).

REMARKS

When RS-485 communication operation is performed through the RS-485 connector, the reset selection/PU stop selection function is valid but the disconnected PU detection function is invalid.

♠ CAUTION

riangle Do not reset the inverter while the start signal is being input. Doing so will cause the inverter to start immediately after a reset, leading to hazardous conditions.

MEMO

3. PROTECTIVE FUNCTIONS

This chapter explains the "protective functions" of this product.

Always read the instructions before using the equipment.

3.1	Errors (Alarms)	170
3.2	Troubleshooting	181
3.3	Precautions for maintenance and inspection	184

Chapter 1

Chapter 2

Chapter 3

Chapter 4

3.1 Errors (Alarms)

When an alarm occurs in the inverter, the protective function is activated bringing the inverter to an alarm stop and the PU display automatically changes to any of the following error (alarm) indications.

If your fault does not correspond to any of the following errors or if you have any other problem, please contact your sales representative.

■ Retention of alarm output signal V	When the magnetic contactor (MC) provided on
tl	he power supply side of the inverter is opened
а	at the activation of the protective function, the
ir	nverter's control power will be lost and the
a	alarm output will not be held.

◆ Alarm indication	When the protective function is activated, the
	operation panel display automatically switches
	to the above indication.

	to the above indication.
Resetting method	When the protective function is activated, the
	inverter output is kept stopped. Unless reset,
	therefore, the inverter cannot restart. Switch
	power off once, then on again; or apply RES
	signal for more than 0.1s. If the RES signal is
	kept on, "Err." appears (flickers) to indicate that
	the inverter is in a reset status.

■ When the protective function is activated, take the appropriate corrective action, then reset the inverter, and resume operation.

3.1.1 Error (alarm) definitions

(1) Major failures

When the protective function is activated, the inverter output is shut off and the alarm is output.

Operation Panel Indication	OC1	OC.	1	FR-PU04	OC During Acc
Name	Overcurrent sh	nut-off duri	ng a	cceleration	
Description	When the inverter output current reaches or exceeds approximately 200% of the rated inverter current during acceleration, the protective circuit is activated to stop the inverter output.				
Check point	Check for sudden acceleration. Check that the downward acceleration time is not long in vertical lift application. Check for output short-circuit/earth (ground) fault.				
Corrective action	Increase the acceleration time. Shorten the downward acceleration time in vertical lift application.				vertical lift application.

Operation Panel Indication	OC2	002	FR-PU04	Stedy Spd OC	
Name	Overcurrent sh	nut-off during c	onstant speed		
Description	When the inverter output current reaches or exceeds approximately 200% of the rated inverter current during constant-speed operation, the protective circuit is activated to stop the inverter output.				
Check point	Check for sudden load change. Check for output short-circuit/earth (ground) fault.				
Corrective action	Keep load stat	ole.			

Operation Panel Indication	ОСЗ	003	FR-PU04	OC During Dec		
Name	Overcurrent sh	Overcurrent shut-off during deceleration				
Description	When the inverter output current reaches or exceeds approximately 200% of the rated inverter current during deceleration (other than acceleration or constant speed), the protective circuit is activated to stop the inverter output.					
Check point	Check for sudden speed reduction. Check for output short-circuit/earth (ground) fault. Check for too fast operation of the motor's mechanical brake.					
Corrective action	Increase the deceleration time. Adjust brake operation.					

Operation Panel Indication	OV1	Ü.	1	FR-PU04	OV During Acc
Name	Regenerative	overvoltag	je sh	ut-off during ac	celeration
Description	When the main circuit DC voltage in the inverter rises to or above the specified value due to excessive regenerative energy during acceleration, the protective circuit is activated to stop the inverter output. The circuit may also be activated by a surge voltage produced in the power supply system.				
Check point	Check for too slow acceleration. (e.g. during downward acceleration in vertical lift load)				
Corrective action	Decrease the acceleration time. Install a power factor improving reactor.				

Operation Panel Indication	OV2	000	FR-PU04	Stedy Spd OV	
Name	_	Regenerative overvoltage shut-off during constant speed			
Description	When the main circuit DC voltage in the inverter rises to or above the specified value due to excessive regenerative energy during constant speed, the protective circuit is activated to stop the inverter output. The circuit may also be activated by a surge voltage produced in the power supply system.				
Check point	Check for sudden load change.				
Corrective action	Keep load stable. Install a power factor improving reactor.				

Operation Panel Indication	OV3	003	FR-PU04	OV During Dec
Name	Regenerative	overvoltage sh	ut-off during de	celeration or stop
Description	When the main circuit DC voltage in the inverter rises to or above the specified value due to excessive regenerative energy during deceleration or stop, the protective circuit is activated to stop the inverter output. The circuit may also be activated by a surge voltage produced in the power supply system.			
Check point	Check for sudden speed reduction.			
Corrective action	 Increase the deceleration time. (Set the deceleration time which matches the moment of inertia of the load) Decrease the braking duty. Install a power factor improving reactor. 			

Operation Panel Indication	ТНМ	[HI]	FR-PU04	Motor Ovrload	
Name	Motor overload	d shut-off (elec	tronic thermal r	elay function) (* 1)	
Description	The electronic thermal relay function in the inverter detects motor overheat due to overload or reduced cooling capability during low-speed operation to stop the inverter output. When a multi-pole motor or two or more motors are run, provide a thermal relay on the output side of the inverter. Protection from burning due to motor temperature rise.				
Check point	Check the motor for use under overload.				
Corrective action	Reduce the IFor a consta 71 "applied r	nt-torque moto	r, set the const	ant-torque motor in Pr.	

Operation Panel Indication	тнт	: H:	FR-PU04	Inv. Overload
Name	Inverter overlo	ad shut-off (ele	ectronic therma	I relay function) (* 1)
Description	If a current of more than 150% of the rated output current flows and overcurrent shut-off does not occur (150% or less), inverse-time characteristics cause the electronic thermal relay function to be activated to stop the inverter output in order to protect the output transistors. Output transistor protection from overheat			
Check point	Check the motor for use under overload.			
Corrective action	Reduce the loa	ad weight.		

^{*1.} Resetting the inverter initializes the internal thermal integratied data of the electronic thermal relay function.

Operation Panel Indication	FIN	Flo	FR-PU04	H/Sink O/Temp
Name	Fin overheat			
Description	If the heatsink overheats, the temperature sensor is actuated to stop the inverter output.			
Check point	Check for too high ambient temperature. Check for heatsink clogging.			
Corrective action	Set the ambier	nt temperature	to within the sp	pecifications.

Operation Panel Indication	BE	<i>68</i>	FR-PU04	Br. Cct. Fault	
Name	Brake transistor alarm detection (Available for the FR-S520E-0.4K to 3.7K only.)				
Description	This function stops the inverter output if an alarm occurs in the brake circuit, e.g. damaged brake transistors. In this case, the inverter must be powered off immediately.				
Check point	 Reduce the load inertia. Check that the frequency of using the brake is proper. Check that the brake resistor selected is correct. 				
Corrective action	Replace the inverter.				

Operation Panel Indication	GF	5F	FR-PU04	Ground Fault
Name	Start-time output side earth (ground) fault overcurrent			
	This function stops the inverter output if an earth (ground) fault overcurrent flows due to an earth (ground) fault which occurred on the inverter's output (load) side. Made valid when Pr. 40 "start-time earth (ground) fault detection selection" = "1".			
Check point	Check for an earth (ground) fault in the motor and connection cable.			
Corrective action	Remedy the earth (ground) fault portion.			

Operation Panel Indication	ОНТ	0HF	FR-PU04	OH Fault	
Name	External therm	nal relay (*2)			
Description	If the external thermal relay provided for motor overheat protection or the internally mounted temperature relay in the motor switches on (contacts open), the inverter output is stopped. Even if the relay contacts are reset automatically, the inverter will not restart unless it is reset.				
Check point	 Check for motor overheating. Check that the value of 7 (OH signal) is set correctly in any of Pr 60 to Pr. 63 (input terminal function selection). 				
Corrective action	Reduce the lo	ad and operatir	ng duty.		

^{*2.} Functions only when any of Pr. 60 to Pr. 63 (input terminal function selection) is set to OH.

Operation Panel Indication	Panel Indication OLT FR-PU04		FR-PU04	Stil Prev STP
Name	Stall prevention (overload)			
Description	The running frequency has fallen to 0 by stall prevention operation activated. OL appears while stall prevention is being activated.			
Check point	Check the motor for use under overload.			
Corrective action	Reduce the loa	ad weight.		

Operation Panel Indication	ОРТ	0PF	FR-PU04	Option Fault
Name	Communication error			
Description	Stops the inverter output if a setting error or connection (connector) fault occurs during use of RS-485 communication function.			
Check point	Check that the connector is plugged securely.			
Corrective action	Make connection securely. Please contact your sales representative.			

Operation Panel Indication	PE	PE	FR-PU04	Corrupt Memory
Name	Parameter storage device alarm			
Description	A fault occurred in parameters stored (example: EEPROM fault).			
Check point	Check for too many number of parameter write times.			
Corrective action	Please contac	t your sales rep	oresentative.	

Operation Panel Indication	PUE	PUE	FR-PU04	PU Leave Out
Name	Parameter Unit disconnection			
Description	Stops the inverter output if communication between inverter and PU is suspended, e.g. if the PU is disconnected with "1" set in the communication parameter n17 "disconnected PU detection/PU setting lock".			
Check point	 Check that the FR-PU04 is fitted securely. Check the setting of the communication parameter n17 "disconnected PU detection". 			
Corrective action	Fit the FR-PU	04 securely.		

Operation Panel Indication	RET	rEF	FR-PU04	Retry No Over
Name	Retry count over			
Description	If operation cannot be resumed properly within the number of retries set, this function stops the inverter output.			
Check point	Find the cause of alarm occurrence.			
Corrective action	Eliminate the	cause of the en	or preceding th	nis error indication.

Operation Panel Indication	CPU	[PU	FR-PU04	CPU Fault
Name	CPU error			
Description	If the arithmetic operation of the built-in CPU does not end within a predetermined period, the inverter self-determines it as an alarm and stops the output.			
Check point	_			
Corrective action	Please contact	t your sales rep	oresentative.	

(2) Minor failures

When the protective function is activated, the output is not shut off. You can make parameter setting to output the minor fault signal. (Set "98" in any of Pr. 64, Pr. 65 (output terminal function selection). Refer to page 110.)

Operation Panel Indication	FN	T.	FR-PU04	FN
Name	Fan trouble			
Description	For the inverter which contains a cooling fan, F_{\Box} appears on the operation panel when the cooling fan stops due to a fault.			
Check point	Check the cooling fan for a fault.			
Corrective action	Replace the fan.			

(3) Warnings

Operation Panel Indication	OL	8L	FR-PU04	OL		
Name	Stall preventio	n (overcurrent)				
	During acceleration	If a current of more than 150% (* 3) of the rated inverter current flows in the motor, this function stops the increase in frequency until the overload current decreases to prevent the inverter from resulting in overcurrent shut-off. When the overload current has decreased below 150%, this function increases the frequency again.				
Description	During constant- speed operation	If a current of more than 150% (* 3) of the rated inverter current flows in the motor, this function lowers the frequency until the overload current decreases to prevent overcurrent shut-off. When the overload current has reduced below 150%, this function increases the frequency up to the set value.				
	During deceleration	If a current of more than 150% (* 3) of the rated inverter current flows in the motor, this function stops the decrease in frequency until the overload current decreases to prevent the inverter from resulting in overcurrent shut-off. When the overload current has decreased below 150%, this function decreases the frequency again.				
Check point	Check the mo	tor for use unde	er overload.			
Corrective action	The acceleration/deceleration time may change. Increase the stall prevention operation level with Pr. 22 "stall prevention operation level", or disable stall prevention with Pr. 21 "stall prevention function selection". Check that the torque boost (Pr. 0) setting is not higher than required.					

^{*3.} The stall prevention operation current can be set as desired. It is factory-set to 150%.

Operation Panel Indication	oL	οL	FR-PU04	oL	
Name	Stall prevention (overvoltage)				
Description	During deceleration	If the regenerative energy of the motor increases too much to exceed the brake capability, this function stops the decrease in frequency to prevent overvoltage shut-off. As soon as the regenerative energy has reduced, deceleration resumes.			
Check point	Check for sudden speed reduction.				
Corrective action	The deceleration time may change. Increase the deceleration time using Pr. 8 "deceleration time".				

Operation Panel Indication	PS	<i>P</i> 5	FR-PU04	PS
Name	PU stop			
Description	Pr. 75 "reset selection/PU stop selection" had been set and a stop was made by pressing the STOP of the operation panel or parameter unit (FR-PU04) during operation in the external operation mode.			
Check point	Check for a stop made by pressing the (STOP) of the operation panel during external operation.			
Corrective action	Refer to page	115.		

Operation Panel Indication	UV	Uu	
Name	Undervoltage		
Description	If the power supply voltage of the inverter decreases, the control circuit will not operate properly and will result in decreased motor torque or increased heat generation. To prevent this, if the power supply voltage decreases below about 115VAC (about 230VAC for the three-phase 400V power input series, about 58VAC for the single-phase 100V power input series), this function stops the inverter output.		
Check point	 Check for a start of large-capacity motor. Check that the power supply capacity is as indicated in the specifications (Refer to page 196.). 		
Corrective action	Check the pov supply.	ver supply system equipment such as the power	

(4) Write errors

Operation Panel Indication	Er1	Er	1	FR-PU04	Control Mode
Name	Write disable	error			
Description	Write was performed with "1" (write disable) set in Pr. 77 "parameter write disable selection". Frequency jump setting range overlapped. Parameter write was performed though the operation panel does not have the write precedence.				
Corrective action	 (Refer to pag Check the se page 89.) When the FF the operation 	ge 118.) ettings of l R-PU04 is n panel is connector	Pr. 31 fitted invali (RS-		te disable selection". ncy jump). (Refer to or "1", the operation of cation, the operation of

Operation Panel Indication	Er2	8-2	FR-PU04	In PU/EXT Mode OPERATOR ERR
Name	Write-while-ru	nning error/mod	de designation	error
Description	An attempt wo operation mo Write was personal contents.	erformed during was made to ch ode where the r erformed in the	ange the Pr. 79 run command h external opera	nas been input. tion mode.
After stopping operation, make parameter setting. Orrective action After setting the operation mode to the "PU operation mode make parameter setting. (Refer to page 119.)				J operation mode",

Operation Panel Indication	Er3	E-3	FR-PU04	Incr I/P	
Name	Calibration error				
Description	Analog input bias and gain calibration values are too close.				
Corrective action	Check the sett (Refer to page	•	, C6 and C7 (ca	alibration functions).	

3.1.2 To know the operating status at the occurrence of alarm (only when FR-PU04 is used)

When any alarm has occurred, the display automatically switches to the indication of the corresponding protective function (error). By pressing the MON at this point without resetting the inverter, the display shows the output frequency. In this way, it is possible to know the running frequency at the occurrence of the alarm. It is also possible to know the current in the same manner. After resetting, you can confirm the definitions in "Alarm History". (For details, refer to the instruction manual of the parameter unit (FR-PU04).)

3.1.3 Correspondence between digital and actual characters

There are the following correspondences between the actual alphanumeric characters and the digital characters displayed on the operation panel:

Actual	Display
0	
1	
2	
3	3
4	<u>~</u>
5	5
6	8
7	[7]
8	8
9	9

•)	yea on the	operation
	Actual	Display
	A	
	B	
	C	
	D	8
	E	E
	F	F
	G	
	H	\square
	J	
	ı	

Actual	Display
M	[7]
N	-
0	
0	
P	
S	5
U	
V	
r	
-	-

3.1.4 Resetting the inverter

The inverter can be reset by performing any of the following operations. Note that the internal thermal integrated value of the electronic thermal relay function and the number of retries are cleared (erased) by resetting the inverter. Recover about 1s after reset is cancelled.

 ξr . (Err) flickers on the operation panel during reset.


Operation 1 Using the operation panel, perform a reset with the (STOP).

(Enabled only when the inverter protective function is activated (major failure))

Operation 2....... Switch power off once, then switch it on again after the LED on the operation panel turns off.

Operation 3 Turn on the reset signal (RES). (Assign this signal using any of Pr. 60 to Pr. 63.) (Refer to page 41, 108.)

3.1.5 Checking of the alarm history



3.2 Troubleshooting

POINTS

If the cause is still unknown after every check, it is recommended to initialize the parameters (return to factory setting) then reset the required parameter values and check again.

3.2.1 Motor remains stopped

1) Check the main circuit

- Check that a proper power supply voltage is applied (operation panel display is provided).
- Check that the motor is connected properly.
- Check that the jumper across P-P1 is connected.

2) Check the input signals

- Check that the start signal is input.
- Check that both the forward and reverse rotation start signals are not input simultaneously.
- Check that the frequency setting signal is not zero.
 - Check that the AU signal is on when the frequency setting signal is 4 to 20mA.
 - Check that the output stop signal (MRS) or reset signal (RES) is not on. (Assign signals MRS and RES using Pr. 60 to Pr. 63 (input terminal function selection).)
- Check that the sink or source jumper connector is fitted securely.

3) Check the parameter settings

- Check that the reverse rotation prevention (Pr. 78) is not selected.
- Check that the operation mode (Pr. 79) setting is correct.
- Check that the bias and gain (C2 to C7) settings are correct.
- Check that the starting frequency (Pr. 13) setting is not greater than the running frequency.
- Check that various operational functions (such as three-speed operation), especially the maximum frequency (Pr. 1), are not zero.

4) Check the load

- Check that the load is not too heavy.
 - Check that the shaft is not locked.

5) Others

- Check that the operation panel display does not show an error (e.g. OC1).
 - Check that the Pr. 15 "jog frequency" setting is not lower than the Pr. 13 "starting frequency" value.

3.2.2 Motor rotates in opposite direction
 Check that the phase sequence of output terminals U, V and W is correct. Check that the start signals (forward rotation, reverse rotation) are connected properly.
Check the setting of Pr. 17 "RUN key rotation direction selection".
3.2.3 Speed greatly differs from the setting Check that the frequency setting signal is correct. (Measure the input signal level.) Check that the following parameter settings are correct (Pr. 1, Pr. 2, Pr. 19, Pr. 38, Pr. 39, Pr. 95, C2 to C7). Check that the input signal lines are not affected by external noise. (Use shielded cables) Check that the load is not too heavy.
3.2.4 Acceleration/deceleration is not smooth Check that the acceleration and deceleration time settings are not too short. Check that the load is not too heavy. Check that the torque boost setting is not too large to activate the stal prevention function.
3.2.5 Motor current is large
 Check that the load is not too heavy. Check that the torque boost setting is not too large. Check that the rated motor frequency is set in the Pr. 3 "base frequency".
3.2.6 Speed does not increase
 Check that the maximum frequency setting is correct. Check that the load is not too heavy. (In agitators, etc., load may become heavier in winter.)
Check that the torque boost setting is not too large to activate the stall prevention function.
Check that the brake resistor is not connected to terminals P-P1 or terminals PR-P1 accidentally. (FR-S520E-0.4K to 3.7K)
3.2.7 Speed varies during operation
When slip compensation is selected, the output frequency varies with load fluctuation between 0 and 2Hz. This is a normal operation and is not a fault. 1) Inspection of load Check that the load is not varying. 2) Inspection of input signal
Check that the frequency setting signal is not varying. Check that the frequency setting signal is not affected by noise. Check for a malfunction due to an undesirable current when the transistor output unit is connected. (Refer to page 27.)
3) Others Check that the wiring length is not too long.
Check that GD ² load is not small. (at the motor GD ² or smaller) FR-S540E-1.5K to 3.7K
If so, set the Pr. 72 "PWM frequency selection" to 6kHz or higher. (Check for noise or leakage current problem.)

3.2.8 Operation mode is not changed properly

If the operation mode does not change correctly, check the following:

1. External input signal Check that the STF or STR signal is off.

When it is on, the operation mode cannot be

changed.

2. Parameter setting Check the Pr. 79 setting.

When the Pr. 79 "operation mode selection" setting is "0", switching input power on places the inverter in external operation mode. Press

the $\stackrel{\text{PU}}{\underset{\text{EXT}}{\text{}}}$ to switch to PU operation mode.

For other settings (1 to 8), the operation mode is limited accordingly.

(For details of Pr. 79, refer to page 119.)

3.2.9 Operation panel display is not operating

Make sure that terminals PC-SD are not shorted.

Make sure that the connector is fitted securely across terminals P-P1.

3.2.10 Parameter write cannot be performed

- Make sure that operation is not being performed (signal STF or STR is not ON).
- Check that the (SET) (WRITE) was pressed.
- Make sure that you are not attempting to set the parameter outside the setting range.
- Make sure that you are not attempting to set the parameter in external operation mode.
- Check Pr. 77 "parameter write disable selection".

3.2.11 Motor produces annoying sound

Check the Pr. 70 "Soft-PWM setting" and Pr. 72 "PWM frequency selection" settings.

Make sure that the deceleration time is not too short.

3.3 Precautions for maintenance and inspection

The inverter is a static unit mainly consisting of semiconductor devices. Daily inspection must be performed to prevent any fault from occurring due to the adverse effects of the operating environment, such as temperature, humidity, dust, dirt and vibration, changes in the parts with time, service life, and other factors.

3.3.1 Precautions for maintenance and inspection

For some short time after the power is switched off, a high voltage remains in the smoothing capacitor. When accessing the inverter for inspection, wait for at least 10 minutes after the power supply has been switched off, and then make sure that the voltage across the main circuit terminals P-N of the inverter is not more than 30VDC using a tester, etc.

3.3.2 Inspection item

(1) Daily inspection

- •Basically, check for the following faults during operation.
 - 1)Motor operation fault
 - 2)Improper installation environment
 - 3)Cooling system fault
 - 4) Abnormal vibration, abnormal noise
 - 5)Abnormal overheat, discoloration
- During operation, check the inverter input voltages using a tester.

(2) Cleaning

Always run the inverter in a clean status.

When cleaning the inverter, gently wipe dirty areas with a soft cloth immersed in neutral detergent or ethanol.

CAUTION -

Do not use solvent, such as acetone, benzene, toluene and alcohol, as they will cause the inverter surface paint to peel off.

3.3.3 Periodic inspection

Check the areas inaccessible during operation and requiring periodic inspection. Consult us for periodic inspection.


- 1)Cooling system fault.Clean the air filter, etc.
- 2)Tightening check and retightening.......The screws and bolts may become loose due to vibration, temperature changes, etc. Check and tighten them.

Tighten them according to the specified tightening torque.

- 3)Check the conductors and insulating materials for corrosion and damage.
- 4)Measure insulation resistance.
- 5) Check and replace the cooling fan, smoothing capacitor and relay.

3.3.4 Insulation resistance test using megger

- 1) Before performing the insulation resistance test on the external circuit, disconnect the cables from all terminals of the inverter so that the test voltage is not applied to the inverter.
- 2) For the continuity test of the control circuit, use a tester (high resistance range) and do not use the megger or buzzer.
- 3) For the inverter, conduct the insulation resistance test on the main circuit only as shown below and do not perform the test on the control circuit. (use the 500VDC megger)



3.3.5 Pressure test

Do not conduct a pressure test. Deterioration may occur.

3.3.6 Daily and periodic inspection

r z			Inte	erval		's
Area of Inspection	Inspection Item	Inspection Item		Periodic *2	Corrective Action at Alarm Occurrence	Customer's Check
IE.	Surrounding environment	Check the ambient temperature, humidity, dirt, corrosive gas, oil mist, etc	0		Improve emvironment	
General	Overall unit	Check for unusual vibration and noise	0		Check alarm location and retighten	
	Power supply voltage	Check that the main circuit voltages and control voltages are normal *1	0		Inspect the power supply	
		(1) Check with megger (across main circuit terminals and earth (ground) terminal).		0	Contact the manufacturer	
	General	(2) Check for loose screws and bolts.		0	Retighten	
		(3) Check for overheat traces on the parts.		0	Contact the manufacturer	
		(4) Check for stain		0	Clean	
	Conductors,	(1) Check conductors for distortion. (2) Check cable sheaths for		0	Contact the manufacturer	
	cables	breakage and deterioration (crack, discoloration, etc.)		0	Contact the manufacturer	
Main circuit	Transformer/ reactor	Check for unusual odor and abnormal increase in whining sound.	0		Stop the device and contact the manufacturer.	
Ma	Terminal block	Check for damage.		0	Stop the device and contact the manufacturer.	
	Smoothing aluminum	(1) Check for liquid leakage.		0	Contact the manufacturer	
	electrolytic capacitor	(2) Check for safety valve projection and bulge.		0	Contact the manufacturer	
	Relay/ Check that the operation is normal and no chatter is heard.			0	Contact the manufacturer	
	Resistor	(1) Check for crack in resistor insulation.		0	Contact the manufacturer	
	Resistof	(2) Check for a break in the cable.		0	Contact the manufacturer	

_ u				Inte	erval		လု	Ī
Area of Inspectic	Area of Inspection Item		Inspection Item		Periodic *2	Corrective Action at Alarm Occurrence	Customer' Check	
#		(1) Check that the output voltages across phases with the inverter operated alone is balanced			0	Contact the manufacturer		
Control circuit / protective circuit	che		(2) Check that no fault is found in protective and display circuits in a sequence protective operation test.		0	Contact the manufacturer		
ircuit / pr	check	Overall	(1) Check for unusual odor and discoloration.		0	Stop the device and contact the manufacturer.		
ontrol c	Parts che		(2) Check for serious rust development		0	Contact the manufacturer		
ŏ	Aluminum electrolytic capacitor		Check for liquid leakage in a capacitor and deformation trance		0	Contact the manufacturer		
			(1) Check for unusual vibration and noise.	0		Replace the fan		
Cooling system	Coc	ling fan	(2) Check for loose screws and bolts		0	Retighten		
g s)			(3) Check for stain		0	Clean		
olin	Ц	ıtsink	(1) Check for clogging		0	Clean		
Ö	1100	ILSIIIK	(2) Check for stain		0	Clean		
	Λir	filter, etc.	(1) Check for clogging		0	Clean or replace		
	All	iilei, elc.	(2) Check for stain		0	Clean or replace		
	Indication Meter		(1) Check that display is normal.	0		Contact the manufacturer		S
ola)			(2) Check for stain		0	Clean		٥
Dis			Check that reading is normal	0		Stop the device and contact the manufacturer.		PROTECTIVE FUNCTIONS
Load motor	Operation check		Check for vibration and abnormal increase in operation noise	0		Stop the device and contact the manufacturer.		■ PROTECT

^{*1} It is recommended to install a device to monitor voltage for checking the power supply voltage to the inverter.

^{*2} One to two years of periodic inspection cycle is recommended. However, it differs according to the installation environment.

Consult us for periodic inspection.

3.3.7 Checking the inverter and converter module

<Preparation>

- Disconnect the external power supply cables (R, S, T) and motor cables (U, V, W).
- (2) Prepare a tester. (Use 100Ω range).

<Checking method>

Change the polarity of the tester alternately at the inverter terminals R, S, T, U, V, W, P and N, and check for continuity.


CAUTION =

- •Before measurement, check that the smoothing capacitor is discharged.
- •At the time of discontinuity, the measured value is almost ∞ . When there is an instantaneous continuity, due to the smoothing capacitor, the tester may not indicate ∞ . At the time of continuity, the measured value is several to several ten's-of ohms depending on the module type, circuit tester type, etc. If all measured values are almost the same, the modules are without fault.

Module device numbers and terminals to be checked

			Tester	Polarity	Process		Tester	Polarity	Process
			+		value		+		value
		D1	R	Р	Discontinuity	D4	R	N	Continuity
ē	Ф	וט	Р	R	Continuity	D4	N	R	Discontinuity
Converter	Module	D2	S	Р	Discontinuity	D5	S	N	Continuity
Š	<u>8</u>	DZ	Р	S	Continuity	D3	N	S	Discontinuity
ပိ	2	D3	T	Р	Discontinuity	D6	Т	N	Continuity
		D3	Р	T	Continuity	D0	N	T	Discontinuity
		TR1	U	Р	Discontinuity	TR4	U	N	Continuity
<u>_</u>	Φ	1171	Р	U	Continuity	111.4	N	U	Discontinuity
Inverter	Module	TR3	V	Р	Discontinuity	TR6	V	N	Continuity
Ĭ Š	<u> </u>	113	Р	V	Continuity	1110	N	V	Discontinuity
=	2	TR5	W	Р	Discontinuity	TR2	W	N	Continuity
		113	Р	W	Continuity	1112	N	W	Discontinuity

(Assumes the use of an analog meter.)



REMARKS

The FR-S520SE-0.1K to 1.5K and FR-S510WE-0.1K to 0.75K do not have T, D3 and D6.

3.3.8 Replacement of parts

The inverter consists of many electronic parts such as semiconductor devices. The following parts may deteriorate with age because of their structures or physical characteristics, leading to reduced performance or fault of the inverter. For preventive maintenance, the parts must be replaced periodically.

Part Name	Standard Replacement Interval	Description
Cooling fan	2 to 3 years	Replace (as required)
Main circuit smoothing capacitor	10 years *	Replace (as required)
On-board smoothing capacitor	10 years *	Replace the board (as required)
Relays	_	Replace as required

^{*}The design life of electrolytic capacitor is about ten years (36000h) if used for 10 hours a day and 365 days a year in the average yearly ambient temperature of 40°C.

- CAUTION

For parts replacement, consult the nearest Mitsubishi FA Center.

(1) Cooling fan

The cooling fan is used to cool heat-generating parts such as the main circuit semiconductors. The life of the cooling fan bearing is usually 10,000 to 35,000 hours. Hence, the cooling fan must be replaced every 2 to 3 years if the inverter is run continuously. When unusual noise and/or vibration is noticed during inspection, the cooling fan must be replaced immediately.

Inverter Type	Fan Type
FR-S520E-1.5K, 2.2K, 3.7K, FR-S520SE-1.5K	MMF-06D24DS BKO-C2461H07
FR-S540E-1.5K, 2.2K, 3.7K	MMF-06D24ES-FC4 BKO-CA1027H09

Removal


1) Remove the front cover and wiring cover.

Unplug the fan connectors.
 The cooling fan is connected to the cooling fan connector beside the main circuit terminal block of the inverter.

Unplug the connector and separate the inverter from the cooling fan.

- Remove the cooling fan cover. Disengage the fixing hooks pointed by arrows to remove the cooling fan cover.
- Remove the cooling fan and cooling fan cover.
 The cooling fan is secured by the fixing hooks.

Disengage the fixing hooks to remove the cooling fan and cooling fan cover.




Reinstallation

 After confirming the orientation of the fan, reinstall the fan so that the arrow on the left of "AIR FLOW" faces up.

-CAUTION-

Installing the fan in the opposite air flow direction can cause the inverter life to be shorter.



- Reinstall the fan cover to the inverter.
 Run the cable through the wiring groove to prevent it from being caught between the chassis and cover.
- 3) Reconnect the cable to the connector. (Refer to "Removal" for the position of the connector.)
- 4) Reinstall the wiring cover.

(2) Smoothing capacitors

A large-capacity aluminum electrolytic capacitor is used for smoothing in the main circuit DC section, and an aluminum electrolytic capacitor is used for stabilizing the control power in the control circuit. Their characteristics are deteriorated by the adverse effects of ripple currents, etc. The replacement intervals greatly vary with the ambient temperature and operating conditions. When the inverter is operated in airconditioned, normal environment conditions, replace the capacitors about every 10 years.

When a certain period of time has elapsed, the capacitors will deteriorate more rapidly. Check the capacitors at least every year (less than six months if the life will be expired soon).

The appearance criteria for inspection are as follows:

- 1) Case: Check the side and bottom faces for expansion
- 2) Sealing plate: Check for remarkable warp and extreme crack.
- 3) Check for external crack, discoloration, fluid leakage, etc. Judge that the capacitor has reached its life when the measured capacitance of the capacitor reduced below 85% of the rating.

(3) Relays


To prevent a contact fault, etc., relays must be replaced according to the cumulative number of switching times (switching life).

3.3.9 Measurement of main circuit voltages, currents and powers

· Measurement of voltages and currents

Since the voltages and currents on the inverter power supply and output sides include harmonics, measurement data depends on the instruments used and circuits measured.

When instruments for commercial frequency are used for measurement, measure the following circuits with the instruments given on the next page.



Examples of Measuring Points and Instruments

CAUTION

Use an FFT to measure the output voltages accurately.

A tester or general measuring instrument cannot measure accurately.

Measuring Points and Instruments

	Measuri	ng Points and inst	uunents
Item	Measuring Point	Measuring Instrument	Remarks (Reference Measurement Value)
Power supply voltage V1	Across R-S, S-T, T-R	Moving-iron type AC voltmeter	Commercial power supply Within permissible AC voltage fluctuation (Refer to page 196.)
Power supply side current	R, S, and T line currents	Moving-iron type AC ammeter	
Power supply side power P1	At R, S and T, and across R- S, S-T and T- R	Electrodynamic type single-phase wattmeter	,
Power supply side power factor Pf1	Calculate after and power supplifies phase phas	oly side power. ower supply] [F	voltage, power supply side current for single-phase power supply] $Pf1 = \frac{P1}{V1 \times I1} \times 100\%$
Output side voltage V2	Across U-V, V-W and W-U	Rectifier type AC voltmeter (Caution 1) (Moving-iron type cannot measure)	Difference between the phases is within $\pm 1\%$ of the maximum output voltage.
Output side current I2	U, V and W line currents	Moving-iron type AC ammeter (Caution 2)	Current should be equal to or less than rated inverter current. Difference between the phases is 10% or lower of the rated inverter current.
Output side power P2	U, V, W and U-V, V-W	Electrodynamic type single-phase wattmeter	P2 = W21 + W22 2-wattmeter method (or 3-wattmeter method)
Output side power factor Pf2	Calculate in simple Pf2= $\frac{P2}{\sqrt{3}V2\times12}$	illar manner to power sup $\frac{1}{2}$ $ imes$ 100%	oply side power factor.
Converter output	Across P-N	Moving-coil type (such as tester)	Inverter LED display is lit 1.35 × V1
Frequency setting signal	Across 2(+)-5 Across 4(+)-5		0 to 5VDC/0 to 10VDC 4 to 20mADC
Frequency setting power supply	Across 10(+)-5		10 to 5VDC/0 to 10VDC 4 to 20mADC 5VDC
Frequency meter signal	Across FM(+)-SD	Moving-coil type (Tester and such may be used) (Internal resistance: 50kΩ or larger)	Approx. 5VDC at maximum frequency (without frequency meter) T1 BVDC T2 Pulse width T1: Adjust with C1 Pulse cycle T2: Set with Pr. 55 (Pr. 56)

Item	Measuring Point	Measuring Instrument	Remarks (Reference Measurement Value
Start signal Select signal	Across STF, STR, RH, RM, RL-SD	Moving-coil type (Tester and such may be used) (Internal resistance: 50kΩ or larger)	When open 20 to 30VDC ON voltage: 1V or less
Alarm signal	Across A-C Across B-C	Moving-coil type (such as tester)	Continuity check

— CAUTION =

- 1. Use an FFT to measure the output voltage accurately. An FA tester or general measuring instrument cannot measure accurately.
- 2. When the carrier frequency exceeds 5kHz, do not use this instrument since using it may increase eddy-current losses produced in metal parts inside the instrument, leading to burnout.

 In this case, use the approximately effective value type instrument.

4. SPECIFICATIONS

This chapter provides the "specifications" of this product. Always read the instructions before using the equipment

4.1	Specification list	196
4.2	Outline dimension drawings	202

Chapter 1

Chapter 2

Chapter 3

Chapter 4

4.1 Specification list

4.1.1 Ratings

(1) Three-phase 200V power supply

Ту	pe FR-S520E-□K (-C)	0.1	0.2	0.4	0.75	1.5	2.2	3.7	
Αp	pplied motor capacity (kW) (*1)	0.1	0.2	0.4	0.75	1.5	2.2	3.7	
	Rated capacity (kVA) (*2)	0.3	0.5	1.0	1.6	2.8	4.0	6.6	
Output	Rated current (A)	0.8	1.4	2.5	4.1	7.0	10	16.5	
Out	Overload current rating (*3)	150%	150% 60s, 200% 0.5s (inverse time characteristics)						
	Voltage (*4)	Three-phase 200 to 240V							
١١	Rated input AC voltage/frequency	Three-phase 200 to 240V 50Hz/60Hz							
upply	Permissible AC voltage fluctuation	170 to 264V 50Hz/60Hz							
ower s	Permissible frequency fluctuation	Within ±5%							
Powe	Power supply system capacity (kVA) (*5)	0.4	0.7	1.2	2.1	4.0	5.5	9	
Pr	otective structure (JEM1030)	Enclosed type (IP20), IP40 for totally enclosed structure series					re series		
Co	poling system	Self-cooling Forced air coolin			oling				
Approximate mass (kg)		0.5	0.5	8.0	0.9	1.5	1.5	2.1	

- *1. The applied motor capacity indicated is the maximum capacity applicable for use of the Mitsubishi 4-pole standard motor.
- *2. The rated output capacity indicated assumes that the output voltage is 230V.
- *3. The % value of the overload current rating indicated is the ratio of the overload current to the inverter's rated output current.
 - For repeated duty, allow time for the inverter and motor to return to or below the temperatures under 100% load.
- *4. The maximum output voltage does not exceed the power supply voltage. You can set the maximum output voltage to any value below the power supply voltage. However, the pulse voltage value of the inverter output side voltage remains unchanged at about √2 that of the power supply.
- *5. The power supply capacity changes with the values of the power supply side inverter impedances (including those of the input reactor and cables).

(2) Three-phase 400V power supply

Тур	e FR-S540E-□K	0.4	0.75	1.5	2.2	3.7		
App	lied motor capacity (kW) (*1)	0.4	0.75	1.5	2.2	3.7		
	Rated capacity (kVA) (*2)	0.9	1.6	2.7	3.7	5.9		
Output	Rated current (A)	1.1	2.1	3.5	4.8	7.7		
Ont	Overload current rating (*3)	150% 60	150% 60s, 200% 0.5s (Inverse time characteristics)					
	Voltage (*4)		Three phase, 380V to 480V					
>	Rated input AC voltage/frequency	Th	Three phase, 380V to 480V 50Hz/60Hz					
ddn	Permissible AC voltage fluctuation	325 to 528V 50Hz/60Hz						
ower supply	Permissible frequency fluctuation		±5%					
Powe	Power supply system capacity (kVA) (*5)	1.5	2.5	4.5	5.5	9.5		
Pro	Protective structure (JEM1030)		Enclosed type (IP20)					
Coc	oling system	Self-c	ooling	For	ced air coo	ling		
Approximate mass (kg)		1.5	1.5	1.5	1.6	1.7		

- *1. The applied motor capacity indicated is the maximum capacity applicable for use of the Mitsubishi 4-pole standard motor.
- *2. The rated output capacity indicated assumes that the output voltage is 440V.
- *3. The % value of the overload current rating indicated is the ratio of the overload current to the inverter's rated output current.
 - For repeated duty, allow time for the inverter and motor to return to or below the temperatures under 100% load.
- *4. The maximum output voltage does not exceed the power supply voltage. You can set the maximum output voltage to any value below the power supply voltage. However, the pulse voltage value of the inverter output side voltage remains unchanged at about √2 that of the power supply.
- *5. The power supply capacity varies with the value of the power supply side inverter impedance (including those of the input reactor and cables).

(3) Single-phase 200V power supply

Type FR-S520SE-□K		0.1	0.2	0.4	0.75	1.5		
Applied motor capacity (kW) (*1)		0.1	0.2	0.4	0.75	1.5		
	Rated capacity (kVA) (*2)	0.3	0.5	1.0	1.6	2.8		
Output	Rated current (A)	0.8	1.4	2.5	4.1	7.0		
Out	Overload current rating (*3)	150% 60	150% 60s, 200% 0.5s (Inverse time characteristics)					
_	Voltage (*4)	Three phase, 200V to 240V						
>	Rated input AC voltage/frequency	Single-phase, 200V to 240V 50Hz/60Hz						
supply	Permissible AC voltage fluctuation	170 to 264V 50Hz/60Hz						
S J	Permissible frequency fluctuation	±5%						
Power	Power supply system capacity (kVA) (*5)	0.5	0.9	1.5	2.5	4.4		
Pro	tective structure (JEM1030)	Enclosed type (IP20)						
Cooling system		Self-cooling				Forced air cooling		
Approximate mass (kg)		0.5	0.6	0.8	1.0	1.5		

- *1. The applied motor capacity indicated is the maximum capacity applicable when a Mitsubishi 4-pole standard motor is used.
- *2. The rated output capacity indicated assumes that the output voltage is 230V.
- *3. The % value of the overload current rating indicated is the ratio of the overload current to the inverter's rated output current. For repeated duty, allow time for the inverter to return to or below the temperatures under 100% load.
- *4. The maximum output voltage does not exceed the power supply voltage. The maximum output voltage may be set as desired below the power supply voltage. However, the PWM pulse voltage value of the inverter output side voltage remains unchanged at about √2 that of the power supply.
- *5. The power supply capacity changes with the values of the power supply side inverter impedances (including those of the input reactor and cables).

(4) Single-phase 100V power supply

Ту	pe FR-S510WE-□K	0.1	0.2	0.4	0.75		
Ap	plied motor capacity (kW) (*1)	0.1	0.2	0.4	0.75		
	Rated capacity (kVA) (*2)	0.3	0.5	1.0	1.6		
Output	Rated current (A)	0.8	1.4	2.5	4.1		
Out	Overload current rating (*3)	150% 60s,	150% 60s, 200% 0.5s (Inverse time characteristics)				
	Voltage	Three phase, 200V to 230V (*4, 6)					
Ş	Rated input AC voltage/frequency	Single-phase, 100V to 115V 50Hz/60Hz					
supply	Permissible AC voltage fluctuation	90 to 132V 50Hz/60Hz					
S	Permissible frequency fluctuation	±5%					
Power	Power supply system capacity (kVA) (*5)	0.5	0.9	1.5	2.5		
Protective structure (JEM1030)		Enclosed type (IP20)					
Cooling system			Self-c	ooling			
Approximate mass (kg)		0.6	0.7	0.9	1.6		

- *1. The applied motor capacity indicated is the maximum capacity applicable when a Mitsubishi 4-pole standard motor is used.
- *2. The rated output capacity indicated assumes that the output voltage is 230V.
- *3. The % value of the overload current rating indicated is the ratio of the overload current to the inverter's rated output current.

 For repeated duty, allow time for the inverter to return to or below the temperatures under
 - For repeated duty, allow time for the inverter to return to or below the temperatures under 100% load.
- *4. For single-phase 100V power input, the output voltage provided cannot be twice or more than the power supply voltage.
- *5. The power supply capacity changes with the values of the power supply side inverter impedances (including those of the input reactor and cables).
- *6. For single-phase 100V power input, the application of motor load reduces the output voltage about 10 to 15%. Therefore, the load must be reduced when a general-purpose motor is used

4.1.2 Common specifications


	Coı	ntrol method		Selectable between Soft-PWM control and high of frequency PWM control, selectable between V/F cautomatic torque boost control.		
	Output frequency range		y range	0.5 to 120Hz (starting frequency variable between 0 and 60Hz)		
	Frequency setting resolution			5VDC input: 1/500 of max. set frequency, 10VDC, 4 to 20mADC input: 1/1000 of max. set frequency Digital input: 0.1Hz (less than 100Hz), 1Hz (100Hz or higher)		
	Frequency accuracy		racy	Analog input: Within ±1% of max. output frequency (25°C±10°C) Digital input: Within ±0.5% of set output frequency (when set by the setting dial)		
	Sta	rting torque		150% (at 5Hz) during automatic torque boost con	trol	
	Acceleration/deceleration time setting		celeration	0, 0.1 to 999s (acceleration and deceleration can individually), linear or S-pattern acceleration/decemode can be selected.	eleration	
	Braking torque Regeneration		Regeneration	0.1K, 0.2K 150%, 0.4K, 0.75K 100%, 1.5K 50%, 2.2K, 3.7K 20%		
ons	(*2) DC injection brake		DC injection brake	Operation frequency (0 to 120Hz), operation time (0 to 10s), operation voltage (0 to 15%)		
ati		Frequency	Analog input	0 to 5VDC, 0 to 10VDC, 4 to 20mA		
specific		setting signal	Digital input	Entered from operation panel		
Control specifications		Start signal	STF, STR	Forward and reverse rotation, start signal automatic self-holding input (3-wire input) can be selected.		
ŏ		Reset		Reset the alarm output when the protective function is activated.		
	nals	Multi-speed selection		Up to 15 speeds can be selected. (Each speed can be set between 0 and 120Hz, running speed can be changed during operation from the operation panel.)		
	Input signals	Second function selection		Used to select second functions (acceleration time, deceleration time, torque boost, base frequency, electronic thermal relay function).	Use Pr. 60 to	
		Output stop		Instantaneous shut-off of inverter output (frequency, voltage)	Pr. 63 for selection	
		Current inpu	it selection	Used to select frequency setting signal 4 to 20 mA (terminal 4).		
		External the input	rmal relay	Thermal relay contact input for use when the inverter is stopped by the external thermal relay.		
		Jog signal		Jog operation mode selection		
		PID control	valid	Selection for exercising PID control		
		PU operatio		Used to switch between PU operation and		
	operation switchover		vitchover	external operation from outside the inverter.		


	Operational functions		Maximum and minimum frequency settings, frequency jump operation, external thermal relay input selection, automatic restart after instantaneous power failure, forward/reverse rotation prevention, slip compensation, operation mode selection, PID control, computer link operation (RS-485).			
Control specifications	Output signals	Operating Status	1 open collector signal can be selected from among inverter running, up-to-frequency, frequency detection, overload warning, zero current detection, output current detection, PID upper limit, PID lower limit, PID forward/reverse rotation, operation ready, current average value monitor signal, maintenance timer alarm, minor failure and alarm. 1 contact output (1 changeover contact, 230V 0.3AAC, 30V 0.3ADC) signal can be selected.	or n		
		For meter	1 signal can be selected from between output frequency an motor current. Pulse train output (1440 pulses/s, 1mA full scale)			
Pro	otect	tive/warning function	Overcurrent shut-off (during acceleration, deceleration, constant speed), regenerative overvoltage shut-off (during acceleration, deceleration, constant speed), overload shut-off (electronic thermal relay function), heatsink overheat, fan failure (*3), stall prevention, brake transistor alarm (*4), start-time output side earth (ground) fault protection (*5), external thermal relay (*6), disconnected PU, retry count over, communication error, CPU error, undervoltage (*1)			
		ibient nperature	-10°C to +50°C (non-freezing) (-10°C to +40°C for totally enclosed structure feature)			
ent	Am	bient humidity	90%RH or less (non-condensing)			
Environment		orage nperature (*7)	-20°C to +65°C			
Env	Atn	nosphere	Indoors (without corrosive gas, flammable gas, oil mist, dust and dirt etc.)			
	Alti	tude, vibration	Maximum 1000m above seal level, 5.9m/s ² or less			

- *1. When undervoltage or instantaneous power failure occurs, no alarm output is provided but the output is shut off. After power restoration, the inverter may be run as it is. Depending on the running status (e.g. load magnitude), however, overcurrent, regenerative overvoltage or other protection may be activated at power restoration. (in the external operation mode)
- *2. The braking torque indicated is a short-duration average torque (which varies with motor loss) when the motor alone is decelerated from 60Hz in the shortest time and is not a continuous regenerative torque. When the motor is decelerated from the frequency higher than the base frequency, the average deceleration torque will reduce. Since the inverter does not contain a brake resistor, use an optional brake resistor when regenerative energy is large. (Available for the FR-S520E-0.4K to 3.7K only.) A brake unit (BU) may also be used.
- *3. Compatible with only the product having the built-in cooling fan.
- *4. Available for the FR-S520E-0.4K to 3.7K only.
- *5. Activated only when "1" is set in Pr. 40 start-time earth (ground) fault detection selection".
- *6. Activated only when external thermal relay input (OH) is selected in any of Pr. 60 to Pr. 63 (input terminal function selection).
- *7. Temperature applicable for a short period such as transportation.

4.2 Outline dimension drawings

- •FR-S520E-0.1K, 0.2K, 0.4K, 0.75K
- •FR-S520SE-0.1K, 0.2K, 0.4K, 0.75K
- •FR-S510WE-0.1K, 0.2K, 0.4K





•Three-phase 200V power supply

Capacity	D	D1	D2
0.1K,0.2K	80.5	10	52
0.4K	112.5	42	52
0.75K	132.5	62	52

•Single-phase 200V power supply

Capacity	D	D1	D2
0.1K,0.2K	80.5	10	52
0.4K	142.5	42	82
0.75K	162.5	62	82

•Single-phase 100V power supply


Capacity	D	D1	D2
0.1K	80.5	10	52
0.2K	110.5	10	82
0.4K	142.5	42	82


(Unit: mm)

REMARKS

For dimensions of the totally enclosed structure type, refer to those of the standard type inverter of the same capacity.

- •FR-S520E-1.5K, 2.2K, 3.7K
- •FR-S540E-0.4K, 0.75K, 1.5K, 2.2K, 3.7K
- •FR-S520SE-1.5K
- •FR-S510WE-0.75K





•Three-phase 200V power supply

Capacity	W	W1	D	D1	D2	D3
1.5K,2.2K	108	96	135.5	65	52	8
3.7K	170	158	142.5	72	52	5

•Three-phase 400V power supply

Capacity	W	W1	D	D1	D2	D3
0.4K,0.75K	108	96	129.5	59	52	5
1.5K	108	96	135.5	65	52	8
2.2K	108	96	155.5	65	72	8
3.7K	108	96	165.5	65	82	8

•Single-phase 200V power supply

Capacity	W	W1	D	D1	D2	D3
1.5K	108	96	155.5	65	72	8

Single-phase 100V power supply

0 1			,			
Capacity	W	W1	D	D1	D2	D3
0.75K	108	96	149.5	59	72	5
						/! ! '!


(Unit: mm)

REMARKS

- •The FR-S540E-0.4K, 0.75K and FR-S510WE-0.75K do not have a cooling fan.
- •For dimensions of the totally enclosed structure type, refer to those of the standard type inverter of the same capacity.

mounting threads.

•Parameter unit (FR-PU04)



APPENDIX

APPENDIX 1	Parameter instruction code list	206

APPENDIX 1 Parameter instruction code list

Func-	Parameter			uction de	Computer Link Data	Link Parameter Extension
tion	Number	Name	Read	Write	Setting Increments*	Setting (Instruction Code 7F/FF)
	0	Torque boost	00	80	0.1%	0
	1	Maximum frequency	01	81	0.01Hz	0
	2	Minimum frequency	02	82	0.01Hz	0
	3	Base frequency	03	83	0.01Hz	0
	4	Multi-speed setting (high speed)	04	84	0.01Hz	0
ctions	5	Multi-speed setting (middle speed)	05	85	0.01Hz	0
Basic functions	6	Multi-speed setting (low speed)	06	86	0.01Hz	0
asi	7	Acceleration time	07	87	0.1s	0
ä	8	Deceleration time	80	88	0.1s	0
	9	Electronic thermal O/L relay	09	89	0.01A	0
	30	Extended function display selection	1E	9E	1	0
	79	Operation mode selection	4F	None	1	0

The extended function parameters are made valid by setting "1" in Pr. 30 "extended function display selection".

Func-	Parameter	Name		iction de	Computer Link Data	Link Parameter Extension Setting
tion	Number		Read	Write	Setting Increments *	(Instruction Code 7F/FF)
	10	DC injection brake operation frequency	0A	8A	0.01Hz	0
	11	DC injection brake operation time	0B	8B	0.1s	0
suc	12	DC injection brake voltage	0C	8C	0.1%	0
cţi	13	Starting frequency	0D	8D	0.01Hz	0
Į į	14	Load pattern selection	0E	8E	1	0
L C	15	Jog frequency	0F	8F	0.01Hz	0
Standard operation functions	16	Jog acceleration/ deceleration time	10	90	0.1s	0
ard op	17	RUN key rotation direction selection	11	91	1	0
l ğu	19	Base frequency voltage	13	93	0.1V	0
Sta	20	Acceleration/deceleration reference frequency	14	94	0.01Hz	0
21		Stall prevention function selection	15	95	1	0
	22	Stall prevention operation level	16	96	0.1%	0

Func-	Parameter	Name		iction de	Computer Link Data	Link Parameter Extension Setting
tion	Number		Read	Write	Setting Increments *	(Instruction Code 7F/FF)
	23	Stall prevention operation level compensation factor at double speed	17	97	0.1%	0
	24	Multi-speed setting (speed 4)	18	98	0.01Hz	0
	25	Multi-speed setting (speed 5)	19	99	0.01Hz	0
	26	Multi-speed setting (speed 6)	1A	9A	0.01Hz	0
ions	27	Multi-speed setting (speed 7)	1B	9B	0.01Hz	0
Standard operation functions	28	Stall prevention operation reduction starting frequency	1C	9C	0.01Hz	0
eratic	29	Acceleration/deceleration pattern	1D	9D	1	0
do	31	Frequency jump 1A	1F	9F	0.01Hz	0
D a	32	Frequency jump 1B	20	A0	0.01Hz	0
ا گو	33	Frequency jump 2A	21	A1	0.01Hz	0
ital	34	Frequency jump 2B	22	A2	0.01Hz	0
0)	35	Frequency jump 3A	23	A3	0.01Hz	0
	36	Frequency jump 3B	24	A4	0.01Hz	0
	37	Speed display	25	A5	0.001	0
	38	Frequency setting voltage gain frequency	26	A6	0.01Hz	0
	39	Frequency setting current gain frequency	27	A7	0.01Hz	0
	40	Start-time earth (ground) fault detection selection	28	A8	1	0
	41	Up-to-frequency	29	A9	0.1%	0
Output terminal functions	42	Output frequency detection	2A	AA	0.01Hz	0
Our	43	Output frequency detection for reverse rotation	2B	AB	0.01Hz	0
- σ	44	Second acceleration/ deceleration time	2C	AC	0.1s	0
on ioi	45	Second deceleration time	2D	AD	0.1s	0
Second	46	Second torque boost	2E	AE	0.1%	0
S ⊒	47	Second V/F (base frequency)	2F	AF	0.01Hz	0
ction	48	Output current detection level	30	В0	0.1%	0
Current detection	49	Output current detection signal delay time	31	B1	0.1s	0
- int	50	Zero current detection level	32	B2	0.1%	0
Curre	51	Zero current detection period	33	В3	0.01s	0

Func-	Parameter	Name		uction de	Computer Link Data	Link Parameter Extension Setting
tion	Number		Read	Write	Setting Increments *	(Instruction Code 7F/FF)
6	52	Operation panel display data selection	34	B4	1	0
ctions	53	Frequency setting operation selection	35	B5	1	0
ıy fun	54	FM terminal function selection	36	В6	1	0
Display functions	55	Frequency monitoring reference	37	В7	0.01Hz	0
	56	Current monitoring reference	38	В8	0.01A	0
Automatic restart functions	57	Restart coasting time	39	В9	0.1s	0
Auto res func	58	Restart cushion time	3A	ВА	0.1s	0
Additional function	59	Remote setting function selection	3B	BB	1	0
	60	RL terminal function selection	3C	вс	1	0
	61	RM terminal function selection	3D	BD	1	0
Terminal functions selection	62	RH terminal function selection	3E	BE	1	0
funci sele	63	STR terminal function selection	3F	BF	1	0
	64	RUN terminal function selection	40	C0	1	0
	65	A, B, C terminal function selection	41	C1	1	0
	66	Retry selection	42	C2	1	0
	67	Number of retries at alarm occurrence	43	C3	1	0
S	68	Retry waiting time	44	C4	0.1s	0
l jë	69	Retry count display erase	45	C5	1	0
nct	70	Soft-PWM setting	46	C6	1	0
<u>_</u>	71	Applied motor	47	C7	1	0
lection functions	72	PWM frequency selection	48	C8	1	0
ect	73	0-5V/0-10V selection	49	C9	1	0
sel	74	Input filter time constant	4A	CA	1	0
Operation se	75	Reset selection/PU stop selection	4B	СВ	1	0
Opera	76	Cooling fan operation selection	4C	СС	1	0
	77	Parameter write disable selection	4D	None	1	0
	78	Reverse rotation prevention selection	4E	CE	1	0

Func-	Parameter	Name		iction de	Computer Link Data	Link Parameter Extension Setting
tion	Number		Read	Write	Setting Increments *	(Instruction Code 7F/FF)
80		Multi-speed setting (speed 8)	50	D0	0.01Hz	0
_	81	Multi-speed setting (speed 9)	51	D1	0.01Hz	0
ratior	82	Multi-speed setting (speed 10)	52	D2	0.01Hz	0
edo p	83	Multi-speed setting (speed 11)	53	D3	0.01Hz	0
Multi-speed operation	84	Multi-speed setting (speed 12)	54	D4	0.01Hz	0
Multi-	85	Multi-speed setting (speed 13)	55	D5	0.01Hz	0
	86	Multi-speed setting (speed 14)	56	D6	0.01Hz	0
	87	Multi-speed setting (speed 15)	57	D7	0.01Hz	0
	88	PID action selection	58	D8	1	0
	89	PID proportional band	59	D9	0.1%	0
<u> </u>	90	PID integral time	5A	DA	0.1s	0
ont	91	PID upper limit	5B	DB	0.1%	0
PID control	92	PID lower limit	5C	DC	0.1%	0
₫	93	PID action set point for PU operation	5D	DD	0.01%	0
	94	PID differential time	5E	DE	0.01s	0
	95	Rated motor slip	5F	DF	0.01%	0
SU	96	Slip compensation time constant	60	E0	0.01s	0
Sub functions	97	Constant power range slip compensation selection	61	E1	1	0
Sub	98	Automatic torque boost selection (Motor capacity)	62	E2	0.01kW	0
	99	Motor primary resistance	63	E3	0.001Ω	0
	H1 (503)	Maintenance timer	03	_	1	5
90 _	H2 (504)	Maintenance timer alarm output set time	04	84	1	5
Maintenan function	H3 (555)	Current average time	37	В7	0.1s	5
Ma	H4 (556)	Data output mask time	38	B8	0.1s	5
	H5 (557)	Current average value monitor signal output reference current	39	В9	0.01A	5

Func-	Parameter	Name		iction de	Computer Link Data	Link Parameter Extension Setting
tion	Number		Read	Write	Setting Increments *	(Instruction Code 7F/FF)
unction	H6 (162)	Automatic restart after instantaneous power failure selection	3E	BE	1	1
Brake function Additional function	H7 (559)	Second electronic thermal O/L relay	3B	BB	0.01A	5
unction	b1 (560)	Regenerative function selection	3C	ВС	1	5
Brake fu	b2 (561)	Special regenerative brake duty	3D	BD	0.1%	5
	C1 (900)	FM terminal calibration	5C	DC	_	1
ω	C2(902)	Frequency setting voltage bias frequency	5E	DE	0.01Hz	1 (6C/EC=0)
neter	C3(902)	Frequency setting voltage bias	5E	DE	0.1%	1 (6C/EC=1)
Calibration parameters	C4(903)	Frequency setting voltage gain	5F	DF	0.1%	1 (6C/EC=1)
ation	C5(904)	Frequency setting current bias frequency	60	E0	0.01Hz	1 (6C/EC=0)
alibra	C6(904)	Frequency setting current bias	60	E0	0.1%	1 (6C/EC=1)
C7(905)		Frequency setting current gain	61	E1	0.1%	1 (6C/EC=1)
	C8(269)	Parameter for manufacture	er settin	ıg.		
Clear parameters	CLr	Parameter clear		FC	1	
Cle	ECL	Alarm history clear	_	F4	1	_

Func-	Parameter	Name		iction de	Computer Link Data	Link Parameter Extension Setting
tion	Number		Read	Write	Setting Increments *	(Instruction Code 7F/FF)
	n1 (331)	Communication station number	1F	9F	1	3
		Communication speed	20	A0	1	3
	n3 (333)	Stop bit length	21	A1	1	3
	n4 (334)	Parity check presence/ absence	22	A2	1	3
S	n5 (335)	Number of communication retries	23	А3	1	3
Communication parameters	n6 (336)	Communication check time interval	24	A4	0.1s	3
ara	n7 (337)	Waiting time setting	25	A5	1	3
ğ		Run command source	26	A6	1	3
.o	n9 (339)	Speed command source	27	A7	1	3
nicat	n10 (340)	Link startup mode selection	28	A8	1	3
L E		CR, LF selection	29	A9	1	3
Ē	n12 (342)	EEPROM write selection	2A	AA	1	3
ပိ	n13 (145)	PU display language selection	2D	AD	1	1
	n14 (990)	PU buzzer control	5A	DA	1	9
	n15 (991)	PU contrast adjustment	5B	DB	1	9
n16 (99		PU main display screen data selection	5C	DC	1	9
	n17 (993)	Disconnected PU detection/PU setting lock	5D	DD	1	9

The parameter numbers in parentheses are those for use with the parameter unit (FR-PU04).

^{*} Though parameter setting by RS-485 communication can be made in the setting increments indicated in the table, note that the valid setting increments are as indicated in the parameter list (page 56).

*The manual number is given on the bottom left of the back cover.

Print Date	*Manual Number	ne manual number is given on the bottom left of the back cover. Revision
Jun., 2003	IB(NA)-0600152E-A	
Sep., 2004	IB(NA)-0600152E-B	
3ep., 2004	IB(NA)-0000 132E-B	Addition
		Three phase 400V power input specification,
		single phase 200V power input specification, single phase 100V power input specification
Jun., 2007	IB(NA)-0600152E-C	
00111., 2007	15(14) () 0000 1022 0	Addition
		Precautions for maintenance/inspection Partical review
		* Faltical leview