PROFINETProjekt / PLC_1 [CPU 1214C DC/DC/DC] / Program blocks

Main [OB1]

| Main Properties							
General							
Name	Main	**Number**	1	**Type**	OB	**Language**	LAD
Numbering	Automatic						
Information							
Title	"Main Program Sweep (Cycle)"	**Author**		**Comment**		**Family**	
Version	0.1	**User-defined ID**					

Main					
Name	**Data type**	**Default value**		**Supervision**	**Comment**
▼ Input					
Initial_Call	Bool				Initial call of this OB
Remanence	Bool				=True, if remanent data are available
Temp					
Constant					

Network 1:


```
        %M50.7                                    %M20.0
      "Clock_0.5Hz"                                "Tag_1"
        ─┤ ├─                                      ─( )─

        %M20.0                                     %Q0.0
        "Tag_1"                                    "Tag_2"
        ─┤ ├─                                      ─( )─
```

Network 2:


```
                              %DB1
                             "PUT_DB"
                               PUT
                         Remote - Variant
               EN                        ENO
        %M50.3
       "Clock_2Hz" ── REQ               DONE ── ...
       W#16#100 ──── ID                 ERROR ── ...
      P#M20.0 BOOL 1 ─ ADDR_1          STATUS ── ...
      P#M20.0 BOOL 1 ─ SD_1
```