

Representation on the Further Environmental Information

For the attention of: Mr James Dalgleish, Principal Planning Officer, Rossendale Borough Council
(planning@rossendalebc.gov.uk)

And of: Development Management, Rochdale Borough Council (development.management@rochdale.gov.uk)

Copied to: Planning Casework Unit, Ministry of Housing, Communities and Local Government
(pcu@communities.gov.uk)

Application: Construction and operation of up to 12 wind turbines with a maximum height to the tip of the blade of 180 metres (above ground level), with associated infrastructure, land at and adjacent to Scout Moor Wind Farm, Rossendale and Rochdale (Further Environmental Information)

References: Rossendale 2025/0267; Rochdale 25/00680/FUL

From: County Councillor Tom Pickup, Padiham and Burnley West division, Lancashire County Council

Date: 4 October 2026

Capacity and interest. This representation is made in a personal capacity and as the elected member for the division named above. It is not made on behalf of Lancashire County Council. Sixty-three of the settlement points from which turbines of both this scheme and Calderdale Energy Park would theoretically be visible are in Lancashire County Council's area, including places in and around my division.

Status. This is a representation on the Further Environmental Information under regulation 25 of the Town and Country Planning (Environmental Impact Assessment) Regulations 2017, made within the period in the councils' re-consultation letters of 25 September 2026, which ask for comments by 23 October 2026. It maintains my objection of 24 August 2026 as corrected at section 3, and replaces its request for further information with the narrower requests at section 9.

1. Summary

The applicant has done what my objection of 24 August asked for in one respect: it has assessed the cumulative landscape and visual effects of this scheme with Calderdale Energy Park, and it has mapped where the two could be seen together (Figure 11.16). In fact it had done so before I wrote, in documents that were not then public. I correct my objection at section 3.

The assessment that has now been published has four gaps that matter to the decision.

1. **No settlement was selected for the cumulative assessment.** Paragraph 11.549 says the cumulative ZTV "rules out settlements within the assessment". That is true of the fourteen settlements the applicant assessed, all within about 10 km of the site: none of them has theoretical visibility of Calderdale Energy Park. It is not true of the settlements that do. Within the applicant's own 20 km cumulative radius, 69 named settlement points have theoretical visibility of both schemes on my bare-earth model, 62 of them inside the applicant's own "both may be visible" class on Figure 11.16, and none of them is in its receptor list. Across the whole overlap the figures are 206 and 198, 60 of the 198 in Lancashire. These are bare-earth figures at the gazetteer point; section 6.1 says what a surface model does to them.
2. **Its map gives no counts.** Figure 11.16 has no turbine counts, no areas and no settlement list. The applicant's own software, given the same inputs, puts the land seeing both schemes at 685 km²; my model puts it at 699 km². From 47.6 km² of it, all 46 turbines are theoretically visible inside a single photomontage frame.
3. **Its viewpoints miss most of the Lancashire overlap.** Its cumulative viewpoints in Lancashire are in Rossendale, beside the site, and on Pendle Hill. None is in Preston, Hyndburn, South Ribble, Ribble Valley or Chorley, which hold 53 of the 63 Lancashire settlement points in the overlap.
4. **It leaves out the night.** There is no cumulative night-time assessment at all, although both schemes will carry red aviation lights.

The requests at section 9 are specific and modest. Those that bear on the decision: publish the data behind Figure 11.16 or accept mine into the environmental information; select and assess settlement receptors for the cumulative assessment; add five cumulative viewpoints; assess night-time effects together; and consult the Lancashire authorities whose areas are in the overlap. The rest are procedural: publish the councils' own landscape review, confirm the consultation and determination dates, and confirm the route to committee under the National Scheme of Delegation.

2. What has changed since 24 August 2026, in the applicant's words

The Further Environmental Information (FEI) is introduced by a covering letter to each council dated 1 July 2026 (Turley, reference 01137). It makes real improvements and I acknowledge them.

- **Fewer turbines.** "Reduction in turbine numbers from 'up to 17 turbines' to 'up to 12 turbines'. Turbines T2, T5, T12, T13 and T17 have been removed from the Proposed Development." Turbines T11 and T14 are "retained in their original positions" and the other ten "relocated within the Site to respond to environmental constraints and consultation feedback" (covering letter).
- **Dimensions.** "up to 180m to tip height, 150m rotor diameter and a hub height of 105m" (FEI Chapter 4, para 4.143), with "a maximum of 50m micro-siting allowance" (para 4.141).
- **Output.** "a minimum total generation capacity of 68.4MW" (para 4.139); "an output of up to 84 MW" (Chapter 15, para 15.46); "some 9,131,564 megawatt hours (MWh) of zero carbon electricity over its lifetime, sufficient to power 84,552 typical UK homes each year" (para 15.73).
- **Lighting.** "a single 2,000 candela steady red light mounted on the nacelle of eight of the 12 turbines (T1, T4, T7, T10, T11, T14, T15 and T16)" (Chapter 11, para 11.487), with "Automatic dimming to 200 candela" (Chapter 4, para 4.164).
- **Description.** The applicant asked the councils to describe the turbines as 180 metres "(above ground level)" and to add "with micro-siting allowance" (covering letter). The question I raised at section 13 of my objection is answered.
- **Calderdale Energy Park** is now cumulative scheme 23 in Chapter 16, Table 16.1, at "14.4km North East", with a cumulative data cut-off of "April 2026" (para 16.35; Chapter 11 para 11.37 gives "15 April 2026").

3. Corrections to my objection of 24 August 2026

3.1 My objection said that no assessment of this scheme together with Calderdale Energy Park existed. That was wrong. The applicant had already prepared one. Its Further Environmental Information, sent to both councils under a covering letter of 1 July 2026 and supplemented on 12 August 2026, contains a written cumulative assessment of Calderdale Energy Park (Chapter 11, paragraphs 11.40 and 11.531 to 11.577) and a cumulative zone of theoretical visibility (Figure 11.16, dated May 2026), and lists Calderdale Energy Park in Chapter 16 (submitted on 12 August) as cumulative scheme 23. The same submission reduced the scheme from 17 turbines to 12 and corrected the description to "above ground level". My objection described the superseded scheme.

3.2 None of these documents was public when I wrote. By my count on 20 August 2026 the Rossendale portal listed 333 documents, which is the number now shown with dates on or before 8 July 2026, none of them part of the Further Environmental Information. On 4 September 2026 the case officer wrote to me that "the LPAs will be carrying out a further public re-consultation in due course on a new set of documentation (Further Environmental Information) from the applicant ... Once that consultation is live, you will be able to view the documents that they refer to below, on our website." The re-consultation letters are dated 25 September 2026 and the portal gives 28 September 2026 as the consultation date. I should have written that no assessment had been published, not that none existed. I ask the councils to confirm the date on which each part of the Further Environmental Information was made available for public inspection, because the portal's "Date Published" column shows earlier dates and because the period for comment depends on it.

3.3 I also said that no independent review of the landscape and visual chapter had been commissioned. That was wrong. The applicant records that LUC reviewed it for both councils, in a draft report dated 10 February 2026 (FEI

Appendix 2.4; Chapter 11 paragraph 11.8 gives January 2026), and found it "fit for purpose and complete enough to support an informed planning decision, subject to the following clarifications". That review is not on the public file. It predates Calderdale Energy Park's preliminary environmental information of April 2026, so it could not have considered it. I ask the councils to publish it.

3.4 Four smaller corrections. (a) The 560 km² I described as having both schemes "inside a single photomontage frame" measured the angle between the centres of the two arrays; requiring every turbine of both schemes to fit within one 53.5 degree frame gives 492.6 km². (b) Appendix B listed cities, towns, villages and suburban areas, not "every populated place"; 27 hamlets and 4 other settlements were omitted. (c) The section 35 direction for Calderdale Energy Park is dated 23 April 2025, on a request of 1 April 2025; 19 March 2026, the date I gave, is when the Planning Inspectorate published it. (d) I said my disagreement with Calderdale's Table 12-9 at Hapton, Altham, Higham, Rishton and Huncoat could not be resolved from the published documents. Calderdale's own blade tip map, PEIR Figure 12-5-1, shows 22 to 28 or 29 to 34 turbines theoretically visible at all five, as my model does; it is the table's text that departs from the developer's own map. (e) My objection said that "the entire adverse planning weight" in the applicant's own summary sat in landscape and visual effects; the table above that sentence listed buried archaeology as significant in part, so "almost the entire" was the right phrase. The remaining corrections, to Appendix A, are listed in Appendix A to this representation.

3.5 What does not change. The cumulative assessment the applicant has now published contains no turbine counts, no areas and no settlement list. The applicant's own software, given the same inputs, puts the land seeing both schemes at 685 km², against my 699 km², and removing five turbines changed that area by 0.3 per cent. The questions in section 9 below rest on the applicant's own documents as they now stand.

4. The applicant's cumulative assessment, in its own words

Why Calderdale is in. "In Scenario 3 there is only one cumulative scheme; Calderdale Wind Farm. In April 2026, a Preliminary Environmental Assessment Report (PEIR) which illustrated 34 turbines at a tip height of up to 200m, approximately 15km away. Whilst this is not the final proposed scheme, there is sufficient information to consider the potential cumulative effects, and this scheme has the potential to be seen in combination/successive views and sequentially with the Project for Assessment which could potentially result in significant cumulative effects." (para 11.40)

The radius. "Following a review of the cumulative search area, it was stated at EIA Scoping that the potential for significant cumulative effects would be contained within a 20km radius." (para 11.37) The scoping report went to the councils on 16 December 2024 (para 11.9), before Calderdale Energy Park's request for a section 35 direction (1 April 2025).

The extent. "As illustrated on Figure 11.16, Calderdale is located approximately 15km northeast of the Project for Assessment and there are very few areas of intervisibility that coincide with landscape and visual receptors." (para 11.533)

Settlements. "The visual receptor groups focus on areas where there could be intervisibility of the Project for Assessment and Calderdale. As illustrated in the cumulative ZTV (Figure 11.16), this rules out settlements within the assessment." (para 11.549)

The Pennine routes. Paragraph 11.557, headed for users of the Pennine Bridleway, finds "a likely significant effect locally to each of the two proposals" and says these "would mainly occur as a result of the projects individually and sequentially, rather than simultaneously from any sections". Paragraph 11.559 concludes that the combined effect "would result in two sequential Significant effects local to each proposed site on parts of the Pennine Way". (Paragraphs 11.558 and 11.559 refer to the Pennine Way under a heading and paragraph about the Pennine Bridleway; the applicant should say which route is meant.)

The conclusion. "Cumulative interactions with Calderdale Wind Farm would only affect a limited number of landscape and visual receptors located on the highest ground with potential cumulative intervisibility. The cumulative assessment with Calderdale Wind Farm found that the additional change brought about by the addition of the Project

for Assessment to a baseline of the operational, consented and Calderdale schemes would be no greater in the level of effect, than was assessed in the main assessment (for the Project for Assessment in isolation) for those few receptors located on high ground." (para 11.577)

5. What the applicant's map shows when it is counted

My model uses the same inputs the applicant states for Figure 11.16: OS Terrain 50, an observer eye height of 2 metres, blade tip, Earth curvature and light refraction, and the Calderdale layout of the PEIR of April 2026. It adds what the figure leaves out: how many turbines, over how much land, and from which named places. The method, the code and every output are at Appendix A.

All figures below are bare earth, with no screening by buildings, walls, hedges or woodland; a single visible blade tip counts as visible; eye height 2.0 m, refraction coefficient 0.075; visibility computed to 45 km from each turbine; Scout Moor II positions carry a 50 metre micro-siting allowance; Calderdale Energy Park positions are those of its PEIR of April 2026 and are not fixed. They are theoretical maxima, not what a person would see on a given day.

Measure, 12 + 34 turbines	Result
Land with theoretical visibility of turbines of both schemes	698.9 km² (685.4 km² in the applicant's own software)
of which every turbine of both schemes fits inside one 53.5 degree photomontage frame	490.5 km²
of which every turbine of both schemes is theoretically visible and fits inside one frame	47.6 km²
Land seeing at least ten turbines of each scheme	283.1 km²
Most turbines theoretically visible from a single point	46 of 46
Named settlement points in the overlap, at the gazetteer point	206, of which 63 in Lancashire
of which inside the applicant's own "both may be visible" class on Figure 11.16	198, of which 60 in Lancashire
of which within 20 km of the nearest Scout Moor II turbine (the applicant's cumulative radius)	69, of which 62 in the applicant's class and 18 in Lancashire

The applicant's map and mine describe the same overlap. Where both models compute, within 45 km of both schemes, the applicant's "both may be visible" class covers 702.6 km² and mine 698.3 km²; 94 per cent of mine lies inside theirs and 93 per cent of theirs inside mine (Appendix C). Over its whole extent the applicant's class is larger, at least 1,394.8 km², because its Calderdale calculation runs well beyond 45 km.

The applicant's own software gives the same answer. Figure 11.16 was made with the Viewshed routine of the Visibility Analysis plugin for QGIS. I rebuilt the overlap in that software with the same inputs: 685.4 km², 1.9 per cent below my figure, with the two maps agreeing over 94 per cent of their combined area. The small difference comes mainly from how each method decides whether a 50 metre cell is visible, which Appendix A sets out.

Removing five turbines barely changed the overlap. Under the same method the 17-turbine scheme gave 700.8 km² and the 12-turbine scheme gives 698.9 km², a change of 0.3 per cent: 8.8 km² left the overlap, 6.9 km² entered it and 692.0 km² is common to both. The combined view is set by the terrain and the separation of the two sites, not by the number of turbines.

Hub height. With Scout Moor II at its 105 metre hub and Calderdale at blade tip, 557.6 km² would see both, and 165 settlement points.

With the existing wind farm. The applicant intends this scheme to be "completed and operational in 2030" (Chapter 4, para 4.135) and gives July 2033 for decommissioning the existing Scout Moor wind farm (Chapter 16, Table 16.1). Modelling the 26 existing turbines at 100 metres from their mapped positions, up to 72 turbines of the three schemes would be theoretically visible from a single point in that period, and 526.5 km² would see all three.

6. Where the applicant's conclusion does not follow from its own evidence

6.1 *No settlement receptor was selected for the cumulative assessment*

Paragraph 11.549 says that Figure 11.16 "rules out settlements within the assessment". That is true of the settlements the applicant assessed. Its fourteen settlement receptor groups, from Norden and Wolstenholme to Bury and Tottington, were chosen for the main assessment and lie within about 10 km of the site (para 11.288). On the applicant's map and on my model, none of them has theoretical visibility of Calderdale Energy Park. Figure 11.16 rules them out because they were never candidates.

It is not true of the settlements that do have it. Within the applicant's own 20 km cumulative radius (para 11.37), 69 named settlement points have theoretical visibility of turbines of both schemes on my bare-earth model, 62 of them inside the applicant's own "both may be visible" class, and not one of them is a receptor in its assessment: Shaw Side, Royton Moss and Oldham Edge in Oldham; Rishton, Great Harwood, Cliffe, Higham, Fence and Wheatley Lane in Lancashire; Revidge, Four Lane Ends and Royshaw Hill in Blackburn. Across the whole overlap the figures are 206 and 198 settlement points. The ten with the most turbines theoretically visible are Revidge, Four Lane Ends, Newchurch in Pendle and Old Town (45 of 46) and Cumeragh Village, Oldham Edge, Acre, Broadbent, Royshaw Hill and Cliffe (44); all ten are in the applicant's green class. In Lancashire the highest are Newchurch in Pendle (12 Scout Moor II and 33 Calderdale turbines), Cliffe (10 and 34), Cumeragh Village (10 and 34), Grimsargh (9 and 34) and Cow Hill (10 and 32). The list is at Appendix B.

These are bare-earth counts at the gazetteer point, on the same basis as the applicant's own Figure 11.16, and they are maxima. The applicant's screened ZTVs for the scheme alone (Figures 11.7 and 11.8) model buildings at 7.5 m and woodland at 10 m and leave out "small copses, hedgerows or individual trees"; no screened cumulative map was produced. I tested what buildings and trees do to them with the Environment Agency's LIDAR surface model (Appendix A, section A6). At the gazetteer point itself, which usually sits in a street, the surface model removes the combined view at 49 of the 51 highest-scoring settlements. Within 100 metres of the point, on open ground, a recreation ground or a higher street, 17 of the 51 keep a view of both schemes, 14 of them with twenty or more turbines in it: Four Lane Ends, Royshaw Hill, Cliffe, Edge End, New Town, Whittingham, Newchurch in Pendle, Knowle Green, Blacko, Fence, Wheatley Lane, Beverley, Haggate and Old Town. The question is therefore not whether every resident of every one of the 206 places would see both wind farms. It is why the applicant's cumulative visual assessment contains no settlement receptor at all when, by its own map, the open ground at the edge of these places is where both schemes would be seen together.

6.2 *The cumulative viewpoints miss most of the Lancashire overlap*

The applicant names Viewpoints 1, 17, 18, 22 and 23 as those where Calderdale is theoretically visible (para 11.534), and mentions 24 and 25. My model agrees: Calderdale turbines are visible at exactly those seven and no others, and four at Viewpoint 17, as the applicant says (para 11.546). Two of them, 17 (Peel Tower) and 18 (Bulls Hill), hold every turbine of both schemes inside one 53.5 degree frame.

Three are in Lancashire: 18 (Bulls Hill) and 25 (above the site), both in Rossendale, and 24 (Pendle Hill). Viewpoint 24 is the only one in the Forest of Bowland National Landscape; there, by my count, the two arrays span 62.9 degrees and do not fit one frame. There is none in Preston, Hyndburn, South Ribble, Ribble Valley or Chorley, which hold 53 of the 63 Lancashire settlement points in the overlap. For the Forest of Bowland the applicant concludes that cumulative interactions "would be limited by distance and very limited intervisibility" (para 11.564); proposed viewpoints A and E below are both inside the National Landscape, and from each all 46 turbines are theoretically visible inside one frame.

I propose five additional cumulative viewpoints, chosen by a stated rule (public access land or a National Trail; every turbine of both schemes inside one 53.5 degree frame where possible; the most turbines visible; spread across different National Character Areas and at least 8 km apart) and then checked against the Environment Agency's LIDAR surface model so that none is proposed from behind a wood (Appendix A, section A6):

	Grid reference	Location	Scout Moor II	Calderdale
A	SD 64975 39375	Access land on Longridge Fell, 1.4 km from Knowle Green, Lancashire; Forest of Bowland National Landscape	12	34
B	SD 95425 21475	Pennine Way near Warland, between the two schemes (successive view)	12	34
C	SE 00075 02875	Access land above Waterside, Oldham (Dark Peak character area)	12	34
D	SD 92725 45275	Access land in North Yorkshire, 1.9 km from Green End, Earby (Lancashire)	12	34
E	SD 72375 47425	Access land near Harrop Fold, Lancashire; Forest of Bowland National Landscape	12	34

From each, all 46 turbines are theoretically visible on bare earth, and all 46 remain visible on the surface model at A, B, C and D (45 at E); from A, C, D and E they fall inside a single 53.5 degree frame. From B, on the Pennine Way between the schemes, they cannot: there the applicant's point about sequential effects (para 11.557) is right, and the viewpoint would show it. Exact positions should be agreed on site with both councils.

6.3 A 20 km radius for a scheme seen from 30 km

Paragraph 11.37 keeps the 20 km cumulative radius stated at scoping in December 2024. On my figures, 479.8 km² of the 698.9 km² overlap, more than two thirds, lies over 20 km from the nearest Scout Moor II turbine. The applicant's own Figure 11.16, over the same area within 45 km of both schemes, puts 495.9 km² of its "both may be visible" class beyond 20 km, west across Lancashire to Preston and south across Greater Manchester. The applicant says its cumulative assessment "follows NatureScot guidance (2021)" (para 11.36). That guidance says that "for the current generation of turbine size, the study area should extend to a minimum of 35km from the outer margin of the wind farm in question, though this may need to be increased for larger turbines", with a search area of up to 60 km, and that the area "should not be limited by local authority boundaries". Chapter 16 itself searched to 45 km (para 16.37). The radius should follow the guidance the applicant cites and the evidence on its own map.

6.4 The combined effects are hedged, not assessed

Paragraph 11.577 reports that "the additional change brought about by the addition of the Project for Assessment" to a baseline that already includes Calderdale "would be no greater in the level of effect" than the scheme alone. That is the primary test the guidance asks for, and I do not criticise its use. GLVIA3 also recognises combined, or total, cumulative effects (paragraph 7.18, as the Landscape Institute's 2024 clarification note records), and the applicant says it considered them "where relevant and there is a noted difference" (para 11.531). Where it did, it reported a possibility rather than a finding. On the Rossendale Hills the combined effect "could be greater due to the influence of Calderdale as a new notable cluster ... but the combined effect might still remain Major/Moderate and Significant" (para 11.544). On the Forest of Bowland it "could be greater than the additional change noted above ... the combined effect is unlikely to be Significant" (para 11.566). On the Pennine Way it "would result in two sequential Significant effects local to each proposed site" (para 11.559). Paragraph 11.577 sums these up as "potential for any notable

increases in effect" on two landscape character areas and the Pennine Bridleway. Where the scheme alone is already Major adverse, the top of the applicant's scale, the additional-change test can only confirm it; the combined effect is where the two schemes together can be weighed, and at each of these receptors it has been noted rather than rated. Those are the findings the councils need, and they should be assessed.

6.5 No cumulative night-time assessment

The FEI's cumulative lighting assessment considers only existing turbines: "there are no existing turbines within 20km of the Project for Assessment which have visible aviation lights fitted" (para 11.492). Calderdale Energy Park's turbines will carry them: "there is a requirement for the turbines to display medium intensity 'steady' red aviation lights at night" (Calderdale PEIR, Chapter 12, para 12.4.45; the same paragraph says Calderdale is "seeking to agree a reduced aviation lighting scheme with the CAA", as this applicant has). The cumulative assessment of Calderdale at paragraphs 11.531 to 11.566 does not mention lighting or night. For this scheme alone the applicant finds that "Significant impacts identified at night would be limited to residents in the communities of Catley Lane Head and Whitworth where Major / Moderate adverse effects would occur at night", with "Moderate and Significant effects" at other places (para 11.576). The combined night-time view has not been assessed by either applicant.

6.6 Calderdale's settlement table should not be relied on to the west

The applicant's Figure 11.16 rests on Calderdale's published layout, not on Calderdale's settlement table, but the councils and consultees may read both. At Hapton, Altham, Higham, Rishton and Huncoat, Calderdale's PEIR Table 12-9 gives up to 14 or up to 21 turbines, while Calderdale's own blade tip map, PEIR Figure 12-5-1, shows 22 to 28 or 29 to 34 at the same places, as my model does (Higham sits at the edge of a class on that map and is the least certain of the five). The same is true at Read, Simonstone, Fence and Wheatley Lane. In the direction of Lancashire, Calderdale's table understates its own map.

7. Policy and law

Development plan. Rossendale Local Plan Policy ENV7 requires that a wind proposal "would not result in unacceptable visual clutter in combination with other existing structures, with cumulative impacts fully assessed to the satisfaction of the Council", and paragraph 262 explains that "In parts of the Borough there has been cumulative visual impact, including with adjacent schemes outside Rossendale." In Rochdale, Places for Everyone Policy JP-G1 asks development to respond to "Views and perceptual qualities", and Core Strategy Policy P2 is the landscape policy weighed in the 2017 decision on this moor. Both councils' own newspaper notices advertise the application as a departure: Rossendale's says "The application would not accord with the provisions of the development plan" and Rochdale's gives "Departure from the Development Plan" as a reason for the notice. A cumulative assessment that excludes settlements and the Lancashire side of the overlap is not one either council can be "fully" satisfied with.

National policy, stated fairly. The National Planning Policy Framework of 17 August 2026 gives "substantial weight" to the benefits of renewable energy (Policy W3), does not require need to be shown (W3(2)), and says that development plan policies "materially inconsistent with national decision-making policies in this Framework should be given very limited weight" (Annex A, para 2). I accept that the community-backing and suitable-area elements of the 2015 Written Ministerial Statement now carry little or no weight. The cumulative criterion of ENV7 is a different matter. It asks for an assessment, not for a particular outcome, and an assessment is what regulation 26(1) and Policy N2 also require: N2 asks decision-makers to "Consider the environmental qualities of land proposed for development, including habitats, landscape character and the natural beauty of the countryside". A policy that asks for a cumulative assessment cannot be materially inconsistent with a Framework that asks for one too.

Regulation 26(2). Neither council may grant permission unless satisfied that its reasoned conclusion "is up to date". Calderdale Energy Park's statutory consultation closed on 8 July 2026 and its application for development consent is expected in November 2026, with a layout that may differ from the PEIR the applicant assessed (para 11.40: "this is not the final proposed scheme"). The councils should say how they will keep the reasoned conclusion up to date if the Calderdale layout changes before determination.

Regulation 25(7). Where further information is provided, the authority "must not determine it before the expiry of 30 days after the latest of" the dates on which it was sent to consultees, notice was published in a local newspaper, or notice was published on a website. Rossendale's newspaper notice appeared in the Rossendale Free Press on 2 October 2026 (dated 2 October, signed by the Planning Manager) and invites representations "within 30 days of the date of this notice", that is until 1 November 2026. Rochdale's notice appeared in the Rochdale Observer on 23 September 2026 (dated 17 September) and invites representations "within 30 days of the date of this publication by: 22nd October 2026". The councils' re-consultation letters of 25 September and the Rossendale portal give 23 October. Three different closing dates are therefore in circulation. On the newspaper notices, Rossendale cannot lawfully determine its application before 2 November 2026 and must accept representations until 1 November; Rochdale's 30 days run to 23 October. I ask both councils to confirm that representations received by 1 November 2026 will be considered on both files, and I support the Rooley Moor Neighbourhood Forum's request that the councils confirm the dates from which each period runs.

Regulation 63. My objection asked what screening under regulation 63(1) of the Conservation of Habitats and Species Regulations 2017 (as amended) had been carried out, and whether Calderdale Energy Park, which lies on Walshaw Moor within the South Pennine Moors Special Area of Conservation, was among the plans and projects considered in combination. No answer is yet on the public file. I repeat the question; I do not assert a likely significant effect.

The 2017 decision. On 6 July 2017 the Secretary of State refused the Rossendale part of a 16-turbine, 115 metre extension to this wind farm, agreeing that "the overall benefits of the scheme would not be sufficient to also outweigh the harm identified to the character and appearance of the area". The policy context has changed since, and I do not suggest the outcome would be the same. The decision shows that cumulative landscape harm on this moor has been decided at Secretary of State level before.

8. The decision route

The National Scheme of Delegation (Town and Country Planning (Discharge of Local Planning Authority Functions) (England) Regulations 2026, SI 2026/854) comes into force on 31 October 2026, as the Rooley Moor Neighbourhood Forum's letter of 25 September 2026 notes. The regulations contain no transitional provision for applications already made. Unless this application is determined before 31 October, it will be determined under the scheme. For Rossendale, regulation 25(7) prevents determination before 2 November; Rochdale's 30 days expire on 23 October, so its half of the scheme could in principle be decided in the last week of October under the present arrangements, which would separate the two decisions. It is a Schedule 2 application (Schedule 2, paragraph 4: an application for planning permission that is not a householder, minor commercial or minor residential application). Under regulation 5 such an application "must be determined by an officer" unless the council's nominated member and nominated officer "agree to refer" it to committee because in their view it raises "one or more issues of economic, social or environmental significance to the local area" or "one or more significant planning matters". An application of this scale, with maintained objections from NATS and Manchester Airport (29 September 2026) and a significant residual landscape effect on the applicant's own case, plainly does, and each council is asked to confirm that its nominated member and officer will so agree, and to name them. The Planning Casework Unit told Rossendale on 29 September 2025 that a decision on call-in would be made once "the recommendation and committee report has been received and reviewed"; a delegated decision would bypass that.

9. Requests

A. Requests that bear on the decision

1. **Figure 11.16's data.** Require the applicant to publish the data behind Figure 11.16 (the number of turbines of each scheme theoretically visible in each cell, and a list of the settlements in the "both may be visible" class), or accept the analysis at Appendices A to C into the environmental information as a representation duly made under regulation 2(1).

2. **Settlements.** Require the applicant to select settlement receptors for the cumulative visual assessment from its own "both may be visible" class on Figure 11.16, within its 20 km radius at least, and to assess them with the screened method it used for its main assessment; paragraph 11.549 should then be rewritten to say what was assessed.
3. **Viewpoints.** Require cumulative wirelines, at least, from the five locations at section 6.2, agreed with both councils and published before determination.
4. **Night-time.** Require a cumulative night-time assessment of this scheme with Calderdale Energy Park.
5. **Neighbouring authorities.** Consult the authorities whose areas contain settlements in the overlap (Appendix B) and which do not appear among the responses on the file, in particular Preston City Council (33 of the 63 Lancashire settlement points), Pendle, South Ribble and Ribble Valley Borough Councils, and Blackburn with Darwen Borough Council. Hyndburn (11 points) and Burnley have already responded and are not repeated here.

B. Procedural requests

6. **The councils' landscape review.** Publish LUC's review of the landscape and visual assessment (draft of 10 February 2026) and LUC's scoping comments of 7 May 2025, and say whether LUC has been asked to review the FEI's cumulative assessment.
7. **Dates.** Confirm the date each part of the FEI was made available for public inspection; the date the regulation 25(3) website notice was published by each council; the earliest date on which each council can determine under regulation 25(7); and that representations received by 1 November 2026, the date in Rossendale's newspaper notice, will be considered on both files.
8. **Regulation 26(2).** Say how the reasoned conclusion will be kept up to date against the Calderdale Energy Park timetable.
9. **Regulation 63.** Say what screening has been carried out and whether Calderdale Energy Park was considered in combination.
10. **Committee.** Confirm that the application will be reported to committee whichever delegation scheme applies; if it falls under SI 2026/854, name the nominated member and nominated officer and confirm that they will agree to refer it under regulation 5(3); and record my request to speak.
11. **Rochdale.** Log this representation on 25/00680/FUL; the Rochdale portal could not be reached from my address when this was written.

This representation is copied to the Planning Casework Unit because the adequacy of the environmental information bears on any decision about call-in, and because the Unit has already asked to be kept informed of this application.

I would be glad to provide the data, code and full-resolution figures to officers and consultees.

Yours sincerely

County Councillor Tom Pickup Padiham and Burnley West division Lancashire County Council


Enclosures

- Figure 1: cumulative zone of theoretical visibility, 12 + 34 turbines
- Figure 2: change in the overlap from 17 to 12 turbines
- Appendix A: method, the 17-turbine and 12-turbine results, the reproduction in the applicant's software, the surface-model screening test, and corrections to Appendix A of 24 August 2026
- Appendix B: settlements in the overlap, 17-turbine and 12-turbine counts side by side (bare earth, at the gazetteer point)
- Appendix C: comparison with the applicant's Figure 11.16

Figure 1

699 km² of land would theoretically see turbines of both schemes

Figure 1. Cumulative zone of theoretical visibility, Scout Moor II as revised (12 turbines) with Calderdale Energy Park (34)




Combined count = Scout Moor II turbines + Calderdale turbines whose blade tips are theoretically visible from a 50 m cell (maximum 46).
Visibility is computed to 45 km from each turbine; the straight-edged arcs to the west and south west are that limit, not terrain. Beyond it the overlap is not counted, so these figures are a floor.
Bare earth: no screening by buildings or vegetation. A single blade tip counts as visible. Eye height 2 m, refraction $k = 0.075$, 45 km from each turbine. Scout Moor II positions carry a 50 m micro-siting allowance; Calderdale positions are the PEIR layout of 7 April 2026 and are not fixed.
Source: Tom Pickup's model, after Scout Moor II FEI Chapter 4 Table 4.1 (1 July 2026) and Calderdale Energy Park PEIR Table 4-1 (7 April 2026).
Contains OS data © Crown copyright and database right 2026 (OS Terrain 50, OS Open Names).

Cumulative zone of theoretical visibility, Scout Moor II as revised (12 turbines) with Calderdale Energy Park (34). 698.9 km² sees turbines of both schemes; 685.4 km² in the applicant's own software (Appendix A, A4). Bare earth, blade tip, eye height 2 m, $k = 0.075$, 45 km. Contains OS data © Crown copyright and database right 2026.

Figure 2

Removing five turbines changed the shared view by 1.9 km² of 701 km²

Figure 2. Land seeing both schemes: the 17-turbine layout (v1r) against the 12-turbine layout (v2), with Calderdale Energy Park unchanged




v1r is the 17-turbine layout of the 2025 Environmental Statement with ground levels under the round-two rule (bilinear OS Terrain 50); v2 is FEI Chapter 4 Table 4.1.
Visibility is computed to 45 km from each turbine; the straight-edged arcs to the west and south west are that limit, not terrain. Beyond it the overlap is not counted, so these figures are a floor.
Bare earth: no screening by buildings or vegetation. A single blade tip counts as visible. Eye height 2 m, refraction $k = 0.075$, 45 km from each turbine. Scout Moor II positions carry a 50 m micro-siting allowance; Calderdale positions are the PEIR layout of 7 April 2026 and are not fixed.
Source: Tom Pickup's model, after Scout Moor II FEI Chapter 4 Table 4.1 (1 July 2026) and Calderdale Energy Park PEIR Table 4-1 (7 April 2026).
Contains OS data © Crown copyright and database right 2026 (OS Terrain 50, OS Open Names).

Change in the overlap from 17 to 12 turbines, under the same method: 8.8 km² left, 6.9 km² entered, 692.0 km² common to both.

Figure 3

Scout Moor II and Calderdale Energy Park: where both may be seen, applicant's Figure 11.16 against our model

Within 45 km of the nearest Scout Moor II turbine, on land inside the applicant's map: applicant 1188 km², ours 699 km², overlap 657 km², IoU 0.53; 94% of ours lies inside theirs and 55% of theirs inside ours. Where both models compute (within 45 km of both schemes): IoU 0.88.



Contains OS data (c) Crown copyright and database right 2026. Applicant layer: Scout Moor II FEI Figure 11.16 (Stephenson Halliday, May 2026), classified from the raster PDF and georeferenced on the 1 km grid. Caveat: the applicant's map plots 65 Calderdale turbine positions; our model uses the 34 in PER Table 4-1. Our model: 50 m grid, eye 2 m, k 0.075, blade tip, 45 km per turbine.

The applicant's Figure 11.16 'both may be visible' class on the 50 m grid (left), this model (centre), and where they agree (right). Where both models compute, intersection over union 0.88.

Appendix A (round two). Method, results, reproduction and corrections

4 October 2026. Accompanies the representation on the Further Environmental Information, Rossendale 2025/0267 and Rochdale 25/00680/FUL. It replaces Appendix A of 24 August 2026 for the revised scheme and records the corrections to that appendix.

Every figure here is bare earth, with no screening by buildings, walls, hedges or woodland; a single visible blade tip counts as visible; observer eye height 2.0 m; refraction coefficient $k = 0.075$; visibility computed to 45 km from each turbine. Scout Moor II positions carry a 50 m micro-siting allowance (FEI Chapter 4, para 4.141). Calderdale Energy Park positions are those of its PEIR Table 4-1 (April 2026) and are not fixed.

A1. Inputs and settings

Item	Value
Terrain	OS Terrain 50, edition of 29 May 2026, 50 m cells, no resampling
Grid	112 km by 112 km, EPSG:27700, 2,240 by 2,240 cells
Observer	2.0 m above ground
Curvature and refraction	apparent drop $d^2 (1 \text{ minus } k) / 2R$, $k = 0.075$, $R = 6,371,000 \text{ m}$ (147 m at 45 km)
Radius	45 km from each turbine
Basis	blade tip; hub height also reported
Rays	7,200 per turbine; a 50 m cell counts as visible if any ray sample inside it sees a tip
Settlements	OS Open Names, types City, Town, Village and Suburban Area, at the gazetteer point

The same settings as the applicant's Figure 11.16, whose legend gives OS Terrain 50, a viewer eye height of 2 m, Earth curvature and light refraction, and blade tip.

A2. Layouts and the ground-level rule

Name	Scout Moor II	Calderdale Energy Park	Ground levels
v1	17 turbines, 2025 ES Chapter 4 Table 4.1	34 turbines, PEIR Table 4-1	as used on 24 August 2026
v1r	the same 17	the same 34	one rule for both schemes
v2	12 turbines, FEI Chapter 4 Table 4.1	the same 34	one rule for both schemes

All 12 FEI positions were checked line by line against FEI Table 4.1. The rule: ground level at each turbine is bilinear interpolation of OS Terrain 50 at the turbine coordinate. Checked against Calderdale's own published foundation levels, it agrees within 0.95 m at all 34 turbines. The Scout Moor II ground levels used on 24 August matched no single rule and their derivation was not recorded; under the rule the 24 August overlap moves from 702.3 km² to 700.8 km². The figures published on 24 August stand as published; v2 is compared with v1r so that like is compared with like.

A3. Results

Measure	v1, as published	v1r	v2
Sees Scout Moor II (km ²)	2,577.8	2,577.5	2,561.8
Sees Calderdale (km ²)	2,107.3	2,105.0	2,105.0
Sees both (km ²)	702.3	700.8	698.9
Both, centres of the two arrays within 53.5 degrees (km ²)	560.0	558.8	557.5
Both, every turbine of both within 53.5 degrees (km ²)	492.6	491.4	490.5
At least 10 of each (km ²)	371.4	371.3	283.1
Most turbines visible from one cell	51 of 51	51 of 51	46 of 46
Settlement points in the overlap (Lancashire)	205 (62)	204 (62)	206 (63)

From v1r to v2, 8.8 km² left the overlap, 6.9 km² entered it and 692.0 km² is common to both: a net change of 0.3 per cent. The thresholded areas fall more, partly because ten of 12 is a stricter bar than ten of 17. The two frame rows are different measures: 490.5 km² is where every turbine of both schemes falls inside one 53.5 degree frame whether or not each is visible; from 47.6 km² of the v2 overlap all 46 turbines are theoretically visible inside one frame.

Hub height: with Scout Moor II at its 105 m hub and Calderdale at blade tip, 557.6 km² sees both, and 165 settlement points.

With the existing Scout Moor wind farm (26 turbines, 100 m to tip, positions from OpenStreetMap, ODbL), between 2030 and its decommissioning in July 2033 up to 72 turbines would be theoretically visible from one cell, and 526.5 km² would see all three schemes.

A4. The cell rule, and reproduction in the applicant's software

The 24 August method did not state how ray samples become cells. A cell counts as visible if any sample inside it sees a tip. With one sight line per cell (the sample nearest the cell centre) the v2 overlap is 664.4 km²; if every sample in the cell must see a tip, 630.1 km².

The applicant's Figure 11.16 was made with the Viewshed routine of the Visibility Analysis plugin for QGIS. The v2 overlap was rebuilt in that software (QGIS 4.2.3, plugin version 1.9.3, binary viewshed, curvature on, refraction 0.075, counts combined by addition, the same terrain and turbines):

Measure (km ²)	This model	QGIS, plugin's own ground rule	QGIS, ground levels as this model
Sees Scout Moor II	2,561.8	2,538.2	2,537.5
Sees Calderdale	2,105.0	2,065.1	2,064.7
Sees both	698.9	685.2	685.4
At least 10 of each	283.1	281.6	282.7
Most turbines visible from one cell	46	46	46

The two overlaps agree over 94 per cent of their combined area (intersection over union 0.936). The applicant's software sits inside the range set by the cell rule.

A5. Checks against the applicants' own figures

Scout Moor II viewpoints. The FEI visualisation sheets give the number of Scout Moor II blade tips and hubs visible at each of the 25 viewpoints. This model gives the same tip count at 23 of 25 and the same hub count at 21 of 25. Calderdale turbines are visible in this model at exactly the seven viewpoints the applicant names (1, 17, 18, 22, 23, 24, 25) and at no other; at Viewpoint 17 the count is four, and the applicant's para 11.546 says "four distant blade tips".

Calderdale PEIR Table 12-9. At all 22 settlements the table records as having no theoretical visibility, and which are in the national gazetteer, this model returns zero.

Calderdale PEIR Figure 12-5-1. Calderdale's own blade tip ZTV was georeferenced on the OS 1 km grid (RMS 11.6 m). Its classes agree with this model, not with Table 12-9's text, at Hapton and Altham (22 to 28 turbines; table "up to 14"), Higham (29 to 34; table "up to 14 turbines theoretically visible from the eastern edge"), and Rishton and Huncoat (29 to 34; table "up to 21"). All 22 zero settlements are unfilled on the map. Three points read lower on the map than in this model, each near a class edge: Slack, Stanbury and Heptonstall.

A6. Screening test: what buildings and trees do to the settlement counts

Every settlement count in this appendix and in Appendix B is bare earth at the OS Open Names gazetteer point, on the same basis as the applicant's Figure 11.16. To test what local surface cover does to them, the 20 settlement points with the highest combined counts and all 42 Lancashire settlement points with a combined count of 20 or more (51 points), the five proposed viewpoints and the applicant's Viewpoint 18 were re-run with the Environment Agency National LIDAR composite first-return surface model (2 m; ground plus buildings and vegetation; surveys 2000 to 2022; Open Government Licence) within 250 m, 500 m and 1,000 m of the observer, and OS Terrain 50 beyond. The observer stands 2 m above the LIDAR terrain model, never on a roof (the surface model is ignored within 5 m of the observer). Each turbine has its own line of sight, sampled every 2 m to the radius and every 50 m beyond, with curvature and refraction as above. The same rays were also run on bare earth, so the effect of surface cover is separated from the effect of finer terrain. Around each settlement point a 3 by 3 grid of observers at 100 m spacing was run at 500 m. Controls were named before the run: Glodwick (Oldham) and Bastwell (Blackburn), whose points sit in terraced streets, fell from 39 and 6 turbines to none; the applicant's Viewpoint 18 on Bulls Hill kept 46 of 46; proposed viewpoint E kept 45 at every radius, and 45 on bare LIDAR terrain too.

Settlement points (51)	250 m	500 m	1,000 m
Still see at least one turbine of each scheme	2	2	1
See both on the same rays with bare earth	48	48	48
See no turbine of either scheme	36	36	38

On the 3 by 3 grid at 500 m, 17 of the 51 settlements (14 of the 42 in Lancashire) have at least one observer within 100 m of the gazetteer point who sees both schemes, and 14 have one with a combined count of 20 or more: Four Lane Ends (44 of 46), Newchurch in Pendle (45), Old Town (43), New Town (44), Edge End (43), Whittingham (43), Cliffe (38), Royshaw Hill (34), Blacko (32), Wheatley Lane (30), Fence (29), Beverley (27), Knowle Green (22) and Haggate (21). Of the proposed viewpoints, B, C and D keep all 46 turbines at every radius and E keeps 45; the first candidate for A (SD 64575 38175) kept only the 12 Scout Moor II turbines, every Calderdale turbine being screened by woodland about 200 m away, and was replaced by the first candidate under the same selection rule that keeps all 46 on the screened surface (pipeline/screen_viewpoint_candidates.py).

The test is a floor, not an estimate: a first-return surface stops a line of sight at any tree crown or chimney, and parts of the composite are over twenty years old. It shows that the gazetteer-point counts should be read as what the open ground at the edge of each place would see, not as what every street would see. The applicant's own settlement assessment uses the same bare-earth ZTVs, with screened ZTVs (Figures 11.7 and 11.8) whose notes say buildings were "modelled with an assumed height of 7.5m and woodland an assumed height of 10m" from OS Open Map Local, and that the model "does not take into account some localised features such as small copses, hedgerows or individual trees and therefore still gives an exaggerated impression of the extent of visibility". The test here uses the measured surface instead, so it sits below the applicant's screened figures as they sit below its bare-earth ones. Script and output:

pipeline/screening_test.py, pipeline/grids/screening_test_v2.json.

A7. Corrections to Appendix A of 24 August 2026

1. The cell rule (A4) was not stated; it moves the overlap by 5 to 10 per cent.
2. "Scout Moor II ... ground levels ... are taken from the terrain model": their derivation was not recorded and matches neither the nearest cell nor bilinear interpolation (A2).
3. The 560 km² and 650 km² field-of-view figures measured the angle between the centres of the two arrays, not whether every turbine fits the frame (A3).
4. The western disagreement with Table 12-9 could be resolved from Calderdale's own Figure 12-5-1 (A5).
5. The hash given for `cumulative_stats.py` was of a version earlier than the one that produced the 53.5 degree, median and 75th percentile figures; the correct first twelve characters are 7d80922cb376.
6. Section A7 described the Rochdale Unitary Development Plan Policy EM/14 as a saved policy. It was deleted and replaced by Core Strategy Policy G3 (Rochdale Core Strategy, October 2016, Appendix 3, Table 7).
7. The published summit heights in A3 were not sourced; the model values (Whernside 736.0 m, Ingleborough 723.3 m, Pendle Hill 555.7 m, Boulsworth Hill 516.4 m, Winter Hill 456.1 m) reproduce.
8. The objection's section 11 said the existing wind farm's 26 turbines, 100 m tip height and 65 MW were "sourced three times over" at ES Table 16.1, the Rossendale committee report of 1 September 2015 para 1.7 and the Inspector's Report para 2. The facts are right; the citations are not: Table 16.1 gives only the count, the committee report gives 65 MW at para 2.1, and the Inspector's Report gives it at para 3.

A8. Reproducing this

```
` python3 -m pipeline.build_ztv --layout v2 python3 -m pipeline.cumulative_stats --layout v2 python3 -m pipeline.settlements --layout v2 python3 -m pipeline.frame_area python3 -m pipeline.screening_test python3 -m pipeline.fig1116_layout_check python3 -m pytest pipeline/tests pipeline/qgis_reproduction/run_qgis_ztv.sh `
```

--layout v1 with the frozen inputs reproduces every figure published on 24 August 2026, including all 205 Appendix B rows; their file hashes are pinned in the tests. The data, code and full-resolution figures are available to officers and consultees on request.

A9. Data sources

OS Terrain 50 and OS Open Names (Ordnance Survey; contains OS data © Crown copyright and database right 2026). EA National LIDAR Programme composite DTM 2 m and first-return DSM 2 m (Environment Agency, OGL; © Environment Agency copyright and/or database right 2022), used in the tests at A5 and A6. CRoW Act 2000 access land, National Trails, National Character Areas and National Landscapes (Natural England, OGL). ONS local authority district boundaries, December 2025 (OGL). OpenStreetMap (ODbL). Scout Moor II Environmental Statement (2025) and Further Environmental Information (2026); Calderdale Energy Park PEIR (April 2026), Table 4-1, Table 12-9 and Figure 12-5-1.

Appendix B (round two). Settlements with theoretical visibility of both schemes

4 October 2026. Accompanies the representation on the Further Environmental Information, Rossendale 2025/0267 and Rochdale 25/00680/FUL.

OS Open Names places of type City, Town, Village or Suburban Area whose gazetteer point lies in a land cell seeing at least one turbine of each scheme, on the revised 12-turbine layout (v2). 206 places, of which 63 are in Lancashire County Council's area (Blackburn with Darwen is listed separately). Counts are bare earth, at the gazetteer point only: they are theoretical maxima, and a surface model removes most of them at the point itself while open ground within 100 m often keeps them (Appendix A, section A6).

v1 is the 17-turbine layout as published on 24 August 2026. 'out' means the place was not in the v1 overlap. Where the v1r rebuild (same 17 positions, ground levels under the round-two rule) differs from v1, the v1r value follows in brackets.

Centres: the angle between the two arrays' centres is 53.5 degrees or less. Whole: every turbine of both schemes fits in one 53.5 degree frame (168 of 206 places).

Last column: whether the point lies in the "both may be visible" class of the applicant's own Figure 11.16 (Appendix C). 198 of 206 do.

Settle ment	Type	Area	v1 SM ll (of 17)	v1 Cal derdal e	v2 SM ll (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
Four Lane Ends	Suburba n Area	Blackbu rn with Darwen	17	34	11	34	45	40 deg	yes	yes	both
Revidge	Suburba n Area	Blackbu rn with Darwen	16 (17)	33	12	33	45	38 deg	yes	yes	both
Roysha w Hill	Suburba n Area	Blackbu rn with Darwen	16	33	11	33	44	41 deg	yes	yes	both
Brookh ouse	Suburba n Area	Blackbu rn with Darwen	8	30	6	30	36	41 deg	yes	yes	both
Pleasing ton	Village	Blackbu rn with Darwen	1 (not in v1r)	26 (not in v1r)	1	26	27	33 deg	yes	yes	both
Shadsw orth	Suburba n Area	Blackbu rn with Darwen	9	17	5	17	22	44 deg	yes	yes	both
Intack	Suburba n Area	Blackbu rn with Darwen	8	15	5	15	20	45 deg	yes	yes	both
Whinny Edge	Suburba n Area	Blackbu rn with Darwen	7	13	5	13	18	42 deg	yes	yes	both
Daisyfie ld	Suburba n Area	Blackbu rn with Darwen	6	10	4	10	14	43 deg	yes	yes	both

Settle ment	Type	Area	v1 SM II (of 17)	v1 Cal derdal e	v2 SM II (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
Bastwel l	Suburba n Area	Blackbu rn with Darwen	7	1	5	1	6	42 deg	yes	yes	both
Tong Street	Suburba n Area	Bradfor d	16	27	11	27	38	28 deg	yes	yes	both
Toftsha w Moor	Suburba n Area	Bradfor d	16	25	11	25	36	28 deg	yes	yes	both
Mountai n	Village	Bradfor d	17	8	12	8	20	40 deg	yes	yes	both
Wyke	Suburba n Area	Bradfor d	9	2	6	2	8	35 deg	yes	yes	both
Old Town	Suburba n Area	Calderd ale	16	34	11	34	45	91 deg	no	no	both
Bank Top	Suburba n Area	Calderd ale	4	32	3	32	35	46 deg	yes	no	both
Pecket Well	Village	Calderd ale	17	20	12	20	32	90 deg	no	no	both
Clifton	Suburba n Area	Calderd ale	1	11	1	11	12	37 deg	yes	yes	both
Chidsw ell	Suburba n Area	Kirklees	13 (14)	31	9	31	40	26 deg	yes	yes	both
Cross Roads	Village	Kirklees	8 (7)	34	6	34	40	30 deg	yes	yes	both
Healey	Suburba n Area	Kirklees	13	29 (30)	9	30	39	28 deg	yes	yes	both
Westbor ough	Suburba n Area	Kirklees	8	32	7	32	39	28 deg	yes	yes	both
Earlshe aton	Suburba n Area	Kirklees	6	32	4	32	36	27 deg	yes	yes	both
East Bierley	Suburba n Area	Kirklees	14	23	11	23	34	28 deg	yes	yes	both
Birkens haw	Village	Kirklees	14	20	9	20	29	28 deg	yes	yes	both
Lower Soothill	Suburba n Area	Kirklees	14	17	10	17	27	26 deg	yes	yes	both
Gomers al Hill Top	Suburba n Area	Kirklees	14	16	10	16	26	30 deg	yes	yes	both
Hightow n Heights	Suburba n Area	Kirklees	11	18 (17)	7	17	24	34 deg	yes	yes	both
Gomers al	Village	Kirklees	12	15	8	15	23	29 deg	yes	yes	both

Settle ment	Type	Area	v1 SM II (of 17)	v1 Cal derdal e	v2 SM II (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
Hill Top Estate	Suburba n Area	Kirklees	9 (8)	18 (17)	6	17	23	29 deg	yes	yes	both
Farnley Tyas	Village	Kirklees	4	19	3	19	22	35 deg	yes	yes	both
Robertt own	Suburba n Area	Kirklees	8	17	5	17	22	32 deg	yes	yes	both
Birstall	Suburba n Area	Kirklees	13	12	9	12	21	28 deg	yes	yes	both
Hartshe ad	Suburba n Area	Kirklees	3	16	4	16	20	34 deg	yes	yes	both
Nunroy d	Suburba n Area	Kirklees	4	13	4	13	17	30 deg	yes	yes	both
Birkens haw Bottoms	Suburba n Area	Kirklees	12	7	9	7	16	28 deg	yes	yes	both
Swinclif fe	Suburba n Area	Kirklees	12	6	9	6	15	29 deg	yes	yes	both
Scholes	Village	Kirklees	2	8	3	8	11	34 deg	yes	yes	both
Newchu rch in Pendle	Village	Lancash ire	17	33	12	33	45	61 deg	no	no	both
Cliffe	Suburba n Area	Lancash ire	14 (15)	34	10	34	44	52 deg	yes	no	both
Cumera gh Village	Village	Lancash ire	15	34	10	34	44	28 deg	yes	yes	both
Grimsar gh	Village	Lancash ire	14	34	9	34	43	29 deg	yes	yes	both
Cow Hill	Village	Lancash ire	14	32	10	32	42	28 deg	yes	yes	both
Edge End	Suburba n Area	Lancash ire	14	33	9	33	42	51 deg	yes	no	both
Lower Fold	Suburba n Area	Lancash ire	14	33	9	33	42	52 deg	yes	no	both
Great H arwood	Town	Lancash ire	12	33	8	33	41	52 deg	yes	no	both
New Town	Suburba n Area	Lancash ire	11 (10)	34	7	34	41	31 deg	yes	yes	both
Rishton	Town	Lancash ire	13	33	8	33	41	50 deg	yes	no	both
Whittin gham	Village	Lancash ire	11	34	7	34	41	29 deg	yes	yes	both

Settle ment	Type	Area	v1 SM II (of 17)	v1 Cal derdal e	v2 SM II (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
Fulwood Row	Suburban Area	Lancashire	11	33	7	33	40	26 deg	yes	yes	both
Waverledge	Suburban Area	Lancashire	11	33	7	33	40	52 deg	yes	no	both
Higham	Village	Lancashire	16	27	12	27	39	67 deg	no	no	both
Broughton	Village	Lancashire	14	27	9	27	36	25 deg	yes	yes	both
Fulwood	Town	Lancashire	12	28	8	28	36	25 deg	yes	yes	both
Hey	Village	Lancashire	14	26	10	26	36	49 deg	yes	no	both
Knowle Green	Village	Lancashire	17	24	12	24	36	35 deg	yes	yes	both
Sharoe Green	Suburban Area	Lancashire	12	28	8	28	36	25 deg	yes	yes	both
Sherwood	Suburban Area	Lancashire	9	29	6	29	35	26 deg	yes	yes	both
Harwood Bar	Suburban Area	Lancashire	3	31	2	31	33	55 deg	no	no	both
Blacko	Village	Lancashire	15	21	11	21	32	55 deg	no	no	both
Fence	Village	Lancashire	14	23	9	23	32	68 deg	no	no	both
Oakenshaw	Suburban Area	Lancashire	out	out	1	30	31	56 deg	no	no	no
Barton	Village	Lancashire	16	19	11	19	30	24 deg	yes	yes	both
Beverley	Village	Lancashire	15	20	10	20	30	56 deg	no	no	both
Nooklands	Suburban Area	Lancashire	13	21	7	21	28	24 deg	yes	yes	both
Tanterton	Suburban Area	Lancashire	14	18	10	18	28	24 deg	yes	yes	both
Wheatley Lane	Village	Lancashire	13	21	7	21	28	68 deg	no	no	both
Red Scar	Suburban Area	Lancashire	9	19	7	19	26	28 deg	yes	yes	both
Cadley	Suburban Area	Lancashire	12	17	8	17	25	24 deg	yes	yes	both
Laneside	Suburban Area	Lancashire	5 (4)	23	2	23	25	61 deg	no	no	both

Settle ment	Type	Area	v1 SM II (of 17)	v1 Cal derdal e	v2 SM II (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
Nog Tow	Suburba n Area	Lancash ire	14	15	10	15	25	24 deg	yes	yes	both
Gallows Hill	Suburba n Area	Lancash ire	10	16	7	16	23	25 deg	yes	yes	both
Ashton- on-Ribb le	Suburba n Area	Lancash ire	13	13	9	13	22	23 deg	yes	yes	both
Haggate	Suburba n Area	Lancash ire	8	16	6	16	22	89 deg	no	no	both
Ingol	Suburba n Area	Lancash ire	13 (12)	14	8	14	22	24 deg	yes	yes	both
Ribblet on	Suburba n Area	Lancash ire	9	16	5	16	21	27 deg	yes	yes	both
Brindle	Village	Lancash ire	3	18	2	18	20	27 deg	yes	yes	both
Cottam	Village	Lancash ire	14	10	10	10	20	23 deg	yes	yes	both
Harle Syke	Suburba n Area	Lancash ire	6	16	4	16	20	88 deg	no	no	no
Higher Penwort ham	Suburba n Area	Lancash ire	12	12	8	12	20	23 deg	yes	yes	both
Brookfi eld	Suburba n Area	Lancash ire	5	16	3	16	19	27 deg	yes	yes	both
Holme Slack	Suburba n Area	Lancash ire	9	14	5	14	19	26 deg	yes	yes	both
Woodpl umpton	Village	Lancash ire	14	10	9	10	19	23 deg	yes	yes	both
Goosnar gh	Village	Lancash ire	13	10	8	10	18	27 deg	yes	yes	both
Deepdal e	Suburba n Area	Lancash ire	10	10	7	10	17	26 deg	yes	yes	both
Ashton Bank	Suburba n Area	Lancash ire	13	7	9	7	16	23 deg	yes	yes	both
Grange	Suburba n Area	Lancash ire	3	14	2	14	16	28 deg	yes	yes	both
Adelphi	Suburba n Area	Lancash ire	11	7	7	7	14	24 deg	yes	yes	both
Larches	Suburba n Area	Lancash ire	13	5	9	5	14	23 deg	yes	yes	both
Lea	Suburba n Area	Lancash ire	13	5	9	5	14	22 deg	yes	yes	both
Ribblet on Hall	Suburba n Area	Lancash ire	5	10	3	10	13	28 deg	yes	yes	both

Settle ment	Type	Area	v1 SM II (of 17)	v1 Cal derdal e	v2 SM II (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
New Gate	Village	Lancash ire	7	4	7	4	11	22 deg	yes	yes	both
Stanhill	Suburba n Area	Lancash ire	6	6	5	6	11	50 deg	yes	no	both
Farington Moss	Village	Lancash ire	5	6 (7)	3	7	10	23 deg	yes	yes	both
New Longton	Village	Lancash ire	9	3	7	3	10	22 deg	yes	yes	both
White Stake	Village	Lancash ire	8 (9)	3	6	3	9	22 deg	yes	yes	both
Avenham	Suburba n Area	Lancash ire	7	2	6	2	8	25 deg	yes	yes	both
Lowerford	Suburba n Area	Lancash ire	2	6	2	6	8	64 deg	no	no	both
Hurst Green	Village	Lancash ire	6	3	4	3	7	40 deg	yes	yes	both
Frenchwood	Suburba n Area	Lancash ire	6	2	4	2	6	25 deg	yes	yes	both
Milnshaw	Suburba n Area	Lancash ire	3	2	2	2	4	59 deg	no	no	no
Black Gates	Suburba n Area	Leeds	11	30	8	30	38	23 deg	yes	yes	both
Adwalton	Suburba n Area	Leeds	16	25	11	25	36	27 deg	yes	yes	both
East Ardsley	Village	Leeds	7 (8)	31	5	31	36	22 deg	yes	yes	both
Westerton	Suburba n Area	Leeds	11	25	8	25	33	23 deg	yes	yes	both
Bruntcliffe	Suburba n Area	Leeds	16	21	11	21	32	25 deg	yes	yes	both
Nook	Suburba n Area	Leeds	11	19	8	19	27	24 deg	yes	yes	both
Common Side	Suburba n Area	Leeds	10 (11)	5	6	5	11	24 deg	yes	yes	both
America Moor	Suburba n Area	Leeds	5	3	3	3	6	25 deg	yes	yes	both
Levenshulme	Suburba n Area	Manche ster	17	13	12	13	25	18 deg	yes	yes	both
Burnage	Suburba n Area	Manche ster	17	11	12	11	23	16 deg	yes	yes	both
Gorton	Suburba n Area	Manche ster	17	10	12	10	22	19 deg	yes	yes	both

Settle ment	Type	Area	v1 SM II (of 17)	v1 Cal derdal e	v2 SM II (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
Belle Vue	Suburba n Area	Manche ster	17	8	12	8	20	18 deg	yes	yes	both
Clayton	Suburba n Area	Manche ster	17	8	12	8	20	20 deg	yes	yes	both
Withing ton	Suburba n Area	Manche ster	17	8	12	8	20	14 deg	yes	yes	both
Fallowfi eld	Suburba n Area	Manche ster	17	7	12	7	19	15 deg	yes	yes	both
Longsig ht	Suburba n Area	Manche ster	17	7	12	7	19	17 deg	yes	yes	both
Rushol me	Suburba n Area	Manche ster	17	7	12	7	19	17 deg	yes	yes	both
West Gorton	Suburba n Area	Manche ster	17	7	12	7	19	18 deg	yes	yes	both
Didsbur y	Suburba n Area	Manche ster	17	6	12	6	18	14 deg	yes	yes	both
East Di dsbury	Suburba n Area	Manche ster	17	5	12	5	17	14 deg	yes	yes	both
Brunswi ck	Suburba n Area	Manche ster	17	4	12	4	16	16 deg	yes	yes	both
Infirmar y	Suburba n Area	Manche ster	17	4	12	4	16	16 deg	yes	yes	both
West Di dsbury	Suburba n Area	Manche ster	17	5 (4)	12	4	16	13 deg	yes	yes	both
Ardwic k	Suburba n Area	Manche ster	17	3	12	3	15	17 deg	yes	yes	both
Beswic k	Suburba n Area	Manche ster	17	3	12	3	15	18 deg	yes	yes	both
Barlow Moor	Suburba n Area	Manche ster	17	2	12	2	14	12 deg	yes	yes	both
Norther n Moor	Suburba n Area	Manche ster	17	2	12	2	14	11 deg	yes	yes	both
Ancoats	Suburba n Area	Manche ster	17	1	12	1	13	16 deg	yes	yes	both
Charlest own	Suburba n Area	Manche ster	17	1	12	1	13	23 deg	yes	yes	both
Chorlto n-cum- Hardy	Suburba n Area	Manche ster	17	1	12	1	13	12 deg	yes	yes	both
Moss Side	Suburba n Area	Manche ster	17	1	12	1	13	14 deg	yes	yes	both
New Moston	Suburba n Area	Manche ster	17	1	12	1	13	25 deg	yes	yes	both

Settle ment	Type	Area	v1 SM II (of 17)	v1 Cal derdal e	v2 SM II (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
Northen den	Suburba n Area	Manche ster	17	1	12	1	13	12 deg	yes	yes	both
Univer sity	Suburba n Area	Manche ster	17	1	12	1	13	15 deg	yes	yes	both
Whalley Range	Suburba n Area	Manche ster	17	1	12	1	13	13 deg	yes	yes	both
Rathmel l	Village	North Y orkshire	3	33	2	33	35	25 deg	yes	yes	both
Airton	Village	North Y orkshire	12	20	8	20	28	21 deg	yes	yes	both
West Marton	Village	North Y orkshire	1	14	1	14	15	30 deg	yes	yes	no
Acre	Suburba n Area	Oldham	17	32	12	32	44	38 deg	yes	yes	both
Broadbe nt	Suburba n Area	Oldham	17	32	12	32	44	40 deg	yes	yes	both
Oldham Edge	Suburba n Area	Oldham	17	32	12	32	44	37 deg	yes	yes	both
Higgins haw	Suburba n Area	Oldham	17	32 (31)	12	31	43	39 deg	yes	yes	both
Glodwi ck	Suburba n Area	Oldham	11	31	8	31	39	35 deg	yes	yes	both
Royton Moss	Suburba n Area	Oldham	17	26	12	26	38	40 deg	yes	no	both
Cold Hurst	Suburba n Area	Oldham	17	24	12	24	36	35 deg	yes	yes	both
Cold Hurst Hollow	Suburba n Area	Oldham	17	21	12	21	33	36 deg	yes	yes	both
Shaw Edge	Suburba n Area	Oldham	17	21	12	21	33	43 deg	yes	no	both
Wernet h	Suburba n Area	Oldham	17	22 (21)	12	21	33	32 deg	yes	yes	both
Higher Barrows haw	Suburba n Area	Oldham	17	19	12	19	31	41 deg	yes	no	both
Narrow Gate Brow	Suburba n Area	Oldham	17	14	12	14	26	45 deg	yes	no	both
Brownl ow	Suburba n Area	Oldham	17	13	12	13	25	41 deg	yes	no	both
Gravel Hole	Suburba n Area	Oldham	17	11	12	11	23	44 deg	yes	no	both

Settle ment	Type	Area	v1 SM II (of 17)	v1 Cal derdal e	v2 SM II (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
Hangin g Chadder	Suburba n Area	Oldham	17	11	12	11	23	43 deg	yes	no	both
Heyside	Suburba n Area	Oldham	17	11	12	11	23	41 deg	yes	no	both
Summit	Suburba n Area	Oldham	17	10	12	10	22	43 deg	yes	no	both
Burnley Brow	Suburba n Area	Oldham	17	9	12	9	21	35 deg	yes	yes	both
Bank Top	Suburba n Area	Oldham	17	8	12	8	20	34 deg	yes	yes	no
Failswo rth	Town	Oldham	17	7	12	7	19	25 deg	yes	yes	both
Shaw Side	Suburba n Area	Oldham	17	7	12	7	19	44 deg	yes	no	both
Westwo od	Suburba n Area	Oldham	17	6	12	6	18	33 deg	yes	yes	both
Alder Root	Suburba n Area	Oldham	17	3	12	3	15	32 deg	yes	yes	both
Cowhill	Suburba n Area	Oldham	17	3	12	3	15	31 deg	yes	yes	both
Busk	Suburba n Area	Oldham	17	2	12	2	14	34 deg	yes	yes	both
North Moor	Suburba n Area	Oldham	17	2	12	2	14	34 deg	yes	yes	no
Long Sight	Suburba n Area	Oldham	17	1	12	1	13	38 deg	yes	yes	both
West Hulme	Suburba n Area	Oldham	17	1	12	1	13	36 deg	yes	yes	no
Moorhe y	Suburba n Area	Oldham	14	2	10	2	12	35 deg	yes	yes	no
Burned ge	Village	Rochdal e	17	7	12	7	19	48 deg	yes	no	both
Buersil Head	Suburba n Area	Rochdal e	17	5	12	5	17	45 deg	yes	no	both
Lady House	Suburba n Area	Rochdal e	17	1	12	1	13	55 deg	no	no	both
Pleasant View	Suburba n Area	Rochdal e	17	1	12	1	13	46 deg	yes	no	both
Heaton Norris	Suburba n Area	Stockpo rt	17	24	12	24	36	17 deg	yes	yes	both
Barrack Hill	Suburba n Area	Stockpo rt	17	23	12	23	35	20 deg	yes	yes	both

Settle ment	Type	Area	v1 SM II (of 17)	v1 Cal derdal e	v2 SM II (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
Mid Reddish	Suburba n Area	Stockpo rt	17	23	12	23	35	18 deg	yes	yes	both
Reddish Green	Suburba n Area	Stockpo rt	17	23	12	23	35	19 deg	yes	yes	both
South Reddish	Suburba n Area	Stockpo rt	17	23	12	23	35	18 deg	yes	yes	both
Heaton Moor	Suburba n Area	Stockpo rt	17	22	12	22	34	16 deg	yes	yes	both
Lancash ire Hill	Suburba n Area	Stockpo rt	17	22	12	22	34	18 deg	yes	yes	both
Heaton Chapel	Suburba n Area	Stockpo rt	17	20	12	20	32	17 deg	yes	yes	both
North Reddish	Suburba n Area	Stockpo rt	17	19	12	19	31	19 deg	yes	yes	both
Brinnin gton	Suburba n Area	Stockpo rt	17	17	12	17	29	19 deg	yes	yes	both
Greave	Suburba n Area	Stockpo rt	17	16	12	16	28	21 deg	yes	yes	both
Woodle y	Village	Stockpo rt	17	16	12	16	28	21 deg	yes	yes	both
Heaton Mersey	Suburba n Area	Stockpo rt	17	12	12	12	24	16 deg	yes	yes	both
Foggbro ok	Suburba n Area	Stockpo rt	17	11	12	11	23	18 deg	yes	yes	both
Edgeley	Suburba n Area	Stockpo rt	17	10	12	10	22	16 deg	yes	yes	both
Offerto n	Suburba n Area	Stockpo rt	17	10	12	10	22	18 deg	yes	yes	both
Little Moor	Suburba n Area	Stockpo rt	17	9	12	9	21	18 deg	yes	yes	both
Shaw Heath	Suburba n Area	Stockpo rt	17	9	12	9	21	16 deg	yes	yes	both
Cale Green	Suburba n Area	Stockpo rt	17	7	12	7	19	16 deg	yes	yes	both
Heavily	Suburba n Area	Stockpo rt	17	7	12	7	19	17 deg	yes	yes	both
Mile End	Suburba n Area	Stockpo rt	17	7	12	7	19	17 deg	yes	yes	both
Stockpo rt Great Moor	Suburba n Area	Stockpo rt	17	6	12	6	18	17 deg	yes	yes	both
Davenp ort	Suburba n Area	Stockpo rt	17	5	12	5	17	16 deg	yes	yes	both

Settle ment	Type	Area	v1 SM II (of 17)	v1 Cal derdal e	v2 SM II (of 12)	v2 Cal derdal e	Combi ned v2 (of 46)	Separa tion	Centre s	Whole	Applic ant Fig. 11.16
Stockpo rt	Town	Stockpo rt	17	4	12	4	16	17 deg	yes	yes	both
Steppin g Hill	Suburba n Area	Stockpo rt	17	2	12	2	14	17 deg	yes	yes	both
Greensi de	Suburba n Area	Tamesi de	17	14	12	14	26	23 deg	yes	yes	both
Fairfiel d	Suburba n Area	Tamesi de	17	12	12	12	24	22 deg	yes	yes	both
Haught on Green	Suburba n Area	Tamesi de	17	12	12	12	24	22 deg	yes	yes	both
Denton	Town	Tamesi de	17	9	12	9	21	23 deg	yes	yes	both
Droylsd en	Town	Tamesi de	17	4	12	4	16	23 deg	yes	yes	both
Gee Cross	Suburba n Area	Tamesi de	17	1	12	1	13	23 deg	yes	yes	both
Hooley Hill	Suburba n Area	Tamesi de	17	1	12	1	13	24 deg	yes	yes	both
Ossett Street Side	Suburba n Area	Wakefie ld	13 (14)	32	10	32	42	25 deg	yes	yes	both
Runtlin gs	Suburba n Area	Wakefie ld	2 (3)	28	3	28	31	26 deg	yes	yes	both

In the v1 overlap but not the v2 overlap: none.

Appendix C (round two). Comparison with the applicant's Figure 11.16

4 October 2026. Accompanies the representation on the Further Environmental Information, Rossendale 2025/0267 and Rochdale 25/00680/FUL.

Figure 11.16, "Cumulative ZTV Calderdale with Scout Moor II" (Stephenson Halliday, May 2026), maps three classes: Calderdale may be visible, Scout Moor II may be visible, both may be visible. Its legend gives OS Terrain 50, a viewer eye height of 2 m, Earth curvature and light refraction, bare earth, blade tip, and Calderdale turbines "as per PEIR Layout 07/04/2026". It gives no turbine counts, areas or settlement list.

C1. Method

The figure is a raster PDF. It was rendered at its native resolution and georeferenced on the OS 1 km grid (9,128 grid intersections, RMS 8.7 m, maximum 20.7 m; checked independently on nine Scout Moor II turbine markers, RMS 12.9 m). The green "both may be visible" class was transferred to the 50 m grid of Appendix A by the majority of pixels in each cell.

C2. Agreement

Area compared (land within the map)	Applicant "both" (km²)	This model (km²)	Intersection over union	This model inside the applicant's	Applicant's inside this model
Within 45 km of both schemes	702.6	698.3	0.88	94%	93%
Within 45 km of Scout Moor II	1,187.9	698.6	0.53	94%	55%
Whole map	1,394.8	698.9	0.46	94%	47%

Where both models compute, they describe the same overlap. The applicant's class is larger over the whole map because its Calderdale calculation extends beyond 45 km: 639.5 km² of its green class lies more than 45 km from every Calderdale turbine (pipeline/grids/fig1116_layout_check.json). Its green class also runs off the west and south edges of the map, so 1,394.8 km² is a minimum for the applicant's own total.

C3. Settlements on the applicant's own map

Of the 206 settlement points in this model's overlap (Appendix B), 198 lie inside the applicant's own "both may be visible" class, 60 of the 63 in Lancashire. The same count results from the majority of pixel votes in the 3 by 3 cells around each point. The eight outside it are Oakenshaw, Harle Syke and Milnshaw (Lancashire), West Marton (North Yorkshire), and Bank Top, North Moor, West Hulme and Moorhey (Oldham). Of the 69 points within 20 km of the nearest Scout Moor II turbine, the applicant's cumulative radius, 62 lie inside the class. Paragraph 11.549 of the FEI says the figure "rules out settlements within the assessment"; the settlements within its assessment are the fourteen groups within about 10 km assessed for the scheme alone (para 11.288), none of which is in this model's overlap or in the green class. All counts here are bare earth at the gazetteer point (Appendix A, section A6).

Beyond 20 km. Within 45 km of both schemes, 495.9 km² of the applicant's green class lies more than 20 km from the nearest Scout Moor II turbine; in this model, 479.8 km² of the 698.9 km² overlap does.

C4. A discrepancy in the figure

Figure 11.16 plots 65 Calderdale turbine markers, although its key says the PEIR layout of 7 April 2026, which has 34. Calderdale's PEIR Chapter 5, para 5.7.1, records an initial 2023 layout of "up to 65 turbines". The applicant's Calderdale visibility class agrees best with the 34-turbine layout (intersection over union 0.92, against 0.85 to 0.87 for the 65 marker positions run through this model at 150, 175 or 200 m; pipeline/grids/fig1116_layout_check.json), so

the analysis appears to use the right layout and the plotted symbols the wrong one. The applicant may wish to correct the figure.