

**EMSL Analytical, Inc.**

200 Route 130 North Cinnaminson, NJ 08077

Tel/Fax: (800) 220-3675 / (856) 786-5974

<http://www.EMSL.com> / [cinnaslab@EMSL.com](mailto:cinnaslab@EMSL.com)

EMSL Order: 042206180

Customer ID: AALI63

Customer PO: A61599

Project ID:

Attention: Shawnie Belluso

AirWell by Assaigai

5930 Midway Park Blvd

Albuquerque, NM 87109

Phone: (505) 345-8964

Fax:

Received Date: 03/23/2022 9:40 AM

Analysis Date: 03/24/2022

Collected Date:

Project: B378 / M6655

**Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy**

Sample	Description	Appearance	Non-Asbestos		Asbestos % Type
			% Fibrous	% Non-Fibrous	
1 042206180-0001	Texturing 1	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	<1% Chrysotile
2 042206180-0002	Tile 2	Red Non-Fibrous Homogeneous		94% Non-fibrous (Other)	6% Chrysotile
3 042206180-0003	Texturing 3	White/Black Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
4 042206180-0004	Roofing 4	Black Fibrous Homogeneous		96% Non-fibrous (Other)	4% Chrysotile

Analyst(s)

Laura Kantor (4)

Samantha Rundstrom, Laboratory Manager  
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method") but augmented with procedures outlined in the 1993 ("final") version of the method. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Estimation of uncertainty is available on request.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NVLAP Lab Code 101048-0, AIHA-LAP, LLC-IHLAP Lab 100194, NJ DEP 03036, PA ID# 68-00367, LA #04127

Initial report from: 03/24/2022 09:33:28

EMSL ANALYTICAL, INC.  
LABORATORY • PRODUCTS • TRAINING

## Asbestos Chain of Custody

EMSL Order Number (Lab Use Only):

042206180

200 ROUTE 130 NORTH  
CINNAMINSON, NJ 08077

PHONE: (800) 220-3675

FAX: (856) 786-5974

Company : AirWell by Assaigai		EMSL-Bill to: <input checked="" type="checkbox"/> Same <input type="checkbox"/> Different If Bill to is Different note instructions in Comments**	
Street: 5930 Midway Park Blvd. NE		Third Party Billing requires written authorization from third party	
City: Albuquerque	State/Province: NM	Zip/Postal Code: 87109	Country: USA
Report To (Name): Shawnie Belluso		Telephone #: 505-345-8964	
Email Address: reports@airwellnow.com		Fax #:	Purchase Order: A61599
Project Name/Number: B378 / M6655		Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email	
U.S. State Samples Taken: NM		CT Samples: <input type="checkbox"/> Commercial/Taxable <input type="checkbox"/> Residential/Tax Exempt	

## Turnaround Time (TAT) Options\* - Please Check

☐ 3 Hour ☐ 6 Hour ☒ 24 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☐ 2 Week

\*For TEM Air 3 hr through 6 hr, please call ahead to schedule. \*There is a premium charge for 3 Hour TEM AHERA or EPA Level II TAT. You will be asked to sign an authorization form for this service. Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide.

PCM - Air ☐ Check if samples are from NY

- ☐ NIOSH 7400  
☐ w/ OSHA 8hr. TWA

## PLM - Bulk (reporting limit)

- ☒ PLM EPA 600/R-93/116 (<1%)  
☐ PLM EPA NOB (<1%)  
 Point Count  
☐ 400 (<0.25%) ☐ 1000 (<0.1%)  
 Point Count w/Gravimetric  
☐ 400 (<0.25%) ☐ 1000 (<0.1%)  
☐ NYS 198.1 (friable in NY)  
☐ NYS 198.6 NOB (non-friable-NY)  
☐ NIOSH 9002 (<1%)

TEM - Air ☐ 4-4.5hr TAT (AHERA only)

- ☐ AHERA 40 CFR, Part 763  
☐ NIOSH 7402  
☐ EPA Level II  
☐ ISO 10312

## TEM - Bulk

- ☐ TEM EPA NOB  
☐ NYS NOB 198.4 (non-friable-NY)  
☐ Chatfield SOP  
☐ TEM Mass Analysis-EPA 600 sec. 2.5

## TEM - Water: EPA 100.2

- Fibers >10µm ☐ Waste ☐ Drinking  
 All Fiber Sizes ☐ Waste ☐ Drinking

## TEM - Dust

- ☐ Microvac - ASTM D 5755  
☐ Wipe - ASTM D6480  
☐ Carpet Sonication (EPA 600/J-93/167)

## Soil/Rock/Vermiculite

- ☐ PLM CARB 435 - A (0.25% sensitivity)  
☐ PLM CARB 435 - B (0.1% sensitivity)  
☐ TEM CARB 435 - B (0.1% sensitivity)  
☐ TEM CARB 435 - C (0.01% sensitivity)  
☐ TEM Qual. via Filtration Technique  
☐ TEM Qual. via Drop-Mount Technique

## Other:

☐

☐ Check For Positive Stop - Clearly Identify Homogenous Group Filter Pore Size (Air Samples): ☐ 0.8µm ☐ 0.45µm

Samplers Name:

Samplers Signature:

Sample #	Sample Description	Volume/Area (Air) HA # (Bulk)	Date/Time Sampled
1	Texturing 1		
2	Tile 2		
3	Texturing 3		
4	Roofing 4		

Client Sample # (s): 1

- 4

Total # of Samples: 4

Relinquished (Client):

Date: 3/22/2022

Time: 5:00 pm

Received (Lab):

Date: 3-23-22

Time: 9:40A

Comments/Special Instructions:



