



Section "A-A"



Section "B-B"

LEGEND :

- 1 Custom orb, 26 gauge, corrugated roofing.
- 2 75 x 50 hwd battens (on edge) at 750 crs.
- 3 50 mm roll of fibreglass insulation with double sided sisilation.
- 4 T & G timber ceiling. 19 mm.
- 5 200 x 75 millsawn oregon rafters at 1500 crs
- 6 400 x 100 millsawn oregon beam. ex 550 depth, cut into curve. 2 lengths half jointed over post & bolted.
- 7 Oregon packer with fixed ventilation.
- 8 200 sq timber posts supporting main beam.
- 9 350 x 50 millsaw oregon fascia
- 10 Capping - use only materials designed for use with zincalume roofing.
- 11 300 x 75 galvanised concealed gutters into 100 x 75 downpipes, leading to above ground tanks.
- 12 Window wall.
- 13 Layout brickwork containing flashings, dpc's etc.
- 14 Brick floor.
- 15 25 mm mortar bed.
- 16 2 mm waterproof membrane.
- 17 50 mm packing sand.
- 18 525 x 350 footing with 6 strands of F8 trenchmesh top & bottom with R6 ligs. 600 min excavated depth.
- 19 525 x 450 two storey footing with S11 trenchmesh top & bottom. 4 main wires. 600 min excavated depth.
- 20 400 x 400 isolated pad footings under verandah posts & beam posts.
- 21 T & G flooring (possibly secondhand) 19 mm min.
- 22 200 x 50 millsawn oregon floor joists at 450 crs.
- 23 200 x 75 millsawn oregon rafters at 1200 crs.
- 24 150 x 50 jack rafters under verandah.
- 25 Exterior brick paving to fall away from building.
- 26 Terracotta tile sill.
- 27 Steel lintel above arched windows.
- 28 Brickheaders above arched windows, supported on steel lintel.
- 29 250 x 75 jarrah or redgum lintel over interior doors in adobe walls.
- 30 Jack rafter.
- 31 200 sq. verandah posts, secured to pad.
- 32 Terracotta pipes as vents.



detail "a"

ROBERTS house - Strzelecki.
shire of Traralgon.

Design Alistair Knox & Accociates.
Mt Pleasant rd, Eltham. (03) 439 7404.

Scale -1:20 & 1:50 / Date - April 84 / Drawn - danny

JOB N^o 1217 (Sheet 2 of 2) *