

Mark Dziudziel

From: Mark Dziudziel
Sent: Tuesday, January 29, 2019 9:14 AM
To: Erik Herz
Cc: Brian Herz
Subject: Q41-6E

Long Island City, 23-10 41st Ave.

Inspected on 1/23/19 in the presence of Ernesto and tenant.

The floor has been damaged by water leak. Since the boards boards do not show high moisture content , there is a chance to complete the work in one day. The furniture must be moved out or moved around (hallway?). The base trim removed.15 boards to weave, about 139 sq ft to replace. One reducer for balcony doors needed. Two men full day, 16 hrs labor.

