

RFI-047 -- ELECTRICAL: ADDITIONAL MEZZANINE DISTRIBUTION PANEL

Synthetic public fixture · not a real project document

Question: The mechanical contractor has requested a dedicated distribution panel to serve new equipment on the Level 02 mechanical mezzanine. This panel, referred to on site as Panel-E, was not part of the originally issued electrical package.

Response: The design team has sized Panel-E for a connected capacity of 15.75 kW, based on the mechanical contractor's submitted equipment list. This panel does not yet appear in the issued electrical schedule; the schedule will be reissued at the next drawing revision. Until then, this RFI response is the current record of Panel-E's capacity.