

RFI-061 -- FINISHES: FIRE RATING CLARIFICATION FOR CORRIDOR DOORS

Synthetic public fixture · not a real project document

Question: The finishes schedule does not clearly state the required fire rating for the doors serving the Level 01 egress corridor. Please clarify against the issued door hardware packages.

Response: All egress corridor doors on Level 01 must match the 90-minute rating already specified for Package A hollow-metal doors. Refer to the door hardware specification sheets for the governing values; this RFI does not change any previously issued rating.