

RFI-058 -- MECHANICAL: DUCT ROUTING CONFLICT ABOVE CORRIDOR

Synthetic public fixture · not a real project document

Question: The supply air duct routed above the Level 01 main corridor conflicts with an existing electrical circuit breaker panel enclosure shown on the reflected ceiling plan.

Response: The mechanical contractor will offset the duct run by 150mm to clear the panel enclosure. No change to the electrical schedule or any panel's connected load is required.