

LEVEL 03 EAST WING DISTRIBUTION SCHEDULE

Synthetic public fixture · not a real project document

Board	Connected Load (kW)	Diversity Factor
Panel-B	34.00	0.71
Panel-F	17.25	0.60