



LOTO Type

CNPC Chuanqing Drilling Engineering Company Limited (CCDC)

Presented by
MD. TOWFIQ ELAHI
EHS ENGINEER



Types of LOTO

LOTO Device : Lockout padlocks

Primary Use : Securing lockout devices in place

When to use it : Use on breaker lockouts, valve lockouts, haspsplug lockouts, cable lockouts, and lock boxes





Application





Types of LOTO

LOTO Device : Lockout hasps

Primary Use : Allowing multiple workers to lock one isolation point

When to use it : Use when more than one authorized employee works on the same machine or energy source





Application





Types of LOTO

LOTO Device : Valve lockouts


Primary Use : Preventing valve movement

When to use it : Use on ball valves, gate valves, butterfly valves, and other fluid, gas, steam, or chemical lines





Application





Types of LOTO

LOTO Device : Breaker lockouts

Primary Use : Preventing electrical circuits from being switched on

When to use it : Use on panel breakers, machine circuits, and electrical isolation points





Application





Types of LOTO

LOTO Device : Plug lockouts


Primary Use : Blocking access to an electrical plug

When to use it : Use for cord-connected equipment that can be isolated by unplugging





Application





Types of LOTO

LOTO Device : Cable lockouts


Primary Use : Securing multiple or irregular energy-isolating points

When to use it : Use on oversized valves, linked handles, disconnects, or equipment with several lockout points





Application





Types of LOTO

LOTO Device : Group lock boxes

Primary Use : Controlling keys during group lockout

When to use it : Use when multiple employees service one machine or when multiple machines are locked out together

