

ICS Activation Checklist — Fire Emergency

Printable version of the on-screen checklist for the Fire Emergency scenario.

Time	Step	Actions	Lead / support	Confirmations
0-1 min	Step 1 — Check safety	- Shout "FIRE!" and raise the alarm / hit the manual alarm. - Radio: "Code Red — [Location] — [Fire Type]." IC activates ICS; OC deploys to the scene.	1st Responder / Security	☐ Alarm raised · location confirmed ☐ IC alerted
1-3 min	Step 2 — Activate ICS	- IC activates ICS and assigns OC, LC, Fire Marshal, EC, Medic. - OC proceeds to the fire scene to assess severity; EC logs time and informs Head Office; Fire Marshal mobilises the response team.	IC / EC	☐ ICS active · ERT activated ☐ Fire Marshal mobilised response team ☐ HO informed
3-5 min	Step 3 — Contain / isolate	- Fire Marshal leads on-site firefighting with Responders using extinguishers, sand, or hoses only if safe. - LC switches off main power/fuel supply when cleared by IC; OC ensures fire doors and containment are followed.	Fire Marshal / OC	☐ Main power & fuel shut down ☐ Fire contained · injuries treated
5-10 min	Step 4 — Evacuation / assembly	- OC directs evacuation routes; Responders and HODs assist guests to muster points without collecting belongings. - LC keeps alarm systems and comms active; Fire Marshal checks rooms and reports "All Clear Zone 1" etc.; EC logs headcount and missing persons.	OC / Responders / Fire Marshal	☐ Alarm & comms active ☐ Evacuation complete · headcount complete
10-15 min	Step 5 — External coordination	- IC contacts the park fire team or local authorities; maintains clear radio traffic as sole external liaison. - EC updates Head Office every 5 minutes until the fire is contained.	IC / EC	☐ Authorities contacted · HO updated
15-30 min	Step 6 — Medical care / support	- First aid: treat burns, inhalation, and shock; prepare for evacuation if required. - LC ensures backup generator power for lights and radios.	Medic / OC / LC	☐ Medical assistance provided ☐ Backup generator power in place if needed
30-60 min	Step 7 — Verification	- Confirm with Fire Marshal that no active fire remains; OC checks for secondary hazards (electrical arcs, fuel leaks). - IC declares "All Clear," or orders complete evacuation if fire cannot be controlled. No re-entry until All Clear.	IC / Fire Marshal / OC	☐ No active fires · secondary hazards checked ☐ All Clear declared or evacuation ordered
Within 24 hrs	Step 8 — Debrief & reporting	- IC leads a formal debrief within 2 hours of containment. - EC submits the Fire Incident Report and headcount log to Head Office within 24 hours; Fire Marshal reviews equipment and drill records.	IC / EC / Fire Marshal / OC / LC / Medic	☐ Team debriefed · report submitted ☐ Equipment checked, replenished, drill records updated