

SIPPY DOWNS DEPOT SHED REFURBISHMENT

ELECTRICAL SERVICES



LOCALITY MAP
N.T.S

LEGEND

POWER

- MAIN SWITCHBOARD (EXISTING)
- DISTRIBUTION SWITCHBOARD (EXISTING)
- NEW DISTRIBUTION SWITCHBOARD: 18 POLE; IP66 MIN; EQUAL TO HAGER VECTOR HAGVE118H LOAD CENTRE OR APPROVED EQUIVALENT
- EXISTING UNDERGROUND HDuPVC ELECTRICAL CONDUIT
- EXISTING OVERHEAD ELECTRICAL CONDUIT
- UNDERGROUND HDuPVC ELECTRICAL CONDUIT (ORANGE). SIZE AND QTY AS INDICATED ON LAYOUT DRAWINGS
- 10A DOUBLE SWITCHED SOCKET OUTLET
- PERMANENT CONNECTION VIA LOCAL WIRED ISOLATOR (RATING/PHASES AS NOTED ON LAYOUT PLAN)
- POINT OF ATTACHMENT TO BE REMOVED (EXISTING)
- JUNCTION BOX AND ASSOCIATED CABLING TO BE REMOVED (EXISTING)

LIGHTING

REFER TABLE BELOW FOR LUMINAIRE SCHEDULE

- 1200x150mm SURFACE MOUNTED BATTEN LUMINAIRE (B1/B2)
- SURFACE MOUNTED BATTEN LUMINAIRE (EXISTING)
- 150mm (DIA) RECESSED DOWNLIGHT LUMINAIRE (D1)
- SURFACE MOUNTED OYSTER LUMINAIRE (EXISTING)
- 305x245mm WALL MOUNTED FLOODLIGHT LUMINAIRE (F1)
- WALL MOUNTED FLOODLIGHT LUMINAIRE (EXISTING)
- WALL MOUNTED OYSTER LUMINAIRE (W1)
- 10A SINGLE WAY LIGHT SWITCH

SCHEMATIC

- CURRENT TRANSFORMER METERING (RETAIL)
- 1Ø OR 3Ø POWER
- BUS BAR / DIN RAIL
- SURGE DIVERTER AND ISOLATION FUSE (RATING AS NOTED)
- ISOLATOR (MCCB / MCB TO SUIT FAULT RATING)
- CIRCUIT BREAKER (MCCB / MCB TO SUIT FAULT RATING)
- RCBO

DRAWING REGISTER

DRAWING NUMBER	DRAWING TITLE
E001	COVER SHEET
E002	SPECIFICATION
E003	DETAILS & SCHEMATICS
E010	SITE PLAN
E020	DEMOLITION PLAN
E021	LAYOUT PLAN

ABBREVIATIONS

ALL OUTLETS TO BE MOUNTED AT 300mm AFFL UNLESS OTHERWISE NOTED.

- FB ISOLATOR FOR FUEL BOWSER
- HWS HOT WATER SYSTEM
- TC TIME CLOCK

COORDINATE INSTALLATION OF OUTLETS/ACCESSORIES FOR SPECIFIC EQUIPMENT WITH RELEVANT EQUIPMENT SUPPLIER. CONFIRM RATINGS AND CONNECTION TYPE PRIOR TO ORDERING. CONFIRM LOCATION PRIOR TO INSTALLATION.

LUMINAIRE SCHEDULE

REF.	DESCRIPTION	LAMP DETAILS				LUMINAIRE DETAILS				MOUNTING ARRANGEMENT	CONTROL GEAR	WARRANTY	EQUAL TO	SUPPLIER	NOTES
		TYPE	WATTAGE (W)	OUTPUT (Lm)	COLOUR TEMP. (K)	IP RATING	IK RATING	DIFFUSER	FINISH						
B1	1260mm (L) x 112mm (W) SURFACE MOUNTED BATTEN LUMINAIRE	LED	36	4719	4000	IP66	IK10	OPAL POLYCARBONATE	GREY	SURFACE MOUNTED TO RAFTERS	INTEGRAL LED DRIVER (NON-DIM)	5 YEARS	STORM G3 1558	GAMMA ILLUMINATION	-
B2	1260mm (L) x 112mm (W) SURFACE MOUNTED BATTEN LUMINAIRE	LED	36	4719	4000	IP66	IK10	OPAL POLYCARBONATE	GREY	SURFACE MOUNTED TO WALL 2600mm AFFL	INTEGRAL LED DRIVER (NON-DIM)	5 YEARS	STORM G3 1558	GAMMA ILLUMINATION	-
D1	150mm (DIA) RECESSED LED DOWNLIGHT LUMINAIRE	LED	13	1082	4000	IP54	-	OPAL POLYCARBONATE ACRYLIC DIFFUSER	WHITE	RECESSED IN CEILING	INTEGRAL LED DRIVER (NON-DIM)	5 YEARS	JADE 150 1448	GAMMA ILLUMINATION	-
F1	305mm (L) x 245mm (W) SURFACE MOUNTED FLOODLIGHT LUMINAIRE	LED	45	4622	4000	IP65	IK10	TEMPERED GLASS	GREY	SURFACE MOUNTED TO WALL 2600mm AFFL	INTEGRAL LED DRIVER (NON-DIM)	5 YEARS	ALTUS 1341	GAMMA ILLUMINATION	-
W1	363mm (DIA) SURFACE MOUNTED OYSTER LUMINAIRE	LED	28	1311	4000	IP65	IK09	OPAL POLYCARBONATE	BLACK	SURFACE MOUNTED TO WALL 2000mm AFFL	INTEGRAL LED DRIVER (NON-DIM)	5 YEARS	MAXIMUS 1353	GAMMA ILLUMINATION	-

A1

2	12.01.22	TENDER ISSUE				C.L	C.L								
1	01.12.21	PRELIMINARY ISSUE				C.L	C.L								
Rv	DATE	REVISIONS				REC.	APPR.								

SURVEYED	
DRAWN	B.GRANT
CHECKED	C.LITTLETON
REVIEWED	C.LITTLETON
COORDINATOR	C.LITTLETON

WEBB AUSTRALIA GROUP - ACN 010 733 561
CAPITAL ONE COMPLEX, SUITE 13A
9 CAPITAL PLACE BIRTINYA QLD 4571
TELEPHONE: (07) 5438 8800
FACSIMILE: (07) 3870 4100
EMAIL: sunshinecoast@webbaustralia.com.au
CONSULTING ELECTRICAL ENGINEERS - MECHANICAL CONSULTANTS
LIGHTING CONSULTANTS - TECHNOLOGY CONSULTANTS - COMMUNICATIONS CONSULTANTS
COPYRIGHT © 2016 WEBB AUSTRALIA GROUP. ALL RIGHTS RESERVED. THIS DOCUMENT IS THE PROPERTY OF WEBB AUSTRALIA GROUP. NO PART OF THIS DOCUMENT IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, IN PART OR IN WHOLE, WITHOUT THE WRITTEN PERMISSION OF WEBB AUSTRALIA GROUP. ANY UNAUTHORIZED REPRODUCTION OR TRANSMISSION OF THIS DOCUMENT IS STRICTLY PROHIBITED. THE CONTRACT ADMINISTRATION IS WITH THE CLIENT.

Q403A



Sunshine Coast
COUNCIL

SIPPY DOWNS DEPOT SHED REFURBISHMENT
ELECTRICAL SERVICES
COVER SHEET

Project Number:
Q403A
Sheet No. - Revision No.
E001 2