CERTIFICATE OF COMPLIANCE

Certificate Number	EX16203
Report Reference	EX16203-2013-10-15
Date	2022-July-06

Issued to:

JINAN MEIDE CASTING CO LTD
Meide Science and Technology Park
Pingyin Industrial Park
JINAN SHANDONG 250400 CN

This is to certify that representative samples of

CHECK VALVES

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/CAN/UL/ULC-312 Standard for Check Valves for Fire-Protection Service

Additional Information:

See the UL Online Certifications Directory at https://iq.ulprospector.com for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	EX16203
Report Reference	EX16203-2013-10-15
Date	2022-July-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model H44X2-363, H44X2-PN10, H44X2-300, H44X2-PN16, H44X2-200, H44X2-PN25,
Model H84X-363, H84X-300, H84X-250, H84X-200, H84X-PN16, H84X-PN10,
Model H44X2A-363, H44X2A-300, H44X2A-250, H44X2A-200, H44X2A-PN16, H44X2A-PN10,
Model DH77XSR-300, DH77XSR-250, DH77XSR-200, DH77XSR-PN16, DH77XSR-PN10,

Model H84XF4-363, H84XF4-300, H84XF4-250, H84XF4-200, H84XF4-PN16, H84XF4-PN10,
Model H24X-363

Note: Model H44X2(A)-363/300/(250)/200 and H44X2(A)-PN16/(10) have same construction except different flange type and Model H44X2(A)-363 add 5 inch size and Model H44X2-363 add plug on body. The check valves are intended for installation in both the horizontal and vertical positions.

Model H84X series have same construction except rated pressure. Model H84X-363 is identical with current listed product model H84X-300 except higher pressure rating, plug material change to MI and add 5inches size.

Model H84XF4 series have same construction with H84X except add side plug on body. Model H84XF4-363 is identical with current listed product model H84XF4-300 except higher pressure rating, plug material change to MI and add 5inches size.

Model DH77XSR-300/250/200/PN16/PN10 has different construction with the above mentioned models; it is also intended for installation in both the horizontal and vertical positions.

Model H24X-363 is identical with current listed models with 363 psi rated pressure except for end configuration.

Model H44X2-PN25 is similar to current listed Model H44X-363 except for no plug and different end configuration designation.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/