MAIN PANEL

Square D Homeline 200 A · 40 spaces · basement east wall

17 Maple Court · surveyed 2026-09-20 · amps from each handle · shaded rows = 2-pole (240 V) · centre strip = bus leg

240 V **GENERATOR subpanel feed (via ATS)** *feeds the 100 A transfer switch → panel G*	**60**	1 3	A B	2 4	**50**	**EV charger, garage** 240 V *2023, Brightline Electric*
240 V **A/C zone 1 condenser**	**40**	5 7	A	6	**20**	Microwave
			B	8	**20**	Kitchen island DF
240 V **A/C zone 2 condenser**	**30**	9 11	A	10	**15**	Family room AFCI
			B	12	**15**	Office / den AFCI
240 V **Dryer receptacle (unused)** *dryer is gas; live 240 V circuit to laundry, see Quirks*	**30**	13 15	A	14	**20**	Powder room GFCI
			B	16	**15**	Primary bedroom lights AFCI *outlets are on G-8*
DF Kitchen countertop W	**20**	17	A	18	**20**	Primary bath GFCI
DF Kitchen countertop E	**20**	19	B	20	**15**	Bedroom 2 AFCI
DF Dishwasher	**20**	21	A	22	**15**	Stair + upstairs hall
Disposal	**20**	23	B	24	**20**	Basement outlets
AFCI Living room	**15**	25	A	26	**15**	Basement lights
AFCI Dining room	**15**	27	B	28	**20**	Deck + patio outlets GFCI
GFCI Garage outlets	**20**	29	A	30	**15**	Attic fan (none) *fan removed 2019; cable capped in attic*
Exterior lights	**15**	31	B	32		spare
GFCI Hall bath	**20**	33	A	34		spare
AFCI Bedrooms 3 + 4	**15**	35	B	36		spare
Smoke/CO (interconnected) *handle rating not legible: verify*	**15?**	37	A	38		spare
spare		39	B	40		spare

Connected load leg A 440 A · leg B 400 A against a 200 A main (2.20× worst leg) · 24 single-pole, 5 two-pole · 6 free poles · incl. the 60 A sub-feed

Print at 100 % on letter; trim and tape inside the panel door. Pencil corrections in the blank rows, then fix them in the book data.

GENERATOR PANEL

12-space subpanel behind the 100 A ATS

17 Maple Court · surveyed 2026-09-20 · amps from each handle · shaded rows = 2-pole (240 V) · centre strip = bus leg

EVERY CIRCUIT ON THIS PANEL IS GENERATOR-BACKED (22 kW standby via automatic transfer switch)

Furnace zone 1 (basement)	**20**	1	**A**	2	**20**	Laundry (washer + gas dryer)
Furnace zone 2 (attic)	**15**	3	**B**	4	**15**	Garage door + garage lights
Sump pump *dedicated simplex receptacle*	**20**	5	**A**	6	**15**	Hall + kitchen lights
Refrigerator	**20**	7	**B**	8	**20**	Primary bedroom outlets AFCI
Water heater power vent *moved here 2025, see Quirks*	**15**	9	**A**	10	**15**	Radon fan
DF Kitchen outlets (backed) *one outlet left of the sink*	**20**	11	**B**	12	**20**	Basement dehumidifier

Connected load leg A 105 A · leg B 110 A against a 60 A feed (1.83× worst leg) · 12 single-pole, 0 two-pole · 0 free poles

Print at 100 % on letter; trim and tape inside the panel door. Pencil corrections in the blank rows, then fix them in the book data.