



August 3, 2026

RE: PREDEV2026-00192

2900 S NATIONAL AVE

Dear: TRENT OVERHUE

Thank you for attending the Pre-Application Review meeting. Please find the attached critical and general comments that may significantly impact the development of your project.

Some of the primary processes that affect your project were discussed at the meeting, however, there may be other processes or approvals needed. You or your consultants are advised to review the list of permits on the City's website at: <https://www.springfieldmo.gov/3426/All-Permits>.

To begin your project create an eCity account at: <https://ecity.springfieldmo.gov/> or go directly to your eCity account.

1. Login to your eCity account
2. Select **Apply** at top of screen
3. Select a Project Application or Permit type
4. Read instructions or checklist
5. Fill out project (record) information
6. Complete additional information if needed
7. Attach documents or site plans if required
8. Review your submittal information
9. **Fees** under the **Payments** drop down menu 1. *(Be aware we are experiencing an increased volume of fake invoice scams though emails)*
10. Select the **Pay Fees** link
11. Select **Check Out** and follow the remaining prompts to enter payment information.

Take a few minutes to tell us about your experience with the predevelopment review process and how we can improve our processes by filling out a brief survey at <https://cityofsgf.questionpro.com/predev>.

1. For assistance with a **Building** permit contact us at 417-864-1059
2. For assistance with a **City Utilities** services contact us at 417-831-8888
3. For assistance with an **Environmental Services** permit contact us at 417-864-1921
4. For assistance with a **Planning** application contact us at 417-864-1611
5. For assistance with a **Public Works** permit contact us at 417-864-1980
6. For assistance with a security (cash escrow, letter of credit, or performance bond) contact us at 417-874-2159

Information about Escrow: If required, Public Improvement Plans must be constructed and accepted prior to approval of the final plat and/or issuance of the Building Permit. A security (cash escrow, letter of credit, or performance bond) can be utilized in lieu of the construction of Public Improvements prior to approval of final plat or issuance of a building permit. It is highly recommended that you contact escrow@springfieldmo.gov for more detailed information and instructions if you desire to submit securities.

DISCLAIMER: The review comments made during the pre-development process are general in nature and are meant to inform the owners, designers, architects, and engineers of issues that may have a critical impact on the proposed project and to guide your team toward the best possible outcome for your project. These comments should not be relied upon as a complete or final review. The contents of pre-development review comments, or any related summaries, do not relieve you or your representative from the responsibility of complying with all applicable City codes and ordinances.

Department of Planning and Development
Busch Municipal Building • 840 Boonville Avenue • Springfield, Missouri 65802
(417)-864-1611 • springfieldmo.gov



PreDevelopment Review Summary

RE: PREDEV2026-00192

Hearing Date: 06/10/26

Department	Review Comments
Building Development Services Review RODNEY WURGLER rwurgler@springfieldmo.gov	CriticalComments: None GeneralComments: When construction documents are submitted, a complete review will be provided.
City Utilities - Developers Services Review JOSH CASEY josh.casey@cityutilities.net	Critical Comments: 1) CU has capacity at a substation in the vicinity of the subject property to provide up to 10MW without negatively impacting CU's system. However, offsite electric distribution improvements will be required to provide service. Based on the primary use of a high performance/AI/compute data center, CU's typical extension policy and economic development policy provisions will likely not apply to the project. The cost to construct the electric infrastructure would be at the developer's expense. 2) CU is also examining if a special rate structure will be needed to accommodate the proposed use. This will likely be applied/enacted in the near future, so depending on when the project would be constructed, it may move to the special rate when enacted. General Comments: Contact Katherine Thompson - Senior Legal Counsel - katherine.thompson@cityutilities.net for details on the development of special policy and rate provisions. 3) The property has access to gas/water. CU's Utility Plan Submittal Guide Sheet is available at https://mo-springfieldutilities.civicplus.com/DocumentCenter/View/636/Utility-Plan-Submittal-Guide-Sheet-PDF to aid in the design of utility plans. Contact Developer Services at 417-831-8888 or Developer_Services@cityutilities.net if you have other questions.
ES - Cleanwater Services Review MATT TAYLOR mtaylor@springfieldmo.gov	No critical issues. Public sewer is currently available and the building is in an approved sewer district. A sewer permit was issued for this property in 1999 and in 2002. No new sewer permit would be required unless making a new connection to public sewer or increasing the size of the water meter.
ES - Sediment Erosion Control Review TRAYSON G LAWLER trayson.lawler@springfieldmo.gov	Critical Comments: 1. Per City Code Sec. 96-44, a City Land Disturbance Permit will be required if the estimated area of disturbance is 1 acre or greater. To apply, submit a Stormwater Pollution Prevention Plan (SWPPP) using the City's current SWPPP template available online: https://www.springfieldmo.gov/5783/Land-Disturbance-Permit. General Comments: The City of Springfield has published an updated City SWPPP template. To ensure the SWPPP complies with all State and City requirements, it is recommended that the SWPPP be submitted using our City template.

Department	Review Comments
Fire Review MARION BLACKWELL marion.blackwell@springfieldmo.gov	<u>Critical Comments:</u> None. <u>General Comments:</u> 2024 IFC in effect as of 01/15/2026 Pre-Action Sprinkler System - normal deferral process. CLEAN AGENT FIRESUPPRESSION Provide clean agent fire extinguishing system plan (deferred submittal) for review per 2024 IFC 904.10 and 2022 NFPA 2001. Automatic extinguishing systems shall not be considered as an alternative for automatic fire sprinkler systems. (2024 IFC 904.2.1) A red sign that is a minimum 6" x 6" in size with 1-inch white lettering shall be placed beside the abort switch explaining how it is to be operated." (2022 NFPA 2001 - 4.3.8.2) Enclosure integrity test to be observed by SFD Fire Protection Review Specialist Provide an enclosure integrity test report. (2022 NFPA 2001 – 10.5) UPS (depending on size and type of battery) may be considered an Energy Storage System - Chapter 12, 2024 IFC
Geographical Information Systems Review SPENSER WALLER spenser.waller@springfieldmo.gov	Structure involved in this project is addressed as 2900 S NATIONAL AVE. Northern smaller structure that does not appear to be involved is addressed as 2900 S NATIONAL AVE BLD A. Project does appear to require any changes to addressing. Additional addresses may be assigned if needed for additional utility services or are otherwise requested.

Department	Review Comments
Planning - DR Review MONICA PEARCY monica.pearcy@springfieldmo.gov	**Please note that the comments below are preliminary and subject to change. Additional or revised comments may be issued if the City adopts new regulations, standards, or guidelines applicable to this type of development. - The property is zoned Planned Development 251 and is a tract of record per AS5209. - The proposed use of "mixed-use office" seems to be permitted based on the submitted layout. The layout indicates the primary use of the building is office space (over 50%), while the HPC portion is considered accessory (under 50%). If the HPC portion is expanded past what is currently shown on the floor plan, staff will likely need to re-evaluate the use. - All uses shall operate in accordance with the noise standards in Section 6-1500 of the Springfield City Code. - No use shall emit an odor that creates a nuisance as determined by Chapter 2A, Article X of the Springfield City Code. - Please provide details regarding expected utility usage, noise level, and plans to mitigate any impacts on the area. - Refer to the PD document for a complete list of standards and use limitations. Update: It was determined that the proposed use does not align with the PD's permitted uses.
Public Works - Stormwater Review TRUETT HOUSE truett.house@springfieldmo.gov	<u>Critical Comments</u> - Any release from this system is a non-stormwater discharge and shall not be allowed to enter the City's MS4. City Code Sec. 96-27 prohibits discharge of polluting substances to the MS4, including heated water and chemically treated cooling water. Further, City Code defines illicit connections to include any conveyance that allows non-stormwater discharges (including sewage / process wastewater / wash water) to enter the MS4. <u>General Comments</u> Additional Stormwater Notes - Site Plan submitted was basic outline. Comments can change with newer site plan submission. - Include on the Plans a calculation of the Existing Impervious Surface Area, Existing Open Space Area, Post Development Impervious Surface Area, and Post Development Open Space Area. Per Chapter 4 Sec 3.2 for Detention Summary. - Excavation Permit is required for any construction in the City Right-of-Way. Zach Butcher is the Public Works Coordinator for Excavation Permits a. (417) 864-1994 zbutcher@springfieldmo.gov - Next Developers Steps: N/A a. All chapter and section references above are to the City's Flood Control and Water Quality Protection Manual Version April 2022: https://www.springfieldmo.gov/DocumentCenter/View/57515/Flood-Control-and-Water-Quality-Protection-Manual-April-2022
Public Works - Traffic Review GRADY PORTER grady.porter@springfieldmo.gov	<u>Critical Comments:</u> - Comments are based solely on the plans and supporting documents provided for this predevelopment review and may be subject to change upon submittal of additional or revised information. <u>General Comments:</u> - Sidewalks- Prior to approval of any building permit that involves new construction or site work, sidewalk is required along entire frontage of McCann Ave and Guinevere St as per City Code Section 36.3.06. Minimum sidewalk width is 5 ft. Sidewalk must be constructed to adjacent streets, driveways or adjacent sidewalk or the applicant must request to pay a \$84.32 per L.F. fee in lieu of sidewalk for the entire property frontage. If sidewalk is constructed it must be shown on Civil Site Plan and constructed under a sidewalk permit OR PIP plans (when required) with grades as necessary to show compliance with ADA requirements.
BDS - Flood Plain Review BELINDA GONZALEZ bgonzalez@springfieldmo.gov	This property is not in the flood area no further action is required.
Department	Review Comments

DISCLAIMER: The review comments made during the pre-development process are general in nature and are meant to inform the owners, designers, architects, and engineers of issues that may have a critical impact on the proposed project and to guide your team toward the best possible outcome for your project. These comments should not be relied upon as a complete or final review. The contents of pre-development review comments, or any related summaries, do not relieve you or your representative from the responsibility of complying with all applicable City codes and ordinances.

