



MARSHFIELD FIRE PROTECTION DISTRICT

521 S Prairie Lane | Marshfield, MO 65706
(417) 859-0884

August 17, 2026

RE: Freedom of Information Act Request

To: Katherine Wiltse

In reference to your request for information dated August 14, 2026, for the data center on Rifle Range Rd in Marshfield, MO. According to our records the address of that location is 259 Rifle Range Rd, Marshfield, MO.

Your request for all records of any emergency response at the data center between the dates of June 1, 2026, and August 14, 2026, has been researched. One report was found for that address dated July 18, 2026, for a smoke odor investigation. A copy of report # 26-0992 has been included with this communication.

As for your request for the ambulance report, Marshfield Fire Protection District does not maintain the records for the ambulance services in Webster County. You might consider contacting the Cox Ambulance Webster County Office in Marshfield, MO to see if they have any ambulance reports for that address. Additionally, as we were dispatched to this call you might consider obtaining that record from Webster County 9-1-1.

If you have any other questions, please contact me by email at asmith@marshfieldfire.com.

Sincerely,

Angie Smith

Administrative Assistant
asmith@marshfieldfire.com
417-859-0884 prompt #1



MARSHFIELD FIRE DEPARTMENT/DISTRICT
MARSHFIELD, MO. 65706

Incident: 26-0992

Incident Date: 7/18/2026

Fire Alarm Level:

EMS Alarm Level:

Response Category:

Primary Incident Type: Investigation: Smoke Investigation

Times

Dispatch

20:39:31

Enroute

20:40:23

Staged

Arrival

20:46:14

Cleared

21:34:57

Cancelled

Turnout Time: 0m 52s

Response Time: 6m 43s

Total Time: 55m 26s

Location

Protected Property:

Address: 259 Rifle Range Rd, Marshfield, MO 65706

District: MFPD

Township:

☐ Indoors

Location Use: As Intended

Location Type: Commercial: Office / Other Technical Services

Secondary Use:

Vacancy Reason:

Action Tactics

- Establish Incident Command
- Incident Assessment (360 Degree Visualization) Completed
- Investigation
- Notify Other Agencies

Aid

☐ Automatic Aid Given

☒ Automatic Aid Received

Aid Given:

Aid Received: NIANGUA FIRE PROTECTION DISTRICT (Auto)

Additional Information

Displacement

☐ People Present

Number of People Displaced:

Displacement Causes:

Animals Rescued:

Estimated Dollar Losses and Value

	PRE-INCIDENT VALUES	LOSSES
Property		
Contents		

Responding Apparatus and Personnel

ENG 4	Type: Engine (Structural)	☒ Is Emergent
Dispatch:	20:39:31	Personnel
Enroute:	20:40:23	#33 Fisher, Angela (Career Firefighter)
Arrival:	20:46:14	
Staged:		
Cleared:	21:34:57	
Canceled:		
SQ 1	Type: Chief/Staff/Command Officer	☒ Is Emergent
Dispatch:	20:39:31	Personnel
Enroute:	20:40:23	Cpt. 4 Saitz, Tony J (Career Captain)
Arrival:	20:46:14	
Staged:		
Cleared:	21:34:57	
Canceled:		
TK 1	Type: Water Tender/Tanker	☒ Is Emergent
Dispatch:	20:39:31	Personnel
Enroute:	20:40:23	#37 Pickett, Jason (Career Firefighter)
Arrival:	20:46:14	
Staged:		
Cleared:	21:34:57	
Canceled:		
POV		
Dispatch:	20:39:31	Personnel
Enroute:	20:40:23	CH 2 JETER, JOE (ASST. CHIEF 3 /FR)
Arrival:	20:46:14	CH 3 Fletcher, Rick (Asst. Chief/FM)
Staged:		
Cleared:	21:34:57	
Canceled:		
Station 1 Dep. Chief Ed Noland		☐ Is Emergent
Dispatch:	20:39:31	Personnel
Enroute:	20:40:23	#48 Whitecotton, Andrew (FF)
Arrival:	20:46:14	
Staged:		
Cleared:	21:34:57	
Canceled:		

Fire

Suppression**Investigation****Appliances****Utility:****Investigation Needed:****Utility District:****Investigation Types****Water Use:****Foam Use:****Water Supply:****Tactic Times****Command Established****360 Completed****Search Begin****Search Completed****Water on Fire****Fire Under Control****Fire Knocked Down****Suppression Complete**☐ Fire Progression?**Arrival Conditions:****Structure Damage:****Outside Fire Cause:****Structure Fire Cause:****Floor of Origin:****Room of Origin:****Acres Burned:****Risk Reduction****Smoke Alarm Presence:****Smoke Alarm Performance:****Occupant Action:**☐ Smoke Alarm Working**Smoke Alarm Types****Other Alarm Types****Fire Alarm Presence:****Smoke Alarm Operation:****Suppression**☐ Suppression Present**Suppression Type:****Suppression Coverage:****Suppression Operation:****Failure Reason:****Sprinkler Count:****Cooking Fire Suppression****Owner****Owner Name:** Trent Overhue

Email:

Phone Number:

Other Contact Information

Insurance

Owner Insurance Company:

Insurance Agency:

Agent Name:

Policy Type:

Policy Number:

Adjuster Name:

Hazards

Disposition:

Number Evacuated:

DOT Class:

☐ Release Occurred

Release Information

Estimated Amount:

Units:

Physical State:

Released Into:

Cause:

Narratives

General

Saitz, Tony

07/18/2026 22:27

Marshfield units were dispatched for a possible fire at the New Data Center which is under construction at this time. Upon arrival Marshfield Captain 4 had assumed command and had discovered light smoke coming from the backside of the new server units. After the completion of the 360 of all of the units, it was discovered that a moderate amount of black smoke was coming from Generator #3. Due to the heavy amount of smoke, Marshfield command had made the decision to shut down the generator, thus causing a power loss to one of the server rooms. Marshfield units had made contact with the general contractor Darren, who was on his way out. After checking the information on the generator panel it was showing no active faults in the system. The GC had advised Marshfield units that it was an older generator and sometimes it blows a lot more exhaust and runs harder than the others. Marshfield units had stood by as he restarted the system, and rebooted the server room. Once done a final check was completed to ensure that no further faults had tripped in which they hadn't. Marshfield units had then taken information and had cleared the scene.

Authorization

Member Making Report: Cpt. 4 Saitz, Tony J

Officer In Charge: Cpt. 4 Saitz, Tony J

Reviewed By:

Reviewed Date: