

Evacuator Bench/Wall Mount Maintenance Manual

SAFETY &/or HAZARD INFORMATION

This bulletin includes important safety information that should be read by owners, managers, service personnel, and anyone in charge of the pool or pool area. Also, we suggest a copy be posted for quick reference.

1. Only personnel trained and familiar with the proper use of pool chemicals should handle acid, liquid chlorine or chlorine compounds. Chemicals should never be used when swimmers are in the pool. Acid and liquid chlorine should always be stored, carried, or handled in plastic containers.
2. If grating is a part of the perimeter system, it should be kept firmly clamped down and in good repair at all times. Should a section of grating become loose or damaged that particular area must be immediately covered and a replacement of grate ordered. Under no circumstances should swimmers be allowed to use any portion of the perimeter that contains loose or damaged grating. Perimeter grating is not intended for foot traffic. Swimmers should be advised not to walk, stand, or jump on perimeter grates.
3. Ladders and grab rails are intended for the use of one swimmer at a time; they are not designed for handstands or other gymnastic stunts and they should not be used for this purpose. Ladder treads should be inspected regularly. If a tread becomes loose or damaged, the ladder should be taken out of service until repairs are made.
4. Lifeguard Chairs are intended for the individual use of trained "on duty" lifeguards, one (1) guard per chair. Lifeguard chairs are not to be used by swimmers, spectators, or by more than one (1) person at a time. There should be no diving from portable lifeguard chairs. Umbrellas should be closed or removed from portable lifeguard chairs during windy conditions. All frame connections are to be checked for tightness. The seat is bolted to the frame assembly. It is important to advise all users to periodically check to determine that the studs are firmly fastened to the seat and the nuts are tight. If they become loose or detached, it could result in serious injury. On outdoor installations or usage, it is suggested that the seat be removed and stored inside during the winter.
5. Starting Platforms should only be used by trained competitive swimmers or under the direct supervision of an instructor. Swimmers should execute shallow racing dives only. Impact with the pool bottom can cause severe injury. Starting platforms have warning labels and inform the purchaser of the need to remove the platforms during non-usage. If your starting platforms do not have warning labels, please contact the manufacturer immediately.
6. Bulkheads are designed and built for strength and safety. Any grating should be kept fully secured to avoid injury. **NO swimming under bulkhead. Never use bulkhead as a support or staging for equipment.** The bulkhead includes a compressor; please refer to owner's manual provided with the unit.

For questions concerning the usage of our equipment, please contact Paddock Pool Equipment Co., customer service.

Operation Guidelines

Congratulations on your recent purchase and installation of a Paddock Evacuator® Source-Capture System. The Evacuator is an engineered solution designed specifically for your facility to work with your mechanical (HVAC) system to eliminate and/or prevent air quality issues. Evacuator Technology source-captures and exhausts heavy trichloramine-laden air and other disinfectant by-products (DBPs) directly from the pool's surface and wet deck before this contaminated air can be recirculated through your mechanical system. We appreciate your commitment to healthy air quality.

Evacuator Design Specifications: Refer to drawing(s)

Maintenance for Evacuator System(s)

Your Evacuator System includes the following marked:

PVC Evacuator Bench System

- Rinse with fresh water and hand dry weekly to maintain clean, spot-free surface.
- Use a non-abrasive mild detergent and cloth as necessary for cleaning.
- The top of bench is HDPE material see **GRATING/SHEETING HDPE Care & Cleaning Maintenance** sheet.

Fiberglass Wall-Mount System

- Rinse with fresh water and hand dry weekly to maintain clean, spot-free surface.
- Polish with fiberglass wax twice a year to maintain gloss.

Exhaust Fan

- Maintain as defined by Manufacturer's Installation, Operation, and Maintenance Manual.
- Exhaust fans may require routine maintenance procedures. Reference manual as needed.

Variable Frequency Drive (VFD)

- Maintain as defined by Manufacturer's Operator's Manual.
- Owner determines adequate operation levels at different load periods and to document the appropriate settings. These VFD settings can be posted in the facility operating manual.
- Typical modes / operation levels may include:
 - Unoccupied Mode: facility may be closed during this time.
 - Occupied Mode / Normal Operation: typical every-day use, normal "business" hours.
 - Event Mode / High-Use Operation: swim meets, high-use periods, large bather loads.

Pool Maintenance

Maintenance

- Establish a routine maintenance schedule per manufacturer's guidelines.
- Monitor the airflow system rates, to be confirmed by facility operator monthly or when issues arise.
- Hire a HVAC maintenance company / mechanical contractor to manage a preventative maintenance schedule who is accustomed to dealing with indoor pools to ensure proper operation and routine up-keep.
- HVAC operating schedule that meets the need of facility programming.
- Consider design upgrades to enhance efficiency and effectiveness of existing system(s).
- When replacing the existing mechanical system, complete a study to determine the best system(s) available based on new technology and code requirements.
- Chloramines are always produced and released into the air in aquatic facilities, even during unoccupied times.
- Clean facilities are safer, more attractive and provide a more enjoyable experience for everyone.

Pool

- Refer to the **Safety &/or Hazard Information** sheet.
- Vacuum regularly to keep organics off pool bottom.

Pool Deck

- Wash down pool deck regularly to remove organics that are brought into the facility by patrons & guests, which are also produced as a result of facility use by patrons.
- Use non-oxidizing cleaning solutions to clean deck.
- Clean deck drains periodically to remove build-up of organics.

Pool Deck Equipment

- Rinse and clean deck equipment on a regular basis to remove build-up of organics and corrosive condensate from chloramines and Disinfectant By-Products (DBPs).
- Periodically wipe down stainless steel goods to remove caustic residue. Apply polish to stainless steel deck equipment, doors, water fountains, and any other fixtures that may be affected.

Patron Hygiene Program

- An effective patron hygiene program will greatly improve air and water quality, along with the staff and user experience.
- Post facility signage to encourage good personal hygiene program
- Swim Coaches can give swimmers breaks every 30 to 60 minutes. Urine is a major contributor to organic loading of a pool and a source of eye and skin irritation.
- Parents can schedule "out of pool" snack time that gives children a chance to use the restrooms.
- Facility Managers can schedule "Adult Only" swim time every hour.
- Everyone can help by encouraging showering and bathroom use before entering the pool, water park, spa, or any body of water within an aquatic facility.
- Maintain a "clean pool deck" policy: no street shoes, glass, food allowed on deck, etc.



GRATING/SHEETING - High Density Polyethylene (HDPE)

CARE AND CLEANING MAINTENANCE

Care and Maintenance

- Paddock's HDPE grating/sheeting is marine-grade polymer sheeting which is resistant to most chemicals and requires little maintenance to keep it looking new.
- Keep harsh solvents, acids, wood stains and wood preservatives away from Paddock HDPE finish. They may cause permanent staining and damage.
- Staining from rust is very difficult to remove so keep uncoated non stainless metals away from HDPE material.
- Shoes with marking soles can leave scuff marks that can be difficult to remove.

Cleaning

- For daily cleaning of everyday dirt and stains, use a non-abrasive cleaner such as "Zud" or "Soft Scrub" and a nylon brush to scrub lightly. Excessively hard scrubbing can mar the finish.
- Hard to remove stains will usually go away if you soak the area with bleach (like Clorox). When using this method, you must remove the grating from the stainless steel so it will not cause corrosion. **Do not use 100% granular or tablet (for pool) chlorine as a bleach alternate.**
- Pressure washing can mar the finish.
- Petroleum based stains can be difficult to remove, soak the area with WD-40®. Then use acetone or toluene with a white nylon scrub pad (color-based pads can transfer dye color to finish when combined with acetone).
- **Do not** use MEK, turpentine or naphtha solvent.
- **Do not** use polishes such as Armor-All ® to non-skid areas, this will reduce the slip coefficient and cause a fall/slip hazard.

Pool Water Considerations

Filtration:

A properly functioning filtration system is essential to providing patrons a clean, healthy swimming environment. A well-functioning filtration system includes an accurately sized filtration system with an appropriate filter bed, proper turnover rate, and filter media to be in good condition.

- Backwash to remove accumulating organics in the sand filters as recommended by manufacturer.
- Recharge regenerative media filters regularly to remove accumulated organics as recommended by manufacturer.
- Clean the pump strainer(s).

Chemical Feed System

- Chemical Controller capable of controlling sanitizer (ORP readings) & pH levels.
- Chemical feed system that provides a controlled feed rate of sanitizing and pH controlling chemicals on demand as needed.

Secondary Pool Disinfection

- Secondary disinfection systems can be added for additional layer of sanitation and also chloramine reduction at point of contact. Systems must be maintained on a regular, scheduled basis per manufacturer's guidelines for optimal operation and disinfection.
- Enzymes: supplementing your water chemistry program with Orenda™ Technologies Catalytic Enzymes will encourage the bio-oxidation of organic contaminants commonly found in pools, spas, and other recreational water systems. These enzymes naturally consume and digest oils and organics allowing your sanitizer (chlorine/bromine) to be more effective. Proper use of enzymes can also reduce chloramine production.

Water Chemistry

- Follow the National Swimming Pool Foundation Water Chemistry Guidelines, go to www.nspf.org.



Air Quality Recipe for Success

Introduction:

Most indoor swimming environments pose a challenge for owners and operators due to the multitude of factors that are required to provide a safe, comfortable swimming environment. Treating pool water with an oxidizing sanitizer is a must for maintaining healthy pool water. Unfortunately, there is a resulting reaction which causes issues for most indoor swimming environments.

All pools generate off-gassing Disinfectant By-Products (DBPs) as a result of oxidizing chemicals (chlorine/bromine) doing what they are supposed to do: *Oxidize Organics*. Organics could be defined as common foreign objects introduced to the pool: dirt, hair, skin cells, saliva, urine, etc. The issue relative to indoor pools and oxidizing organics is where these DBPs go and what impact they are having on the following: Patrons & Staff, Facility & Replacement Costs, Operating Costs, and Reputation.

Facts:

- Swimmers introduce organics into pools and onto pool decks which must be oxidized in order to maintain a healthy environment.
- The oxidation process results in DBPs off-gassing from the chlorinated pool water, including water splashed onto pool decks as well as aerosolized through water features.
- Traditional indoor aquatic facility HVAC systems are designed to heat, cool, and/or dehumidify natatorium air. They also are designed to introduce outdoor air (dilution) on an as-needed basis.
- The combination of chlorine oxidizing organics, DBPs off-gassing from the water's surface & pool deck, and the HVAC re-circulating DBP-laden air, creates a compounding effect of the contaminated air, which all contribute to a "Poor Indoor Air Quality Cycle".

Water & Air: Bridging the Gap

A swimming pool's water purification system, operating procedures, and resulting water quality conditions serve as the foundation for a natatorium's overall environment. Water temperature, filtration effectiveness, water chemistry conditions, chemical feed systems, types of chemicals, supplemental disinfecting equipment, facility maintenance procedures, and the organic load in pool water (clarity is an indicator) all contribute to the health of the pool water in both a positive and/or negative way. A swimming pool is a living biological 'science project' and requires consistent professional maintenance to stay ahead of compounding issues.

A natatorium's mechanical system provides patron comfort in the natatorium. This depends on operating parameters, equipment condition, and engineered airflow. The equipment must be designed properly and maintained on a regular basis to ensure proper effective operation.

Facility Air Considerations

Mechanical System Design & Operation

- Proper Airflow Rates:
 - Total Airflow
 - Supply Air
 - Exhaust Air
 - Outdoor Air
 - Evacuator Exhaust
- Duct System Design
 - Proper Return & Supply Distribution
 - Avoid Dead Spots, Stratification, & Zonal Effects
 - May Need Supply Register Adjustments
 - May Need Supplemental Directional Fans

Design Parameters

Secondary Facility Air Disinfection

- Cold Plasma Ionization: Located within the Pool Dehumidification Unit (PDU), this system disinfects and reduces VOC (volatile organic compound) levels in the air being recirculated in the indoor aquatic environment. This technology creates positive and negative ions, which are drawn to airborne particles due to their polarization, making them larger and increasing the effectiveness of filtration. In the same manner, they attach to pathogens such as viruses, bacteria, and mold spores, robbing and deactivating the hydrogen component of the pathogen creating a cleaner/safer environment. It also has additional air quality improvements such as odor control and reducing allergens. The use of the Cold Plasma system will also allow you to run your outside air at lower levels when conditions warrant it, saving energy.

System Balance:

Paddock Evacuator Technology is designed to complement the operation of the existing mechanical system. Upon installation of Evacuator Technology, the owner/operator should consult his servicing mechanical contractor to balance the existing mechanical system's exhaust rate with that of the Evacuator.

The Evacuator should run 24 hours per day, 365 days per year.

Balance Mechanical System:

- Chloramines are always produced and released into the air in aquatic facilities, even during unoccupied times.
- A recommended 0.05"—0.15" WC negative pressure must be always maintained in the natatorium air space. This keeps the "pool (corrosive air) in the pool (environment)".
- Maintain outdoor air introduction through the existing mechanical system as designed by a professional mechanical engineer and/or manufacturer's recommendations and at least the ASHRAE minimum outdoor air standard, unless otherwise specified.
- **Opening doors and windows are not recommended, as this can overload the mechanical equipment, interrupt the intended air flow patterns, and/or create an environment with bad (or worse) air conditioning.**
- Owner/operator may reduce exhaust air further in the existing mechanical system during off-hour / unoccupied times to recover energy costs as design allows. Technology now exists that allows facilities to run below ASHRAE minimum outdoor air volumes based on certain criteria.
- Reduce the exhaust rate of the existing mechanical system as required. In some cases, the exhaust fan(s) in the existing mechanical system may be shut down completely as Evacuator Technology may handle 100% of the required exhaust.
- Source-capture exhaust removes a much higher amount (percentage) of airborne chloramines and other disinfection by-products per CFM exhausted than conventional return exhaust.
- Turn off / disconnect supplementary exhaust fans in the space, per design. The majority of exhaust will typically be through the Evacuator, unless otherwise designed. Please check with your installer or the supplied drawings to verify this information.

Owners Responsibility & Suggested Operating Guidelines to Complement Evacuator Technology:

- Ensure Evacuator is running at all times: 24 hours per day, 365 days per year. If Evacuator is deemed to not be operational, contact Paddock or your local mechanical representative immediately.
- Reduce organics introduced into the pool area by enforcing aggressive patron hygiene and maintenance programs.
- Maintain pool water chemistry based on the guidelines provided above.
- Maintain Evacuator, Pool, & Mechanical System as outlined above for best results.
- Balance existing mechanical system to ensure a recommended 0.05"—0.15" WC negative pressure exists in the facility.
- Maintain existing mechanical system to ensure proper airflow and outdoor air introduction as designed per the facilities operating parameters.
- HVAC Maintenance Company / Mechanical Contractor is scheduled to provide routine maintenance as defined by the mechanical equipment manufacturer.
- **Preventative maintenance is the key!**