



Perimeter Overflow & Recirculation System Maintenance Manual

SAFETY &/or HAZARD INFORMATION

This bulletin includes important safety information that should be read by owners, managers, service personnel, and anyone in charge of the pool or pool area. Also, we suggest a copy be posted for quick reference.

1. Only personnel trained and familiar with the proper use of pool chemicals should handle acid, liquid chlorine or chlorine compounds. Chemicals should never be used when swimmers are in the pool. Acid and liquid chlorine should always be stored, carried, or handled in plastic containers.
2. If grating is a part of the perimeter system, it should be kept firmly clamped down and in good repair at all times. When a section of grating become loose or damaged that particular area must be immediately covered and a replacement of grating ordered. Under no circumstances should swimmers be allowed to use any portion of the perimeter that contains loose or damaged grating. Perimeter grating is not intended for foot traffic. Swimmers should be advised not to walk, stand, or jump on perimeter grates.
3. Ladders and grab rails are intended for the use of one swimmer at a time; they are not designed for handstands or other gymnastic stunts and they should not be used for this purpose. Ladder treads should be inspected regularly. If a tread becomes loose or damaged, the ladder should be taken out of service until repairs are made.
4. Lifeguard Chairs are intended for the individual use of trained "on duty" lifeguards, one (1) guard per chair. Lifeguard chairs are not to be used by swimmers, spectators, or by more than one (1) person at a time. There should be no diving from portable lifeguard chairs. Umbrellas should be closed or removed from portable lifeguard chairs during windy conditions. All frame connections are to be checked for tightness. The seat is bolted to the frame assembly. It is important to advise all users to periodically check to determine that the studs are firmly fastened to the seat and the nuts are tight. If they become loose or detached, it could result in serious injury. On outdoor installations or usage, it is suggested that the seat be removed and stored inside during the winter.
5. Starting Platforms should only be used by trained competitive swimmers or under the direct supervision of an instructor. Swimmers should execute shallow racing dives only. Impact with the pool bottom can cause severe injury. Starting platforms have warning labels and inform the purchaser of the need to remove the platforms during non-usage. If your starting platforms do not have warning labels, please contact the manufacturer immediately.
6. Bulkheads are designed and built for strength and safety. Any grating should be kept fully secured to avoid injury. **NO swimming under bulkhead. Never use bulkhead as a support or staging for equipment.** The bulkhead includes a compressor; please refer to owner's manual provided with the unit.

For questions concerning the usage of our equipment, please contact Paddock Pool Equipment Co., customer service.

Perimeter Overflow/Recirculation System

Refer to drawing(s)

Your low carbon stainless steel pool perimeter will require maintenance. See following:

- [Proper Care & Maintenance Guide of Stainless Steel Products](#)
- [GRATING - High Density Polyethylene \(HDPE\)](#)
- [Over-all Pool Maintenance](#)
- Check grating for loose or damaged area(s), see [Safety Information sheet # 2](#).
- Inspect all return inlets and plugs monthly. Replace any missing inlet(s) or damaged grating immediately, to prevent possible injury.
- **Gutter Trough system without return tube will not have return inlets or plugs.**

Maintenance for Integral Gutter / Deck Drain and/or Evacuator System (if applicable)

- The Evacuator (Extra Chamber) and/or Deck Drain system on your pool needs to be checked and cleaned regularly. For your HDPE Grating, follow [GRATING - High Density Polyethylene \(HDPE\)](#) page.
- Rinse with fresh water after cleaning the pool deck to ensure no dirt or debris is left on the surface on the grating.
- Large debris should not be washed into deck drain. The risk of poor drainage or drain blockage could create an issue of water pooling on the deck and become a hazard to pool staff and patrons.
- **Integral Gutter Evacuator System** See [Stainless Steel Products Care & Maintenance and Grating High Density Polyethylene \(HDPE\)](#).
- **The Evacuator should run 24 hours per day, 365 days per year.**

Owners Responsibility & Suggested Operating Guidelines to Complement Evacuator Technology:

- If Evacuator is deemed to not be operational, contact Paddock Pool Equipment Co. or your local mechanical representative immediately.
- Reduce organics introduced into the pool area by enforcing aggressive patron hygiene and maintenance programs.
- Maintain Evacuator, Pool water chemistry & Mechanical System as outlined above for best results.
- Maintain existing mechanical system to ensure proper airflow and outdoor air introduction as designed per the facilities operating parameters.

HVAC Maintenance Company / Mechanical Contractor is scheduled to provide routine maintenance as defined by the mechanical equipment manufacturer.

Preventative maintenance is the key!

Over-all Pool Maintenance

Pool

- Vacuum regularly to keep organics off pool bottom.
- Backwash to remove accumulating organics in the sand filters as recommended by manufacturer.
- Recharge regenerative media filters regularly to remove accumulated organics as recommended by manufacturer.

Pool Deck

- Wash down pool deck regularly to remove organics that are brought into the facility by patrons & guests, which are also produced as a result of facility use by patrons.
- Use non-oxidizing cleaning solutions to clean deck.
- Clean deck drains periodically to remove build-up of organics.

Pool Deck Equipment

- Rinse and clean deck equipment on a regular basis to remove build-up of organics and corrosive condensate from chloramines and Disinfectant By-Products (DBPs).
- Periodically wipe down stainless steel goods to remove caustic residue. Apply polish to stainless steel deck equipment, doors, water fountains, and any other fixtures that may be affected.

Patron Hygiene Program

- An effective patron hygiene program will greatly improve air and water quality, along with the staff and user experience.
- Post facility signage to encourage good personal hygiene program
- Swim Coaches can give swimmers breaks every 30 to 60 minutes. Urine is a major contributor to organic loading of a pool and a source of eye and skin irritation.
- Parents can schedule “out of pool” snack time that gives children a chance to use the restrooms.
- Facility Managers can schedule “Adult Only” swim time every hour.
- Everyone can help by encouraging showering and bathroom use before entering the pool, water park, spa, or any body of water within an aquatic facility.
- Maintain a “clean pool deck” policy: no street shoes, glass, food allowed on deck, etc.

Owners Responsibility & Suggested Operating Guidelines to Complement Evacuator Technology:

- Ensure Evacuator is running at all times: 24 hours per day, 365 days per year. If Evacuator is deemed to not be operational, contact Paddock or your local mechanical representative immediately.
- Reduce organics introduced into the pool area by enforcing aggressive patron hygiene and maintenance programs.
- Maintain pool water chemistry based on the health department guidelines.
- Maintain Evacuator, Pool, & Mechanical System as outlined above for best results.

Clean facilities are safer, more attractive, and provide a more enjoyable experience for all.