

Paddock Regenerative Preventative Maintenance

As for preventative maintenance on a Regenerative filter there are only a few things that are required. Depending on bather (number of people) load, make up water chemistry and whether a pool is indoor or outdoor. Each filter must be degreased and demineralized to prevent damage to internal elements and to prevent a decrease in filter effectiveness.

Degreaser should be done on a yearly schedule for indoor pools (normal usage) and 1-2 times a year on an outdoor pool based on hours of operation and bather load. An outdoor pool schedule is more frequent because of outside contaminants, body oils, lotions and sunscreens. Over time these “oils” will attach to Flex-tubes preventing media separation for Flex-tubes through coagulation of materials and decreased mechanical agitation during regeneration of media.

Demineralizer frequency is based on pool water and make up water chemistry. With a pool being located in a traditional hard-water area (high total alkalinity and calcium), mineral build up/scaling can occur on internal portions of filter decreasing filter effectiveness.

Media addition is also dependent on bather load, frequency of regeneration and frequency of degreasing/demineralizing. After regeneration the pressure differential should be less than 3-6 psi on a normally operating system. If pressure differential exceeds 10-12 psi “after regeneration”, then media has exceeded its holding capacity and will need to be replaced. Most pools change media about every 3-6 months. Most of the time it is not required, because it is a scheduled event not based on pressure differentials.

