California Closets - Exhibit D

COMMUNICATION TIMELINE AND CURE ATTEMPTS

This chronology records notice of the installation conditions, repair and inspection visits, and resolution discussions from November 2025 through March 18, 2026, followed by later steps and third-party records. Each entry refers to the preserved communications cited in its row. The communications reflect scheduling and access coordination for inspection and repair visits. Entries tagged ELEC record notice of electrical, outlet-access, and lighting conditions and the Company's response.

Key:
FIT = Fitment / measurement / dimensional issues
ELEC = Electrical / lighting / outlet access
SVC = Service / scheduling / repair follow-up
PAY = Payment dispute / collection efforts
RES = Resolution discussions / settlement terms
MGMT = Management / executive escalation

Date	Channel	Company Rep	Issue	Company Response	Status
Nov 7, 2025	In Person	Installation Team	FIT	Advised concerns would be addressed after installation completion	Open
Nov 10, 2025	In Person	Installation Team	FIT / ELEC	Advised the Designer would follow up; access issues referenced	Open
Nov 11, 2025	Email	Accounts Receivable / Finance	PAY	Final payment requested while work was incomplete **Record Ref. D1**	Disputed
Nov 13, 2025	Email	Designer	SVC	Requested scheduling for repair items **Record Ref. D2**	Pending

Date	Channel	Company Rep	Issue	Company Response	Status
Nov 14, 2025	Call / Email	Designer	SVC	Agreed to an in-person review **Record Ref. D2** **Record Ref. D3**	Scheduled
Nov 21, 2025	In Person	Designer	FIT / ELEC / SVC	Reviewed reported conditions; repair items identified. Designer stated that she sizes measurements down as a precaution. **Record Ref. D4** **Record Ref. G1**	No resolution documented
Dec 1, 2025	Email	Finance	PAY	Final payment requested again **Record Ref. D5**	Disputed
Dec 2, 2025	Text	Customer Service	SVC	Stated coordination with the Designer would occur **Record Ref. D6**	No resolution documented
Dec 18, 2025	Email	Finance / Designer	ELEC / PAY	Urgent lighting concerns submitted; no confirmation of corrective action received **Record Ref. D7**	No repair documented
Dec 19, 2025	Call / Text	Designer	SVC	Advised Customer Service would coordinate the repair **Record Ref. D3** **Record Ref. D7**	No resolution documented
Dec 23, 2025	Call	Designer	PAY / SVC	Final payment requested; stated the repair team would follow up **Record Ref. D3**	No follow-up call documented
Jan 9, 2026	Email	Finance	PAY	Past due payment notice issued **Record Ref. D8**	Disputed

Date	Channel	Company Rep	Issue	Company Response	Status
Jan 12, 2026	Call / Email	Finance	PAY / MGMT	Past due payment notice issued; dispute escalated internally after the Customer objected to the demand **Record Ref. D8**	Open
Jan 13, 2026	Text	Customer Service	SVC	Repair appointment scheduled **Record Ref. D10**	Scheduled
Jan 16, 2026	In Person	Repair Team	FIT / ELEC	Confirmed that measurement and access issues could not be corrected in place	Open
Jan 20, 2026	Email	Sales Manager	MGMT	Requested an in-person management review **Record Ref. D11**	Scheduled
Jan 30, 2026	In Person	Sales Manager	FIT / ELEC / MGMT	Reviewed the installed conditions on site and concluded that the gaps and blocked outlets could not be addressed without removal. **Record Ref. G2**	Open
Feb 5, 2026	Email	Sales Manager	RES / PAY	Revised proposal requested additional payment tied to replacement **Record Ref. D11**	Escalated
Feb 11, 2026	Email	Sales Manager	RES	Presented replacement, refund, or removal options **Record Ref. D11**	Under review
Feb 16, 2026	Email	Sales Manager	RES	Proposed revised liability terms limiting the Company's responsibility for damage and restoration **Record Ref. D11**	Declined
Feb 17, 2026	Email	Sales Manager	RES	Follow-up request for revised liability terms limiting responsibility for damage and restoration **Record Ref. D11**	Declined

Date	Channel	Company Rep	Issue	Company Response	Status
Feb 26, 2026	Email	Sales Manager	MGMT	Referred the matter to the CFO **Record Ref. D12**	Escalated
Feb 27, 2026	Email	CFO	RES	Customer's reply accepted removal and a refund and proposed removal language **Record Ref. D13**	Under review
Mar 3, 2026	Email	CFO	RES	Requested a call to conclude the matter **Record Ref. D14**	Scheduled
Mar 5, 2026	Email	CFO	RES	Call scheduled for March 6 **Record Ref. D15**	Scheduled
Mar 6, 2026	Call	CFO	RES	Resolution call; revised liability terms renewed **Record Ref. D16** **Record Ref. G3**	Not resolved
Mar 18, 2026	Email	CFO	RES / PAY	Withdrew the removal and refund proposal; stated the installation conformed to the signed contract and Plans; stated the Company had not been permitted access to complete the finish trim; requested the $9,545.00 balance within seven days **Record Ref. D17**	Withdrawn

STEPS AFTER MARCH 18, 2026

The Company's last written communication in the record is dated March 18, 2026.

Date	Event	Record
Mar 19 - May 6, 2026	Customer gathered project records and arranged an assessment of the outlet conditions by a licensed electrician	

Date	Event	Record
May 7, 2026	Licensed electrician assessed the installation	**Record Ref. B12**
May 18, 2026	Licensed electrician issued Quote #3497 for “Letter for client and dob permit and inspection”	**Supporting document**
May 25, 2026	Customer accepted Quote #3497 ($1,556.98, including tax)	**Supporting document**
Jun 19, 2026	Electrician’s written assessment issued: outlet design and placement would not pass a DOB inspection	**Record Ref. B12**
Jun 27, 2026	Licensed electrician requested the DOB final electrical inspection (Request REQ040750)	**Record Ref. B11**
Aug 6, 2026	NYC DOB Electrical Inspection No. 7571390 resulted in Fail-Final; receptacle concealed behind millwork and not accessible	**Record Ref. B11**
Aug 7 - Nov 10, 2026	Customer evaluated options for removal and restoration and prepared this notice	