



To be located on all DC junction boxes
and every 10' on DC conduit


**WARNING: PHOTOVOLTAIC
POWER SOURCE**
NEC 690.31(G)



DC Junction Box




Soladeck



NEC 690.56(C)(1)(A)



Service Disconnect



NEC 690.56(C)(1)(A)



DC Conduit

Main Service Panel



Utility
Meter
Socket



NEC 690.13(B)



Solar Meter Socket



690.56(C)(3)



NEC 690.13(B)



NEC 690.54




Photovoltaic
AC Disconnect



NEC 690.54



Load Center
(To Combine Inverters)



690.56(C)(3)



NEC 690.13(B)



NEC 690.4(B)



NEC 690.53



Inverter(s)



NEC 690.4(B)



NEC 690.53



DC Disconnect



NEC 690.13(B)



Enphase Envoy Box