



July 20, 2012

To whom it may concern,

This letter is to inform you of our method of protecting the module conductors on our ground mounted solar array. We install a non-metallic mesh on the back of our racking to create an area that is no longer "readily accessible". Please see picture below.

Respectfully,  
Kevin Kura

Trinity Solar  
Installation Manager



**Corporate Headquarters**

2211 Allenwood Rd.  
Wall, NJ 07719



Made with Earth-Friendly Products

**877-797-2978**

Ph: 732-780-3779

Fax: 732-780-6671

[www.TrinitySolarSystems.com](http://www.TrinitySolarSystems.com)