INSTALLATION OF NEW ROOF MOUNTED/ GROUND MOUNTED 11.96kW PV SYSTEM 194 PIERCE ROAD WEST BROOKFIELD, MA 01585

PIERCE ROAD

VICINITY MAP

SITE

GENERAL NOTES

IF ISSUED DRAWING IS MARKED WITH A REVISION CHARACTER OTHER THAN "A", PLEASE BE ADVISED THAT FINAL EQUIPMENT AND/OR SYSTEM CHARACTERISTICS ARE SUBJECT TO CHANGE DUE TO AVAILABLITY OF EQUIPMENT

GENERAL NOTES

- 1. THE INSTALLATION CONTRACTOR IS RESPONSIBLE FOR INSTALLING ALL EQUIPMENT AND FOLLOWING ALL DIRECTIONS AND INSTRUCTIONS CONTAINED IN THE DRAWING PACKAGE AND INFORMATION RECEIVED FROM TRINITY.
- 2. THE INSTALLATION CONTRACTOR IS RESPONSIBLE FOR INSTALLING ALL EQUIPMENT AND FOLLOWING ALL DIRECTIONS AND INSTRUCTION CONTAINED IN THE COMPLETE MANUAL
- 3. THE INSTALLATION CONTRACTOR IS RESPONSIBLE FOR READING AND LINDERSTANDING ALL DRAWINGS COMPONENT AND INVERTER MANUALS PRIOR TO INSTALLATION. THE INSTALLATION CONTRACTOR IS ALSO REQUIRED TO HAVE ALL COMPONENT SWITCHES IN THE OFF POSITION AND FUSES REMOVED PRIOR TO THE INSTALLATION OF ALL FUSES BEARING SYSTEM COMPONENTS.
- 4. ONCE THE PHOTOVOLTAIC MODULES ARE MOUNTED, THE INSTALLATION CONTRACTOR SHOULD HAVE A MINIMUM OF ONE ELECTRICIAN WHO HAS ATTENDED A SOLAR PHOTOVOLTAIC INSTALLATION COURSE ON SITE
- 5. FOR SAFETY, IT IS RECOMMENDED BY THE MANUFACTURE THAT THE INSTALLATION CREW ALWAYS HAVE A MINIMUM OF TWO PERSONS WORKING TOGETHER AND THAT EACH OF THE INSTALLATION CREW
 MEMBERS BE TRAINED IN FIRST AID AND
- 6. THIS SOLAR PHOTOVOLTAIC SYSTEM IS TO BE INSTALLED FOLLOWING THE CONVENTIONS OF THE NATIONAL ELECTRIC CODE. ANY LOCAL CODE WHICH MAY SUPERSEDE THE NEC SHALL GOVERN
- 7. ALL SYSTEM COMPONENTS TO BE INSTALLED WITH THIS SYSTEM ARE TO BE "UL" LISTED ALL FOUIPMENT WILL BE NEMA 3R OUTDOOR RATED UNLESS INDOORS.

GENERAL NOTES CONTINUED

- THE DC VOLTAGE FROM THE PANELS IS ALWAYS PRESENT AT THE DC DISCONNECT ENCLOSURE AND THE DC TERMINALS OF THE INVERTER DURING DAYLIGHT HOURS ALL PERSONS WORKING ON OR INVOLVED WITH THE PHOTOVOLTAIC SYSTEM ARE WARNED THAT THE SOLAR MODULES ARE **ENERGIZED WHENEVER THEY ARE** EXPOSED TO LIGHT.
- ALL PORTIONS OF THIS SOLAR PHOTOVOLTAIC SYSTEM SHALL BE MARKED CLEARLY IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE ARTICLE
- PRIOR TO THE INSTALLATION OF THIS PHOTOVOLTAIC SYSTEM THE INSTALLATION CONTRACTOR SHALL ATTEND A PRE-INSTALLTION MEETING FOR THE REVIEW OF THE INSTALLATION PROCEDURES, SCHEDULES, SAFETY AND COORDINATION.
- PRIOR TO THE SYSTEM START UP THE INSTALLATION CONTRACTOR SHALL ASSIST IN PERFORMING ALL INITIAL HARDWARE CHECKS AND DC WIRING CONDUCTIVITY CHECKS.
- FOR THE PROPER MAINTENANCE AND ISOLATION OF THE INVERTS REFER TO THE ISOLATION PROCEDURES IN THE
- THE LOCATION OF PROPOSED ELECTRIC AND TELEPHONE UTILITIES ARE SUBJECT APPROPRIATE UTILITY COMPANIES AND OWNERS.
- ALL MATERIALS, WORKMANSHIP AND CONSTRUCTION FOR THE SITE IMPROVEMENTS SHOWN HEREIN SHALL BE IN ACCORDANCE WITH:
 - A) CURRENT PREVAILING MUNICIPAL AND/OR COUNTY SPECIFICATIONS STANDARDS AND REQUIREMENTS

GENERAL NOTES CONTINUED

- B) CURRENT PREVAILING UTILITY COMPANY SPECIFICATIONS. STANDARDS, AND REQUIREMENTS THIS SET OF PLANS HAVE BEEN PREPARED FOR THE PURPOSE OF
- MUNICIPAL AND AGENCY REVIEW AND APPROVAL. THIS SET OF PLANS SHALL NOT BE UTILIZED AS CONSTRUCTION DRAWINGS UNTIL REVISED TO INDICATE "ISSUED FOR CONSTRUCTION"
- ALL INFORMATION SHOWN MUST BE CERTIFIED PRIOR TO USE FOR CONSTRUCTION ACTIVITIES

ABBREVIATIONS

- AMP AMPERE ALTERNATING CURRENT AMP FRAME ABOVE FINISHED FLOOR ABOVE FINISHED GRADE
- AMERICAN WIRE GAUGE CONDUIT (GENERIC TERM OF RACEWAY, PROVIDE AS SPECIFIED)
- COMBINER BOX CIRCUIT CURRENT TRANSFORMER
- COPPER DIRECT CURRENT DISCONNECT SWITCH DWG DRAWING
- ELECTRICAL SYSTEM INSTALLER ELECTRICAL METALLIC TUBING FUSIBLE SWITCH FUSE
- GROUND GFI GROUND FAULT INTERRUPTER FREQUENCY (CYCLES PER

ABBREVIATIONS CONTINUED

- JUNCTION BOX THOUSAND CIRCULAR MILS KILO-VOLT AMPERE kVA KILO-WATT kWH KILO-WATT HOUR
- MCB MAIN CIRCUIT BREAKER MDP MAIN DISTRIBUTION PANEL MLO MAIN LUG ONLY
- MOUNTED MTG MOUNTING NEUTRAL
- NATIONAL ELECTRICAL CODE NIC NO# NOT IN CONTRACT
- NUMBER OVER CURRENT PROTECTION
- POLF. PULL BOX
- PHASE PVC POLY-VINYL CHLORIDE CONDUIT POWER
- QTY QUANTITY RGS RIGID GALVANIZED STEEL
- SOLID NEUTRAL JSWBD SWITCHBOARD TYPICAL
- UNLESS OTHERWISE INDICATED WEATHERPROOF TRANSFORMER
 - MOUNT 72 INCHES TO BOTTOM OF ABOVE FINISHED FLOOR OR



SATELLITE VIEW
SCALE: NTS

SHEET INDEX

- PV-1 COVER SHEET W/ SITE INFO & NOTES
- PV-2 LAYOUT PLAN W/ MODULE LOCATIONS
- PV-3 STRUCTURAL DETAILS
- PV-4 ELECTRICAL 3 LINE DIAGRAM



Issued / Revisions DESCRIPTION DATE

Project Title:

RODEEN, ADAM

TRINITY ACCT # 2015-74913

194 PIERCE ROAD WEST BROOKFIELD. MA 01585

Drawing Title:

Proiect Address:

PROPOSED 11.96kW SOLAR SYSTEM

Drawing Information DRAWING DATE 2/26/2016 DRAWN BY: REVISED BY:


System Information: OTAL SYSTEM SIZE: 11.96kW TOTAL MODULE COUNT: MODULES USED: TRINA 260 MODULE SPEC #: TSM-260 PD05.08 UTILITY COMPANY NAT'L GRID UTILITY ACCT #: 63021 50014 UTILITY METER #: 30931144

Rev. No.

Sheet



2211 Allenwood Road Wall, New Jersey 07719



INDICATES NEW INVERTER TO BE

REFER TO EQUIPMENT SCHEDULE FOR SPECS.

INSTALLED OUTSIDE

INDICATES NEW MAIN DISCONNECT TO BE GROUPED WITH MAIN PANEL

Issued / Revisions		
P1	ISSUED TO TOWNSHIP FOR PERMIT	2/26/2016
NO.	DESCRIPTION	DATE

RODEEN, ADAM

TRINITY ACCT #: 2015-74913

Project Address:

194 PIERCE ROAD WEST BROOKFIELD, MA 01585

Drawing Title:

PROPOSED 11.96kW SOLAR SYSTEM

Drawing Information DRAWING DATE 2/26/2016 DRAWN BY: REVISED BY:


System Information: TOTAL SYSTEM SIZE: 11.96kW TOTAL MODULE COUNT: MODULES USED: TRINA 260 MODULE SPEC #: TSM-260 PD05.08 UTILITY COMPANY: NAT'L GRID UTILITY ACCT #: 63021 50014 UTILITY METER #: 30931144 DEAL TYPE: MOSAIC

Sheet




2211 Allenwood Road Wall, New Jersey 07719


www.Trinity-Solar.com











Drawing Information

DRAWING DATE: 2/26/2016

DRAWN BY: JC

System Information:

System Information:

TOTAL SYSTEM SIZE: 11.96kW

TOTAL MODULE COUNT: 46

MODULES USED: TRINA 260

MODULE SPEC #: TSM-260 PD05.08

UTILITY COMPANY: NAT'L GRID

UTILITY ACCT #: 63021 50014

UTILITY METER #: 30931144

DEAL TYPE: MOSAIC

Rev. No.


PV - 3

Sheet



2211 Allenwood Road Wall, New Jersey 07719

877-797-2978 www.Trinity-Solar.com



NEC 690.64

ARRAY CIRCUIT WIRING NOTES 1.) LICENSED ELECTRICIAN ASSUMES ALL RESPONSIBILITY FOR DETERMINING ONSITE CONDITIONS AND EXECUTING INSTALLATION IN ACCORDANCE WITH NEC 2014

- 2.) LOWEST EXPECTED AMBIENT TEMPERATURE BASED ON ASHRAE MINIMUM MEAN EXTREME DRY BULB TEMPERATURE FOR ASHRAE LOCATION MOST SIMILAR TO INSTALLATION LOCATION. LOWEST EXPECTED AMBIENT TEMP = -16°C
- 3.) HIGHEST CONTINUOUS AMBIENT TEMPERATURE BASED ON ASHRAE HIGHEST MONTH 2% DRY BULB TEMPERATURE FOR ASHRAE LOCATION MOST SIMILAR TO INSTALLATION LOCATION. HIGHEST CONTINUOUS TEMP = 33°C
- 4.) 2005 ASHRAE FUNDAMENTALS 2% DESIGN TEMPERATURES DO NOT EXCEED 47°C IN THE UNITED STATES (PALM SPRINGS, CA IS 44.1°C). FOR LESS THAN 9 CURRENT-CARRYING CONDUCTORS IN A ROOF-MOUNTED SUNLIT CONDUIT AT LEAST 0.5" ABOVE ROOF AND USING THE OUTDOOR DESIGN TEMPERATURE OF 47°C OR LESS (ALL OF UNITED STATES)
- 5.) PHOTOVOLTAIC POWER SYSTEMS SHALL BE PERMITTED TO OPERATE WITH UNGROUNDED PHOTOVOLTAIC SOURCE AND OUTPUT CIRCUIT AS PER NEC 690.35
- 6.) ALL EQUIPMENT INSTALLED OUTDOORS SHALL HAVE A NEMA 3R RATING.
- 7.) ALL SOLAR SYSTEM LOAD CENTERS TO CONTAIN ONLY GENERATION CIRCUITS AND NO UNUSED POSITIONS OR

CALCULATIONS FOR CURRENT CARRYING CONDUCTORS REQUIRED CONDUCTOR AMPACITY PER STRING [NEC 690.8(B)(1)]: (15.00*1.25)3 = 56.25A

AWG #6, DERATED AMPACITY AMBIENT TEMP: 55°C, TEMP DERATING FACTOR: .76 RACEWAY DERATING = 2 CCC: 1.00 (75*.76)1.00 = 57.00A

57.00A [>] 56.25A, THEREFORE WIRE SIZE IS VALID

TOTAL AC REQUIRED CONDUCTOR AMPACITY 42.00A*1.25 = 52.50A

AWG #6, DERATED AMPACITY AMBIENT TEMP: 30°C, TEMP DERATING: 1.0 RACEWAY DERATING 5 3 CCC: N/A

75A - 52.50A, THEREFORE AC WIRE SIZE IS VALID

CALCULATION FOR PV OVERCURRENT PROTECTION TOTAL INVERTER CURRENT: 42.00A 42.00A*1.25 = 52.50A


--> 60A OVERCURRENT PROTECTION IS VALID

GFCI RECEPTACLE 1p15A BREAKER EXISTING 14/2 NM CABLE 120/240V 200A MAIN BREAKER UŤILITY 200A BUSBAR METER LOCKABLE 60A DISCONNECT FUSED W/ 60A FUSES GROUPED W/ MAIN 60A UNFUSED PRODUCTION BREAKER LOAD CENTER DISCONNECT **INVERTER #1** OOOOO G В **(A)** SQUARE D PN: D222N SQUARE D EXISTING MAIN BREAKER LOAD DU222NRB CENTER INSULATED LINE TAPS INSTALLED ON MAIN FEEDERS

	PV MODULE SPECIFICATIONS	
	TRINA 260 (TSM-260 PD05.08)	
Imp		8.5
Vmp		30.6
Voc		38.2
Isc		9

	INVERTER #1 - SE10000A-US			
DC			AC	
Imp	30.5	Pout	10000	
Vmp	350	lout	42	
Voc	500	Imax	52.5	
Isc	45	Vnom	240	

А	#6 THWN-2 GEC TO EXISTING GROUND ROD	G	3/4" FMC W/ 3-#6 THWN-2, 1-#8 THWN-2 GROUND
В	3/4" EMT W/ 2-#6 THWN-2, 1-#10 THWN-2, 1-#10 THWN-2 GROUND	н	1" PVC W/ 4-#10 THWN-2, 1-#10 THWN-2 GROUND (TRENCHED APPROX. 150')
С	3/4" EMT W/ 2-#6 THWN-2, 1-#10 THWN-2 GROUND	ı	3/4" EMT W/ 6-#10 THWN-2, 1-#10 THWN-2 GROUND
D	3/4" EMT W/ 4-#10 THWN-2, 1-#10 THWN-2 GROUND		
Ε	3/4" EMT W/ 2-#6 THWN-2, 1-#10 THWN-2, 1-#10 THWN-2 GROUND		
F	#12 PV WIRE W/ #6 BARE COPPER BOND TO ARRAY		



Project Title:

RODEEN, ADAM

TRINITY ACCT #: 2015-74913

Project Address:

194 PIERCE ROAD WEST BROOKFIELD, MA 01585

Drawing Title:

PROPOSED 11.96kW SOLAR SYSTEM

Drawing Information		
DRAWING DATE:	2/26/2016	
DRAWN BY:	JC	
REVISED BY:		

System Information:	
TOTAL SYSTEM SIZE:	11.96kW
TOTAL MODULE COUNT:	46
MODULES USED:	TRINA 260
MODULE SPEC #:	TSM-260 PD05.08
UTILITY COMPANY:	NAT'L GRID
UTILITY ACCT #:	63021 50014
UTILITY METER #:	30931144
DEAL TYPE:	MOSAIC



Sheet



2211 Allenwood Road Wall, New Jersey 07719 www.Trinity-Solar.com