INSTALLATION OF NEW GROUND MOUNTED 20.8kW PV SYSTEM **102 EAST DELAWARE AVENUE** LANDISVILLE, NJ 08326

GENERAL NOTES

IF ISSUED DRAWING IS MARKED WITH A REVISION CHARACTER OTHER THAN "A", PLEASE BE ADVISED THAT FINAL EQUIPMENT AND/OR SYSTEM CHARACTERISTICS ARE SUBJECT TO CHANGE DUE TO AVAILABLITY OF EQUIPMENT.

GENERAL NOTES

- 1. THE INSTALLATION CONTRACTOR IS RESPONSIBLE FOR INSTALLING ALL EQUIPMENT AND FOLLOWING ALL DIRECTIONS AND INSTRUCTIONS CONTAINED IN THE DRAWING PACKAGE AND INFORMATION RECEIVED FROM TRINITY.
- 2. THE INSTALLATION CONTRACTOR IS RESPONSIBLE FOR INSTALLING ALL EQUIPMENT AND FOLLOWING ALL DIRECTIONS AND INSTRUCTION CONTAINED IN THE COMPLETE MANUAL
- 3. THE INSTALLATION CONTRACTOR IS RESPONSIBLE FOR READING AND LINDERSTANDING ALL DRAWINGS COMPONENT AND INVERTER MANUALS PRIOR TO INSTALLATION. THE INSTALLATION CONTRACTOR IS ALSO REQUIRED TO HAVE ALL COMPONENT SWITCHES IN THE OFF POSITION AND FUSES REMOVED PRIOR TO THE INSTALLATION OF ALL FUSES BEARING SYSTEM COMPONENTS.
- ONCE THE PHOTOVOLTAIC MODULES ARE MOUNTED, THE INSTALLATION CONTRACTOR SHOULD HAVE A MINIMUM OF ONE ELECTRICIAN WHO HAS ATTENDED A SOLAR PHOTOVOLTAIC INSTALLATION COURSE ON SITE
- 5. FOR SAFETY, IT IS RECOMMENDED BY THE MANUFACTURE THAT THE INSTALLATION CREW ALWAYS HAVE A MINIMUM OF TWO PERSONS WORKING TOGETHER AND THAT EACH OF THE INSTALLATION CREW
 MEMBERS BE TRAINED IN FIRST AID AND
- 6. THIS SOLAR PHOTOVOLTAIC SYSTEM IS TO BE INSTALLED FOLLOWING THE CONVENTIONS OF THE NATIONAL ELECTRIC CODE. ANY LOCAL CODE WHICH MAY SUPERSEDE THE NEC SHALL GOVERN
- 7. ALL SYSTEM COMPONENTS TO BE INSTALLED WITH THIS SYSTEM ARE TO BE "UL" LISTED ALL FOUIPMENT WILL BE NEMA 3R OUTDOOR RATED UNLESS INDOORS.

GENERAL NOTES CONTINUED

- THE DC VOLTAGE FROM THE PANELS IS ALWAYS PRESENT AT THE DC DISCONNECT ENCLOSURE AND THE DC TERMINALS OF THE INVERTER DURING DAYLIGHT HOURS ALL PERSONS WORKING ON OR INVOLVED WITH THE PHOTOVOLTAIC SYSTEM ARE WARNED THAT THE SOLAR MODULES ARE **ENERGIZED WHENEVER THEY ARE** EXPOSED TO LIGHT.
- ALL PORTIONS OF THIS SOLAR PHOTOVOLTAIC SYSTEM SHALL BE MARKED CLEARLY IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE ARTICLE
- PRIOR TO THE INSTALLATION OF THIS PHOTOVOLTAIC SYSTEM THE INSTALLATION CONTRACTOR SHALL ATTEND A PRE-INSTALLTION MEETING FOR THE REVIEW OF THE INSTALLATION PROCEDURES, SCHEDULES, SAFETY AND COORDINATION.
- PRIOR TO THE SYSTEM START UP THE INSTALLATION CONTRACTOR SHALL ASSIST IN PERFORMING ALL INITIAL HARDWARE CHECKS AND DC WIRING CONDUCTIVITY CHECKS.
- FOR THE PROPER MAINTENANCE AND ISOLATION OF THE INVERTS REFER TO THE ISOLATION PROCEDURES IN THE
- THE LOCATION OF PROPOSED ELECTRIC AND TELEPHONE UTILITIES ARE SUBJECT APPROPRIATE UTILITY COMPANIES AND OWNERS.
- ALL MATERIALS, WORKMANSHIP AND CONSTRUCTION FOR THE SITE IMPROVEMENTS SHOWN HEREIN SHALL BE IN ACCORDANCE WITH:
 - A) CURRENT PREVAILING MUNICIPAL AND/OR COUNTY SPECIFICATIONS STANDARDS AND REQUIREMENTS

GENERAL NOTES CONTINUED

- B) CURRENT PREVAILING UTILITY COMPANY SPECIFICATIONS. STANDARDS, AND REQUIREMENTS THIS SET OF PLANS HAVE BEEN
- PREPARED FOR THE PURPOSE OF MUNICIPAL AND AGENCY REVIEW AND APPROVAL. THIS SET OF PLANS SHALL NOT BE UTILIZED AS CONSTRUCTION DRAWINGS UNTIL REVISED TO INDICATE "ISSUED FOR CONSTRUCTION".
- ALL INFORMATION SHOWN MUST BE CERTIFIED PRIOR TO USE FOR CONSTRUCTION ACTIVITIES

ABBREVIATIONS

AMP

GND

ALTERNATING CURRENT AMP FRAME ABOVE FINISHED FLOOR ABOVE FINISHED GRADE AMERICAN WIRE GAUGE

AMPERE

CONDUIT (GENERIC TERM OF RACEWAY, PROVIDE AS SPECIFIED) COMBINER BOX

CIRCUIT CURRENT TRANSFORMER CU COPPER DIRECT CURRENT DISCONNECT SWITCH

DWG DRAWING ELECTRICAL SYSTEM INSTALLER FMT ELECTRICAL METALLIC TUBING FUSIBLE SWITCH FUSE

GROUND GFI GROUND FAULT INTERRUPTER FREQUENCY (CYCLES PER

ABBREVIATIONS CONTINUED

JUNCTION BOX THOUSAND CIRCULAR MILS KILO-VOLT AMPERE kVA KILO-WATT kWH KILO-WATT HOUR MCB MAIN CIRCUIT BREAKER

MDP MAIN DISTRIBUTION PANEL MLO MAIN LUG ONLY MOUNTED MTG

MOUNTING NEUTRAL NATIONAL ELECTRICAL CODE NIC NO# NOT IN CONTRACT

NUMBER OVER CURRENT PROTECTION

OCP P POLF. PULL BOX PHASE

PVC POLY-VINYL CHLORIDE CONDUIT POWER


QTY QUANTITY RGS RIGID GALVANIZED STEEL SOLID NEUTRAL

JSWBD SWITCHBOARD TYPICAL UNLESS OTHERWISE INDICATED

WEATHERPROOF TRANSFORMER

MOUNT 72 INCHES TO BOTTOM OF ABOVE FINISHED FLOOR OR

EAST DELAWARE AVENUE •



VICINITY MAP

SITE

APPROVED

By DESIGN DEPARTMENT at 12:11 pm, Feb 11, 2016



SATELLITE VIEW


SHEET INDEX

PV-1 COVER SHEET W/ SITE INFO & NOTES

PV-2 LAYOUT PLAN W/ MODULE LOCATIONS

PV-3 ELECTRICAL 3 LINE DIAGRAM

Engineer / License Holder:



Issued / Revisions			
R1	CONSTRUCTION DWG	2/11/2016	
P1	ISSUED TO TOWNSHIP FOR PERMIT	9/21/2015	
NO.	DESCRIPTION	DATE	

Project Title:

DROGO, TERI- (SYSTEM #1) TRINITY ACCT #: 2015-62193

Proiect Address:

102 EAST DELAWARE AVENUE LANDISVILLE. NJ 08326

Drawing Title:

PROPOSED 20.8kW SOLAR SYSTEM

Drawing Information		
DRAWING DATE:	9/21/2015	
DRAWN BY:	JC	
REVISED BY:	JES	

System Information:		
TOTAL SYSTEM SIZE:	20.8kW	
TOTAL MODULE COUNT:	80	
MODULES USED:	TRINA 260	
MODULE SPEC #:	TSM-260 PD05.08	
UTILITY COMPANY:	ACE	
UTILITY ACCT #:	55004665489	
UTILITY METER #:	99G053668270	
DEAL TYPE:	SUNNOVA	






Sheet




2211 Allenwood Road Wall, New Jersey 07719 www.Trinity-Solar.com



INSTALLED OUTSIDE.
REFER TO EQUIPMENT SCHEDULE FOR SPECS.

Engineer / License Holder:



Issued / Revisions			
R1	CONSTRUCTION DWG	2/11/2016	
P1	ISSUED TO TOWNSHIP FOR PERMIT	9/21/2015	
NO.	DESCRIPTION	DATE	

DROGO, TERI- (SYSTEM #1)

TRINITY ACCT #: 2015-62193

Project Address:

102 EAST DELAWARE AVENUE LANDISVILLE, NJ 08326

Drawing Title:

PROPOSED 20.8kW SOLAR SYSTEM

Drawing Information			
DRAWING DATE: 9/21/2015			
DRAWN BY:	JC .		
REVISED BY:	JES		

20.8kW
80
TRINA 260
TSM-260 PD05.08
ACE
55004665489
99G053668270
SUNNOVA


Rev.	No.	
(R	_
`		

Sheet




2211 Allenwood Road Wall, New Jersey 07719


877-797-2978 www.Trinity-Solar.com











DATE

9/21/2015

JES

20.8kW

TRINA 260

55004665489

SUNNOVA


Sheet

www.Trinity-Solar.com

2211 Allenwood Road Wall, New Jersey 07719

99G053668270

TSM-260 PD05.08



ARRAY CIRCUIT WIRING NOTES

COMPLIES WITH 2011 NEC

- 1.) LOWEST EXPECTED AMBIENT TEMPERATURE BASED ON ASHRAE MINIMUM MEAN EXTREME DRY BULB TEMPERATURE FOR ASHRAE LOCATION MOST SIMILAR TO INSTALLATION LOCATION. LOWEST EXPECTED AMBIENT
- 2.) HIGHEST CONTINUOUS AMBIENT TEMPERATURE BASED ON ASHRAE HIGHEST MONTH 2% DRY BULB TEMPERATURE FOR ASHRAE LOCATION MOST SIMILAR TO INSTALLATION LOCATION. HIGHEST CONTINUOUS TEMP =
- 3.) 2005 ASHRAE FUNDAMENTALS 2% DESIGN TEMPERATURES DO NOT EXCEED 47°C IN THE UNITED STATES (PALM SPRINGS, CA IS 44.1°C). FOR LESS THAN 9 CURRENT-CARRYING CONDUCTORS IN A ROOF-MOUNTED SUNLIT CONDUIT AT LEAST 0.5" ABOVE ROOF AND USING THE OUTDOOR DESIGN TEMPERATURE OF 47°C OR LESS (ALL OF UNITED STATES),
- 4.) PHOTOVOLTAIC POWER SYSTEMS SHALL BE PERMITTED TO OPERATE WITH UNGROUNDED PHOTOVOLTAIC SOURCE AND OUTPUT CIRCUIT AS PER
- 5.) ALL EQUIPMENT INSTALLED OUTDOORS SHALL HAVE A NEMA 3R RATING.

CALCULATIONS FOR CURRENT CARRYING

CONDUCTORS
REQUIRED CONDUCTOR AMPACITY PER STRING [NEC 690.8(B) (1)]: (15.00*1.25)3 = 56.25A

AWG #6, DERATED AMPACITY AMBIENT TEMP: 55°C, TEMP DERATING FACTOR: .76
RACEWAY DERATING = 2 CCC: 1.00 (75*.76)1.00 = 57.00A

57.00A ≥ 56.25A, THEREFORE WIRE SIZE IS VALID


TOTAL AC REQUIRED CONDUCTOR AMPACITY 67.00A*1.25 = 83.75A

AWG #4, DERATED AMPACITY
AMBIENT TEMP: 30°C, TEMP DERATING: 1.0
RACEWAY DERATING ≤ 3 CCC: N/A 95A*1.0 = 95A

95A = 83.75A, THEREFORE AC WIRE SIZE IS VALID

CALCULATION FOR PV OVERCURRENT PROTECTION TOTAL INVERTER CURRENT: 67.00A

67.00A*1.25 = 83.75A --> 90A OVERCURRENT PROTECTION IS VALID





PV MODULE SPECIFICATIONS		
TRINA 260 (TSM-260 PD05.08)		
Imp 8.5		8.5
Vmp		30.6
Voc		38.2
Isc		9

INVERTER #1 - SE10000A-US				
	DC		AC	
Imp	30.5	Pout	10000	
Vmp	350	lout	42	
Voc	500	Imax	52.5	
Isc	45	Vnom	240	

	INVERTER	#2 - SE6000A-	-US
DC			AC
Imp	18	Pout	6000
Vmp	350	lout	25
Voc	500	Imax	31.25
Isc	30	Vnom	240

Α	#6 THWN-2 GEC TO EXISTING GROUND ROD	G	3/4" EMT W/ 2-#8 THWN-2, 1-#10 THWN-2, 1-#10 THWN-2 GROUND
В	1" EMT W/ 2-#4 THWN-2, 1-#8 THWN-2, 1-#8THWN-2 GROUND	Η	#12 PV WIRE W/ #8 BARE COPPER BOND TO MODULES AND RAILS
С	3/4" EMT W/ 2-#6 THWN-2, 1-#10 THWN-2 GROUND	_	1" FMC W/ 3-#4 THWN-2, 1-#8 THWN-2 GROUND
D	3/4" EMT W/ 6-#10 THWN-2, 1-#10 THWN-2 GROUND	J	1 1/2" PVC W/ 2-2/0 THWN-2, 1-#1 THWN-2, 1-#1 THWN-2 GROUND (CONDUIUT TO BE TRENCHED APPROX. 270')
E	3/4" EMT W/ 4-#10 THWN-2, 1-#10 THWN-2 GROUND		
F	3/4" EMT W/ 2-#6 THWN-2, 1-#10 THWN-2, 1-#10 THWN-2 GROUND		





	Issued / Revisions			
R1	CONSTRUCTION DWG	2/11/2016		
P1	ISSUED TO TOWNSHIP FOR PERMIT	9/21/2015		
NO.	DESCRIPTION	DATE		

Project Title:

DROGO, TERI- (SYSTEM #1)

TRINITY ACCT #: 2015-62193

Project Address:

102 EAST DELAWARE AVENUE LANDISVILLE, NJ 08326

Drawing Title:

PROPOSED 20.8kW SOLAR SYSTEM

Drawing Information	
DRAWING DATE:	9/21/2015
DRAWN BY:	JC
REVISED BY:	JES

System Information:		
TOTAL SYSTEM SIZE:	20.8kW	
TOTAL MODULE COUNT:	80	
MODULES USED:	TRINA 260	
MODULE SPEC #:	TSM-260 PD05.08	
UTILITY COMPANY:	ACE	
UTILITY ACCT #:	55004665489	
UTILITY METER #:	99G053668270	
DEAL TYPE:	SUNNOVA	



PV - 4

Sheet



2211 Allenwood Road Wall, New Jersey 07719

877-797-2978 www.Trinity-Solar.com