IMONI ASSEMBLY TEST REPORT

Report No:	iMoni-SRMS-0586				
Assembly Sr. No.	TTiMGPH26000K210				
DateTime:	09-09-2026 15:00:00				
TestLevel:	iMoni Assembly				
DeviceIP:	192.168.0.123	CPU Sr. No.	Base PCB Sr. No.	Camera Sr. No.	PSU Sr. No.
TotalTests:	16	373	171	182	LB/F/26/9204

Sr. No.	TestName	Status	Total Checks	Reason	Remarks
1	Visual Test	PASSED		Visual inspection passed successfully	
2	Burn-In Test	PASSED		Burn-In test passed successfully	
3	Fan Test	PASSED	9		
4	Limit Switch Test	PASSED	3		
5	Fire Alarm Test	PASSED	3		
6	Water Leakage Test	PASSED	3		
7	EM Lock through Keypad	PASSED	3		
8	EM Lock through eMS	PASSED	3		
9	Water Logging Test	PASSED	3		
10	Humidity Test	PASSED	1		
11	Inside Temperature Test	PASSED	1		
12	Outside Temperature Test	PASSED	1		
13	Non - Critical Load Test	PASSED	3		
14	Camera Test	PASSED	1		
15	Fan-Fail Test Test	PASSED	2		
16	HUPS	PASSED	1		

OPERATOR:		APPROVED BY:	