IMONI ASSEMBLY TEST REPORT					
Report No:	iMoni-SRMS-0603				
Assembly Sr. No.	TTiMGPH26000K216				
DateTime:	09-09-2026 16:40:00				
TestLevel:	iMoni Assembly				
DeviceIP:	192.168.0.133	CPU Sr. No.	Base PCB Sr. No.	Camera Sr. No.	PSU Sr. No.
TotalTests:	16	133	193	124	LB/F/26/9232

Sr. No.	TestName	Status	Total Checks	Reason	Remarks
1	Visual Test	PASSED		Visual inspection passed successfully	
2	Burn-In Test	PASSED		Burn-In test passed successfully	
3	Fan Test	PASSED	9		
4	Limit Switch Test	PASSED	3		
5	Fire Alarm Test	PASSED	3		
6	Water Leakage Test	PASSED	3		
7	EM Lock through Keypad	PASSED	3		
8	EM Lock through eMS	PASSED	3		
9	Water Logging Test	PASSED	3		
10	Humidity Test	PASSED	1		
11	Inside Temperature Test	PASSED	1		
12	Outside Temperature Test	PASSED	1		
13	Non - Critical Load Test	PASSED	3		
14	Camera Test	PASSED	1		
15	Fan-Fail Test Test	PASSED	2		
16	HUPS	PASSED	1		
OPERATOR:			APPROVED BY:		