# IMONI ASSEMBLY TEST REPORT

| | | | | | |
|---|---|---|---|---|---|
| Report No: | iMoni-SRMS-0756 | | | | |
| Assembly Sr. No. | TTiMGPH26000K252 | | | | |
| DateTime: | 10-09-2026 15:20:00 | | | | |
| TestLevel: | iMoni Assembly | | | | |
| DeviceIP: | 192.168.0.51 | CPU Sr. No. | Base PCB Sr. No. | Camera Sr. No. | PSU Sr. No. |
| TotalTests: | 16 | 301 | 191 | 197 | LB/F/26/9127 |

| Sr. No. | TestName | Status | Total Checks | Reason | Remarks |
|---|---|---|---|---|---|
| 1 | Visual Test | PASSED | | Visual inspection passed successfully | |
| 2 | Burn-In Test | PASSED | | Burn-In test passed successfully | |
| 3 | Fan Test | PASSED | 9 | | |
| 4 | Limit Switch Test | PASSED | 3 | | |
| 5 | Fire Alarm Test | PASSED | 3 | | |
| 6 | Water Leakage Test | PASSED | 3 | | |
| 7 | EM Lock through Keypad | PASSED | 3 | | |
| 8 | EM Lock through eMS | PASSED | 3 | | |
| 9 | Water Logging Test | PASSED | 3 | | |
| 10 | Humidity Test | PASSED | 1 | | |
| 11 | Inside Temperature Test | PASSED | 1 | | |
| 12 | Outside Temperature Test | PASSED | 1 | | |
| 13 | Non - Critical Load Test | PASSED | 3 | | |
| 14 | Camera Test | PASSED | 1 | | |
| 15 | Fan-Fail Test Test | PASSED | 2 | | |
| 16 | HUPS | PASSED | 1 | | |

| | | | |
|---|---|---|---|
| OPERATOR: | | APPROVED BY: | |