

3MWh BESS Storage System

Revision: v2.1

Verdict: AMBER

Design is feasible but cost overruns are present. Needs active HVAC for 25degC baseline. Note: target prove-nance: CATL website.

Modules

Name	Mass	Cost
Lithium-Ion Battery Racks	25000.0 kg	£120,000
Grid-scale Inverter System	1500.0 kg	£45,000
Thermal Management (HVAC)	800.0 kg	£15,000
Fire Suppression (NOVEC)	200.0 kg	£8,000

Bill of Materials

Part Number	Material
BAT-LFP-280AH	LFP Cell
INV-SIC-1MW	SiC Module
CAB-ISO-40FT	Cor-Ten Steel

Suppliers

Name	Match Score
CATL	98%
SMA Solar Technology	92%
Trane Technologies	85%