BMP Inspection and Maintenance Log

TRPA Stormwater Management Program | BMP Hotline (775) 589-5202 | bmp@trpa.gov

Property

APN

Owner or manager name

Property address

Contact phone and email

Land use (single-family, multi-family, commercial)

Date of this inspection

BMP inspection and maintenance is necessary to keep BMPs functioning and to keep a BMP Certificate active. Inspect each BMP on the property after major storms and at least twice a year, in spring after snowmelt and in fall before Oct. 15. Check the box next to each BMP type present on the property, answer each question, and note the location and any corrective action. Keep this log on file; commercial and multi-family owners submit it with photos and invoices so TRPA can reissue the certificate with a new date. Refer to the BMP Handbook for each practice.

☐ 1. Gravel Infiltration System (trench, drywell)

Chapter 4.1-c

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is stormwater from impervious surfaces conveyed to and captured by the infiltration trench?	☐	☐		
Is compaction minimal?	☐	☐		
Have invasive weeds been cleared?	☐	☐		
Has accumulated sediment from upslope contributing sources been cleared?	☐	☐		
Is standing water properly infiltrating or evaporating 96 hours after storm events?	☐	☐		
For dripline trenches: is the 5-foot zone next to the structure free of combustible material, per fire defensible space guidelines?	☐	☐		

☐ 2. Infiltration Basin

Chapter 4.1-b

For vegetated basins, inspect plant health and replace dead plants.

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is stormwater conveyed to functioning inlets and outlets?	☐	☐		
Is erosion or undercutting at the inlets and outlets stabilized, especially along adjacent pavement?	☐	☐		
Is the basin clear of trash and debris (inlet, outlet, and within the structure)?	☐	☐		
Have invasive weeds been cleared?	☐	☐		
Is standing water properly infiltrating or evaporating 96 hours after storm events? If no, the basin may need to be cleaned or rebuilt.	☐	☐		

☐ 3. Sediment Trap

Chapter 4.4-i

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is the sediment trap structurally intact and properly capturing and conveying stormwater?	☐	☐		
Is the trap clear of trash and debris (inlet, outlet, and within the structure)?	☐	☐		
Is standing water properly infiltrating or evaporating 96 hours after storm events?	☐	☐		

☐ 4. Drop Inlet (Drain Inlet)

Chapter 4.3-e

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is the drop inlet structurally intact and properly capturing and conveying stormwater?	☐	☐		
Is the system clear of trash and debris (inlet, outlet, and within the structure)?	☐	☐		
Has accumulated sediment from upslope contributing sources been cleared?	☐	☐		
Is standing water properly infiltrating or evaporating 96 hours after storm events?	☐	☐		

☐ 5. Drop Inlet Insert (Drain Inlet Insert)

Chapter 4.4-d

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is the insert in place?	☐	☐		
Does the insert appear to be functioning properly? Refer to the manufacturer's instructions.	☐	☐		

☐ 6. Slotted Channel Drain

Chapter 4.3-g

Drains without removable grates may need a vacuum truck to clean.

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is the drain structurally intact and properly capturing and conveying stormwater?	☐	☐		
Is the drain clear of trash and debris (inlet, outlet, and within the structure)?	☐	☐		
Has accumulated sediment from upslope contributing sources been cleared?	☐	☐		
Is standing water properly infiltrating or evaporating 96 hours after storm events?	☐	☐		

☐ 7. Curb and Gutter

Chapter 4.3-b

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Are the curbs and gutters structurally intact and properly conveying stormwater?	☐	☐		
Are the curbs and gutters clear of trash and debris?	☐	☐		

☐ 8. Asphalt or Concrete Swale

Chapter 4.3-h

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is the swale structurally intact and properly capturing and conveying stormwater?	☐	☐		
Has accumulated sediment from upslope contributing sources been cleared?	☐	☐		

☐ 9. Rock-Lined or Vegetated Swale

Chapter 4.3-j

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is stormwater from impervious surfaces properly reaching and conveyed by the swale?	☐	☐		
Is the swale clear of trash and debris?	☐	☐		
Has accumulated sediment that would reduce swale capacity been cleared?	☐	☐		
Is erosion or undercutting at the inlets and outlets stabilized, especially along adjacent pavement?	☐	☐		
Rock-lined: have dislodged or unstable rocks been reoriented?	☐	☐		
Vegetated: is adequate vegetation present to prevent erosion?	☐	☐		
Vegetated: is the vegetation adequately mowed or pruned?	☐	☐		

☐ 10. Vegetation (including under driplines)

Chapter 4.1-c

Per fire defensible space guidelines, keep combustible material out of the 5-foot zone next to structures.

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Have eroding areas been stabilized?	☐	☐		
Is the area clear of trash, debris, and excess sediment?	☐	☐		
Is adequate vegetation present to prevent erosion and support infiltration? Inspect plant health and replace dead plants.	☐	☐		
Have invasive weeds been cleared?	☐	☐		

☐ 11. Subsurface Infiltration System

Chapter 4.1-d

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Are the system components structurally intact and functioning as designed?	☐	☐		
Is the system clear of sediment and debris (inlet, outlet, and within the structure)?	☐	☐		
Has the system been serviced (vacuum truck) according to the manufacturer's specifications?	☐	☐		

☐ 12. Parking and Vehicle Barriers

Chapter 4.2-l

Chapter 60.4 of the TRPA Code of Ordinances requires vehicle access to be limited to paved areas.

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is vehicle access restricted to paved areas?	☐	☐		
Are all barriers structurally intact, and properly spaced and sized to prevent vehicle access?	☐	☐		
Have barriers that were moved for site management, such as snow storage, been put back?	☐	☐		

☐ 13. Baffled Vault or Hydrodynamic Separator

Chapter 4.4-f, 4.4-g

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Has the system been serviced (vacuum truck) according to the manufacturer's specifications?	☐	☐		

☐ 14. Slope Stabilization

Chapter 4.2-d through 4.2-h

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is loose or bare soil stabilized by an appropriate measure (vegetation, terracing, rock, retaining wall)?	☐	☐		

☐ 15. Pervious Pavement or Paver Stones

Chapter 4.1-a

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is the surface structurally intact and properly capturing and infiltrating stormwater?	☐	☐		
Has accumulated sediment been cleared manually or by a contracted service?	☐	☐		
If there is an outlet pipe, is it functioning properly?	☐	☐		
Are all areas upslope of the surface stabilized?	☐	☐		

☐ 16. Snow Storage

Chapter 4.2-c

Snow storage areas should never be located in stream environment zones or on top of infiltration BMPs.

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is the snow storage location sited upslope of capture and conveyance BMPs?	☐	☐		
Is the snow storage area sized at roughly 20 percent of the area to be plowed?	☐	☐		

☐ 17. Sweeping and Pavement

Chapter 4.2-b, 4.2-i

Commercial street sweepers remove fine sediment that hand sweeping leaves behind.

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Is pavement structurally intact and properly conveying stormwater?	☐	☐		
Has accumulated sediment been cleared manually or by a contracted service?	☐	☐		

☐ 18. Dumpster Management

Chapter 4.2-m

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Are dumpsters located on paved surfaces?	☐	☐		
Are dumpsters closed, latched, and secure against wildlife?	☐	☐		

☐ 19. Hazardous Material Management

Chapter 4.2-n

Proper storage keeps fuels, oils, and chemicals out of stormwater.

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Are storage and containment structures intact, without deteriorating joints or leaks?	☐	☐		
Have all spills been contained, cleaned up, and properly disposed of?	☐	☐		

☐ 20. Fertilizer Management

Chapter 5.4.2

Sites with more than 1 cumulative acre of turf need a fertilizer management plan.

INSPECTION QUESTION	YES	NO	LOCATION	DOCUMENTATION / CORRECTIVE ACTION
Have required monitoring reports been submitted to the proper jurisdictions?	☐	☐		
Are site management personnel trained on the fertilizer management plan?	☐	☐		

21. Other BMPs and notes

Describe erosion, surface runoff, other BMPs on the property, work done by a contractor (attach the invoice), and anything TRPA should know.

Declaration

I declare under penalty of perjury that the information in this log is true and correct to the best of my knowledge, and that I am the owner of the property or authorized to act for the owner.

Signature (type your name)

Date

Submit: email the saved PDF with photos and invoices to bmp@trpa.gov with the APN in the subject line, or use the online BMP Maintenance Documentation form linked from the Maintenance page of the Lake Tahoe BMPs site. Keep a copy for your records.