

HARBOR BUILD - STEEL MILL CERTIFICATE

MATERIAL TEST CERTIFICATE

Synthetic incoming scan | Project Alpha | received 2026-07-29 | CO-014

Certificate no. HB-MTC-260729-17	Status Incoming review	Product Structural plate	Grade S355 equivalent
Heat no. HX-729-ALPHA	Lot no. LOT-07-29	Quantity 24 plates	Thickness 12 mm nominal

CHEMICAL COMPOSITION (mass %)

C 0.16	Mn 1.42	P 0.018	S 0.009	Si 0.28	Al 0.031
-----------	------------	------------	------------	------------	-------------

MECHANICAL TEST RESULTS

Test	Yield strength	Tensile strength	Elongation	Impact test	Result
Tension	382 MPa	541 MPa	24 %	-	Pass
Charpy V	-	-	-	42 J at -20 C	Pass
Dimensional	12.03 mm	-	-	-	Pass

ACCEPTANCE DECLARATION

Material heat and lot records satisfy the stated synthetic project acceptance criteria.
Traceability is retained by heat no. HX-729-ALPHA and lot no. LOT-07-29.
For coordination filing only; this scan is not a supplier release or shipment authorization.

REVIEW ROUTING

Submittal reference	SUB-242 Project Alpha structural package
Review reference	CO-014 coordinated opening steel work
Disposition	Under review - verify against shop package
Record date	2026-07-29

Digitally reproduced incoming record. No real manufacturer, address, personnel, badge, or access information.