

Foundation Amendment

I wish to construct the concrete segments of the foundation using the foxblocks ICF system.

<https://www.foxblocks.com/>

This change will not affect the thickness, strength, or dimensions of the foundation documented in the house plan.

A spokesperson from Fox Block recommended using "Titen HD Heavy-Duty Screw Anchors" instead of the ½" cast-in Hilti Kwik Bolt referenced in Section S-4.0, detail #8. These anchors offer a tensile strength of 125,000 psi, making them more robust. Additionally, they can be positioned nearer to the concrete's outer surfaces compared to expanding bolts.

Documentation of the fox block system and the Titen anchor system are attached. Please contact me with any concerns about this change.

Justin Meyer

permit@justinmeyer.com

303-834-7418